



**STOLL
KEENON
OGDEN**

300 WEST VINE STREET
SUITE 2100
LEXINGTON, KY 40507-1801
MAIN: (859) 231-3000
FAX: (859) 253-1093

LINDSEY W. INGRAM III
DIRECT DIAL: (859) 231-3982
DIRECT FAX: (859) 246-3672
L.Ingram@skofirm.com

March 29, 2013

HAND DELIVERED

Jeff Derouen
Executive Director
Public Service Commission
211 Sower Boulevard
Frankfort, Kentucky 40601

Re: Case No. 2009-00253

Dear Mr. Derouen:

Ordering Paragraph 6 of the Commission's October 5, 2011 Order in the above-referenced matter requires this firm's client, Kentucky American Water, to file a written report of the test results of 200 15-year 5/8 inch meters tested in 2012. Enclosed please find an original and ten copies of the test results and a summary thereof. Please let me know if you have any questions and thank you for your attention to this matter.

Very truly yours,

Stoll Keenon Ogden PLLC

Lindsey W. Ingram III

Enclosures

010311.003026/4111865.1

Pursuant to the Commission's October 5, 2011 Order in Case No. 2009-00253, Kentucky American Water tested 209 randomly selected meters that became 15 years old in 2012.

Currently, functioning meters are tested for low, medium and high flow rates. Meters that are stuck are not included in these results because they represent nonfunctioning meters. The current testing procedure for low, medium, and high flow rates is in accordance with what is required by the Commission for normal accuracy testing.

The actual type of analysis performed to establish accuracy is a means analysis test. This method is consistent with the 10 year pilot study authorized by the Commission on September 30, 1997. Meter accuracy for various flow levels was measured by a means analysis that was compared to the established acceptable accuracy rates of the pilot for each type of test. The mean of a set of data is the same as the average. The average for the sample was calculated. An average of the low tests that under-registers by 10% or over-registers by 1% will be considered an indicator of inaccuracy. An average that under-registers by 1.5% or over-registers by 1.5% for the medium and high tests was considered an indication of inaccurate meters.

Table 1 provides the detailed test for the 15-year old meters tested in 2012. Note that stuck and broken meters are treated outside the analysis. For the means test to be undertaken, meters were selected in a random fashion from the meters that were 15 years old in 2012.

Table 1							
Kentucky American Water Sample Tests 2012							
Sample Summary Table							
Mean Analysis							
	Low Flow Test		Medium Flow Test		High Flow Test		Means
Year of Meter	Mean	Below 10% or Above 1%	Mean	Below 1.5% or Above 1.5%	Mean	Below 1.5% or Above 1.5%	Test Accurate?
15-Year	96.38%	No	100.73%	No	100.41%	No	Yes

15-Year Old Meter Accuracy

The above results show that the means tests for the three flow tests were accurate where 100% represents full accuracy for the 15-year old meters. Because all three tests were accurate, the test for the 15-year old meters was considered accurate for 2012.

**For The Kentucky Public Service Commission
 Sampling Of Fifteen Year Old Meters
 Installation Date 1997
 Year Tested 2012**

Average		
Low	Medium	High
96.38	100.73	100.41

Average		
Low	Medium	High
Pass	Pass	Pass

ID	Meter Number	Manufacturer	Model	Installation Date	Test Results				Status			
					Low	Medium	High	Average	Low	Medium	High	Overall
1	000440845T	Trident	T-10	1997	95	101	100.6	98.87	Pass	Pass	Pass	Pass
2	000442711T	Trident	T-10	1997	97	101	100.6	99.53	Pass	Pass	Pass	Pass
3	000442724T	Trident	T-10	1997	99	102	101.4	100.80	Pass	Fail	Pass	Fail
4	000442727T	Trident	T-10	1997	100	102	101.4	101.13	Pass	Fail	Pass	Fail
5	000442739T	Trident	T-10	1997	96	100	100.4	98.80	Pass	Pass	Pass	Pass
6	000442740T	Trident	T-10	1997	100	101	101.1	100.70	Pass	Pass	Pass	Pass
7	000442747T	Trident	T-10	1997	98	100	100.6	99.53	Pass	Pass	Pass	Pass
8	000442819T	Trident	T-10	1997	99	101	100.5	100.17	Pass	Pass	Pass	Pass
9	000442820T	Trident	T-10	1997	101	101	101.3	101.10	Pass	Pass	Pass	Pass
10	000442822T	Trident	T-10	1997	99	101	100.7	100.23	Pass	Pass	Pass	Pass
11	000442843T	Trident	T-10	1997	99	100	99.5	99.50	Pass	Pass	Pass	Pass
12	000442849T	Trident	T-10	1997	96	101	99.9	98.97	Pass	Pass	Pass	Pass
13	000442880T	Trident	T-10	1997	99	101	100.2	100.07	Pass	Pass	Pass	Pass
14	000442900T	Trident	T-10	1997	100	101	100.9	100.63	Pass	Pass	Pass	Pass
15	000442935T	Trident	T-10	1997	98	99	100.5	99.17	Pass	Pass	Pass	Pass
16	000442972T	Trident	T-10	1997	51	101	101.2	84.40	Fail	Pass	Pass	Fail
17	000443005T	Trident	T-10	1997	97	101	99.7	99.23	Pass	Pass	Pass	Pass
18	000443025T	Trident	T-10	1997	99	101	100.7	100.23	Pass	Pass	Pass	Pass
19	000443048T	Trident	T-10	1997	97	101	100.4	99.47	Pass	Pass	Pass	Pass
20	000443052T	Trident	T-10	1997	94	101	100.3	98.43	Pass	Pass	Pass	Pass
21	000443062T	Trident	T-10	1997	96	101	100.7	99.23	Pass	Pass	Pass	Pass
22	000443070T	Trident	T-10	1997	97	101	100.4	99.47	Pass	Pass	Pass	Pass
23	000443087T	Trident	T-10	1997	100	101	100.6	100.53	Pass	Pass	Pass	Pass
24	000443091T	Trident	T-10	1997	99	101	101.3	100.43	Pass	Pass	Pass	Pass
25	000443092T	Trident	T-10	1997	98	101	100.6	99.87	Pass	Pass	Pass	Pass

ID	Meter		Installation Date	Test Results				Status				
	Number	Manufacturer		Model	Low	Medium	High	Average	Low	Medium	High	Overall
26	000443093T	Trident	T-10	1997	99	101	100.7	100.23	Pass	Pass	Pass	Pass
27	000443218T	Trident	T-10	1997	98	101	100.1	99.70	Pass	Pass	Pass	Pass
28	000443245T	Trident	T-10	1997	101	101	101.4	101.13	Pass	Pass	Pass	Pass
29	000443288T	Trident	T-10	1997	97	101	100.6	99.53	Pass	Pass	Pass	Pass
30	000443313T	Trident	T-10	1997	97	101	100.6	99.53	Pass	Pass	Pass	Pass
31	000443353T	Trident	T-10	1997	98	101	100.8	99.93	Pass	Pass	Pass	Pass
32	000443453T	Trident	T-10	1997	96	100	99.2	98.40	Pass	Pass	Pass	Pass
33	000443454T	Trident	T-10	1997	100	100	100.6	100.20	Pass	Pass	Pass	Pass
34	000443458T	Trident	T-10	1997	96	100	99.8	98.60	Pass	Pass	Pass	Pass
35	000443459T	Trident	T-10	1997	97	101	100.1	99.37	Pass	Pass	Pass	Pass
36	000443460T	Trident	T-10	1997	99	100	99.7	99.57	Pass	Pass	Pass	Pass
37	000443471T	Trident	T-10	1997	98	101	100.5	99.83	Pass	Pass	Pass	Pass
38	000443488T	Trident	T-10	1997	97	101	100.0	99.33	Pass	Pass	Pass	Pass
39	000443522T	Trident	T-10	1997	96	101	100.0	99.00	Pass	Pass	Pass	Pass
40	000443564T	Trident	T-10	1997	99	101	100.7	100.23	Pass	Pass	Pass	Pass
41	000443586T	Trident	T-10	1997	100	101	100.5	100.50	Pass	Pass	Pass	Pass
42	000443593T	Trident	T-10	1997	97	101	101.1	99.70	Pass	Pass	Pass	Pass
43	000443658T	Trident	T-10	1997	99	100	100.4	99.80	Pass	Pass	Pass	Pass
44	000443691T	Trident	T-10	1997	99	100	100.0	99.67	Pass	Pass	Pass	Pass
45	000443713T	Trident	T-10	1997	98	100	100.0	99.33	Pass	Pass	Pass	Pass
46	000443716T	Trident	T-10	1997	98	101	100.3	99.77	Pass	Pass	Pass	Pass
47	000443717T	Trident	T-10	1997	98	101	99.9	99.63	Pass	Pass	Pass	Pass
48	000443812T	Trident	T-10	1997	99	101	99.8	99.93	Pass	Pass	Pass	Pass
49	000443841T	Trident	T-10	1997	99	101	100.9	100.30	Pass	Pass	Pass	Pass
50	000444061T	Trident	T-10	1997	97	101	100.3	99.43	Pass	Pass	Pass	Pass
51	000444076T	Trident	T-10	1997	97	101	101.3	99.77	Pass	Pass	Pass	Pass
52	000444080T	Trident	T-10	1997	98	100	100.0	99.33	Pass	Pass	Pass	Pass
53	000444116T	Trident	T-10	1997	98	101	100.4	99.80	Pass	Pass	Pass	Pass
54	000444122T	Trident	T-10	1997	98	101	100.8	99.93	Pass	Pass	Pass	Pass
55	000444213T	Trident	T-10	1997	99	101	100.9	100.30	Pass	Pass	Pass	Pass
56	000444257T	Trident	T-10	1997	100	101	100.7	100.57	Pass	Pass	Pass	Pass
57	000444290T	Trident	T-10	1997	99	101	100.6	100.20	Pass	Pass	Pass	Pass
58	000444304T	Trident	T-10	1997	98	101	100.8	99.93	Pass	Pass	Pass	Pass
59	000444375T	Trident	T-10	1997	98	101	100.7	99.90	Pass	Pass	Pass	Pass
60	000444383T	Trident	T-10	1997	98	101	100.7	99.90	Pass	Pass	Pass	Pass

ID	Meter Number	Manufacturer	Model	Installation Date	Test Results				Status			
					Low	Medium	High	Average	Low	Medium	High	Overall
61	000444397T	Trident	T-10	1997	100	101	100.7	100.57	Pass	Pass	Pass	Pass
62	000444413T	Trident	T-10	1997	98	100	100.6	99.53	Pass	Pass	Pass	Pass
63	000444424T	Trident	T-10	1997	-	97	100.9	65.97	Fail	Fail	Pass	Fail
64	000444425T	Trident	T-10	1997	101	101	100.9	100.97	Pass	Pass	Pass	Pass
65	000444426T	Trident	T-10	1997	98	101	100.1	99.70	Pass	Pass	Pass	Pass
66	000444427T	Trident	T-10	1997	98	101	100.3	99.77	Pass	Pass	Pass	Pass
67	000444429T	Trident	T-10	1997	101	101	101.4	101.13	Pass	Pass	Pass	Pass
68	000444432T	Trident	T-10	1997	99	101	100.9	100.30	Pass	Pass	Pass	Pass
69	000444433T	Trident	T-10	1997	98	101	99.5	99.50	Pass	Pass	Pass	Pass
70	000444444T	Trident	T-10	1997	101	101	101.2	101.07	Pass	Pass	Pass	Pass
71	000444445T	Trident	T-10	1997	99	101	100.8	100.27	Pass	Pass	Pass	Pass
72	000444458T	Trident	T-10	1997	100	100	100.4	100.13	Pass	Pass	Pass	Pass
73	000444459T	Trident	T-10	1997	101	100	100.1	100.37	Pass	Pass	Pass	Pass
74	000444465T	Trident	T-10	1997	100	101	101.3	100.77	Pass	Pass	Pass	Pass
75	000444466T	Trident	T-10	1997	99	101	100.8	100.27	Pass	Pass	Pass	Pass
76	000444467T	Trident	T-10	1997	101	101	101.5	101.17	Pass	Pass	Pass	Pass
77	000444471T	Trident	T-10	1997	100	101	100.2	100.40	Pass	Pass	Pass	Pass
78	000444475T	Trident	T-10	1997	97	101	100.5	99.50	Pass	Pass	Pass	Pass
79	000444476T	Trident	T-10	1997	97	101	100.7	99.57	Pass	Pass	Pass	Pass
80	000444477T	Trident	T-10	1997	98	100	100.0	99.33	Pass	Pass	Pass	Pass
81	000444478T	Trident	T-10	1997	99	100	100.1	99.70	Pass	Pass	Pass	Pass
82	000444530T	Trident	T-10	1997	100	102	101.3	101.10	Pass	Fail	Pass	Fail
83	000444531T	Trident	T-10	1997	95	101	100.5	98.83	Pass	Pass	Pass	Pass
84	000444565T	Trident	T-10	1997	100	101	101.0	100.67	Pass	Pass	Pass	Pass
85	000444577T	Trident	T-10	1997	99	101	100.4	100.13	Pass	Pass	Pass	Pass
86	000444585T	Trident	T-10	1997	98	100	100.3	99.43	Pass	Pass	Pass	Pass
87	000444602T	Trident	T-10	1997	98	101	100.5	99.83	Pass	Pass	Pass	Pass
88	000444609T	Trident	T-10	1997	99	101	100.6	100.20	Pass	Pass	Pass	Pass
89	000444615T	Trident	T-10	1997	98	101	100.8	99.93	Pass	Pass	Pass	Pass
90	000444622T	Trident	T-10	1997	97	101	100.7	99.57	Pass	Pass	Pass	Pass
91	000444644T	Trident	T-10	1997	97	101	100.6	99.53	Pass	Pass	Pass	Pass
92	000444645T	Trident	T-10	1997	98	102	100.8	100.27	Pass	Fail	Pass	Fail
93	000444648T	Trident	T-10	1997	101	102	101.5	101.50	Pass	Fail	Pass	Fail
94	000444654T	Trident	T-10	1997	99	101	100.9	100.30	Pass	Pass	Pass	Pass
95	000444656T	Trident	T-10	1997	100	101	100.8	100.60	Pass	Pass	Pass	Pass

ID	Meter Number	Manufacturer	Model	Installation Date	Test Results				Status			
					Low	Medium	High	Average	Low	Medium	High	Overall
96	000444660T	Trident	T-10	1997	99	101	101.2	100.40	Pass	Pass	Pass	Pass
97	000444707T	Trident	T-10	1997	100	101	101.4	100.80	Pass	Pass	Pass	Pass
98	000444713T	Trident	T-10	1997	101	100	101.4	100.80	Pass	Pass	Pass	Pass
99	000444714T	Trident	T-10	1997	96	101	100.7	99.23	Pass	Pass	Pass	Pass
100	000444723T	Trident	T-10	1997	97	101	100.3	99.43	Pass	Pass	Pass	Pass
101	000444738T	Trident	T-10	1997	98	101	99.4	99.47	Pass	Pass	Pass	Pass
102	000444747T	Trident	T-10	1997	95	101	100.3	98.77	Pass	Pass	Pass	Pass
103	000444770T	Trident	T-10	1997	98	101	99.8	99.60	Pass	Pass	Pass	Pass
104	000444772T	Trident	T-10	1997	98	101	100.5	99.83	Pass	Pass	Pass	Pass
105	000444781T	Trident	T-10	1997	98	101	100.6	99.87	Pass	Pass	Pass	Pass
106	000444785T	Trident	T-10	1997	98	101	100.8	99.93	Pass	Pass	Pass	Pass
107	000444794T	Trident	T-10	1997	97	101	100.2	99.40	Pass	Pass	Pass	Pass
108	000444804T	Trident	T-10	1997	94	101	101.3	98.77	Pass	Pass	Pass	Pass
109	000444829T	Trident	T-10	1997	98	101	100.5	99.83	Pass	Pass	Pass	Pass
110	000444831T	Trident	T-10	1997	97	102	101.5	100.17	Pass	Fail	Pass	Fail
111	000444864T	Trident	T-10	1997	96	100	100.2	98.73	Pass	Pass	Pass	Pass
112	000444865T	Trident	T-10	1997	97	100	98.7	98.57	Pass	Pass	Pass	Pass
113	000444880T	Trident	T-10	1997	98	101	100.0	99.67	Pass	Pass	Pass	Pass
114	000444910T	Trident	T-10	1997	99	101	100.8	100.27	Pass	Pass	Pass	Pass
115	000444947T	Trident	T-10	1997	97	101	100.8	99.60	Pass	Pass	Pass	Pass
116	000444991T	Trident	T-10	1997	98	101	101.5	100.17	Pass	Pass	Pass	Pass
117	000444992T	Trident	T-10	1997	94	101	101.0	98.67	Pass	Pass	Pass	Pass
118	000444995T	Trident	T-10	1997	100	101	100.8	100.60	Pass	Pass	Pass	Pass
119	000445024T	Trident	T-10	1997	99	101	100.8	100.27	Pass	Pass	Pass	Pass
120	000445033T	Trident	T-10	1997	95	101	100.6	98.87	Pass	Pass	Pass	Pass
121	000445096T	Trident	T-10	1997	97	101	100.3	99.43	Pass	Pass	Pass	Pass
122	000445098T	Trident	T-10	1997	98	100	99.7	99.23	Pass	Pass	Pass	Pass
123	000445255T	Trident	T-10	1997	94	100	99.3	97.77	Pass	Pass	Pass	Pass
124	000445285T	Trident	T-10	1997	96	99	99.1	98.03	Pass	Pass	Pass	Pass
125	000445292T	Trident	T-10	1997	97	101	99.9	99.30	Pass	Pass	Pass	Pass
126	000445370T	Trident	T-10	1997	100	101	101.0	100.67	Pass	Pass	Pass	Pass
127	000445372T	Trident	T-10	1997	96	99	99.7	98.23	Pass	Pass	Pass	Pass
128	000445373T	Trident	T-10	1997	98	101	100.1	99.70	Pass	Pass	Pass	Pass
129	000445399T	Trident	T-10	1997	100	101	100.3	100.43	Pass	Pass	Pass	Pass
130	000445400T	Trident	T-10	1997	99	101	100.9	100.30	Pass	Pass	Pass	Pass

ID	Meter Number	Manufacturer	Model	Installation Date	Test Results				Status			
					Low	Medium	High	Average	Low	Medium	High	Overall
131	000445403T	Trident	T-10	1997	98	101	100.8	99.93	Pass	Pass	Pass	Pass
132	000445473T	Trident	T-10	1997	96	101	100.4	99.13	Pass	Pass	Pass	Pass
133	000445479T	Trident	T-10	1997	97	101	99.8	99.27	Pass	Pass	Pass	Pass
134	000445952T	Trident	T-10	1997	97	100	100.1	99.03	Pass	Pass	Pass	Pass
135	000446025T	Trident	T-10	1997	100	101	100.9	100.63	Pass	Pass	Pass	Pass
136	000446047T	Trident	T-10	1997	97	101	100.0	99.33	Pass	Pass	Pass	Pass
137	000446128T	Trident	T-10	1997	95	100	100.1	98.37	Pass	Pass	Pass	Pass
138	000446135T	Trident	T-10	1997	98	101	99.5	99.50	Pass	Pass	Pass	Pass
139	000446148T	Trident	T-10	1997	94	102	100.7	98.90	Pass	Fail	Pass	Fail
140	000446165T	Trident	T-10	1997	96	99	99.4	98.13	Pass	Pass	Pass	Pass
141	000446192T	Trident	T-10	1997	99	101	100.4	100.13	Pass	Pass	Pass	Pass
142	000446202T	Trident	T-10	1997	96	101	100.4	99.13	Pass	Pass	Pass	Pass
143	000446236T	Trident	T-10	1997	98	101	100.9	99.97	Pass	Pass	Pass	Pass
144	000446237T	Trident	T-10	1997	98	101	100.7	99.90	Pass	Pass	Pass	Pass
145	000446238T	Trident	T-10	1997	96	101	100.5	99.17	Pass	Pass	Pass	Pass
146	000446239T	Trident	T-10	1997	99	101	100.4	100.13	Pass	Pass	Pass	Pass
147	000446240T	Trident	T-10	1997	98	101	101.0	100.00	Pass	Pass	Pass	Pass
148	000446304T	Trident	T-10	1997	97	101	100.0	99.33	Pass	Pass	Pass	Pass
149	000446318T	Trident	T-10	1997	98	100	100.8	99.60	Pass	Pass	Pass	Pass
150	000446362T	Trident	T-10	1997	95	101	99.5	98.50	Pass	Pass	Pass	Pass
151	000446401T	Trident	T-10	1997	100	101	100.5	100.50	Pass	Pass	Pass	Pass
152	000446430T	Trident	T-10	1997	95	100	99.2	98.07	Pass	Pass	Pass	Pass
153	000446448T	Trident	T-10	1997	98	100	100.3	99.43	Pass	Pass	Pass	Pass
154	000446454T	Trident	T-10	1997	96	100	100.4	98.80	Pass	Pass	Pass	Pass
155	000446461T	Trident	T-10	1997	94	100	99.3	97.77	Pass	Pass	Pass	Pass
156	000446463T	Trident	T-10	1997	99	101	101.1	100.37	Pass	Pass	Pass	Pass
157	000446485T	Trident	T-10	1997	94	100	99.1	97.70	Pass	Pass	Pass	Pass
158	000446487T	Trident	T-10	1997	100	101	100.1	100.37	Pass	Pass	Pass	Pass
159	000446502T	Trident	T-10	1997	97	100	99.6	98.87	Pass	Pass	Pass	Pass
160	000446504T	Trident	T-10	1997	95	100	99.8	98.27	Pass	Pass	Pass	Pass
161	000446517T	Trident	T-10	1997	97	101	100.6	99.53	Pass	Pass	Pass	Pass
162	000446519T	Trident	T-10	1997	96	101	100.6	99.20	Pass	Pass	Pass	Pass
163	000446553T	Trident	T-10	1997	98	101	101.3	100.10	Pass	Pass	Pass	Pass
164	000446567T	Trident	T-10	1997	99	101	100.5	100.17	Pass	Pass	Pass	Pass
165	000446586T	Trident	T-10	1997	97	100	100.1	99.03	Pass	Pass	Pass	Pass

ID	Meter Number	Manufacturer	Model	Installation Date	Test Results				Status			
					Low	Medium	High	Average	Low	Medium	High	Overall
166	000446653T	Trident	T-10	1997	96	100	99.5	98.50	Pass	Pass	Pass	Pass
167	000446684T	Trident	T-10	1997	95	100	100.0	98.33	Pass	Pass	Pass	Pass
168	000446754T	Trident	T-10	1997	97	100	100.7	99.23	Pass	Pass	Pass	Pass
169	000446768T	Trident	T-10	1997	97	100	99.2	98.73	Pass	Pass	Pass	Pass
170	000446772T	Trident	T-10	1997	100	98	101.0	99.67	Pass	Fail	Pass	Fail
171	000446793T	Trident	T-10	1997	92	100	99.8	97.27	Pass	Pass	Pass	Pass
172	000446805T	Trident	T-10	1997	98	101	100.1	99.70	Pass	Pass	Pass	Pass
173	000446808T	Trident	T-10	1997	100	100	99.2	99.73	Pass	Pass	Pass	Pass
174	000446815T	Trident	T-10	1997	98	101	100.4	99.80	Pass	Pass	Pass	Pass
175	000446838T	Trident	T-10	1997	98	101	99.8	99.60	Pass	Pass	Pass	Pass
176	000446856T	Trident	T-10	1997	93	100	99.9	97.63	Pass	Pass	Pass	Pass
177	000446862T	Trident	T-10	1997	95	101	100.0	98.67	Pass	Pass	Pass	Pass
178	000446863T	Trident	T-10	1997	96	100	100.1	98.70	Pass	Pass	Pass	Pass
179	000446869T	Trident	T-10	1997	97	100	99.3	98.77	Pass	Pass	Pass	Pass
180	000446872T	Trident	T-10	1997	94	101	100.2	98.40	Pass	Pass	Pass	Pass
181	000446873T	Trident	T-10	1997	95	100	100.3	98.43	Pass	Pass	Pass	Pass
182	000446883T	Trident	T-10	1997	95	100	99.6	98.20	Pass	Pass	Pass	Pass
183	000446896T	Trident	T-10	1997	98	101	99.6	99.53	Pass	Pass	Pass	Pass
184	000446913T	Trident	T-10	1997	96	100	100.3	98.77	Pass	Pass	Pass	Pass
185	000446955T	Trident	T-10	1997	98	101	101.2	100.07	Pass	Pass	Pass	Pass
186	000446958T	Trident	T-10	1997	94	100	101.3	98.43	Pass	Pass	Pass	Pass
187	000446992T	Trident	T-10	1997	98	101	101.4	100.13	Pass	Pass	Pass	Pass
188	000447001T	Trident	T-10	1997	96	100	99.1	98.37	Pass	Pass	Pass	Pass
189	000447006T	Trident	T-10	1997	96	100	99.6	98.53	Pass	Pass	Pass	Pass
190	000447027T	Trident	T-10	1997	95	101	100.8	98.93	Pass	Pass	Pass	Pass
191	000447029T	Trident	T-10	1997	96	101	100.1	99.03	Pass	Pass	Pass	Pass
192	000447118T	Trident	T-10	1997	96	100	99.1	98.37	Pass	Pass	Pass	Pass
193	000447145T	Trident	T-10	1997	96	101	100.5	99.17	Pass	Pass	Pass	Pass
194	000447149T	Trident	T-10	1997	96	101	101.4	99.47	Pass	Pass	Pass	Pass
195	000447162T	Trident	T-10	1997	99	101	101.0	100.33	Pass	Pass	Pass	Pass
196	000447167T	Trident	T-10	1997	96	101	100.3	99.10	Pass	Pass	Pass	Pass
197	000447171T	Trident	T-10	1997	96	100	99.2	98.40	Pass	Pass	Pass	Pass
198	000447186T	Trident	T-10	1997	97	101	100.5	99.50	Pass	Pass	Pass	Pass
199	000447188T	Trident	T-10	1997	95	101	101.0	99.00	Pass	Pass	Pass	Pass
200	000447191T	Trident	T-10	1997	-	103	101.7	68.23	Fail	Fail	Fail	Fail

ID	Meter Number	Manufacturer	Model	Installation Date	Test Results				Status			
					Low	Medium	High	Average	Low	Medium	High	Overall
201	000447231T	Trident	T-10	1997	97	101	101.0	99.67	Pass	Pass	Pass	Pass
202	000447287T	Trident	T-10	1997	95	100	99.7	98.23	Pass	Pass	Pass	Pass
203	000447288T	Trident	T-10	1997	92	101	100.3	97.77	Pass	Pass	Pass	Pass
204	000447310T	Trident	T-10	1997	98	101	100.5	99.83	Pass	Pass	Pass	Pass
205	000447311T	Trident	T-10	1997	95	103	100.8	99.60	Pass	Fail	Pass	Fail
206	000447640T	Trident	T-10	1997	95	100	99.7	98.23	Pass	Pass	Pass	Pass
207	000448231T	Trident	T-10	1997	94	101	99.7	98.23	Pass	Pass	Pass	Pass
208	000448415T	Trident	T-10	1997	95	100	99.1	98.03	Pass	Pass	Pass	Pass
209	000448416T	Trident	T-10	1997	96	101	99.6	98.87	Pass	Pass	Pass	Pass