

MAR 3 1 2016

Public Service Commission

Electric Distribution Utility Annual Reliability Report

### SECTION 1: CONTACT INFORMATION

UTILITY NAME REPORT PREPARED BY E-MAIL ADDRESS OF PREPARER E-MAIL ADDRESS OF PREPARER E-MAIL ADDRESS OF PREPARER PHONE NUMBER OF PREPARER Grayson Rural Electric Cooperative Corporation Brian Poling/Mike Martin/Kyle Clevenger <u>brian.poling@graysonrecc.com</u> <u>mike.martin@graysonrecc.com</u> <u>kyle.clevenger@graysonrecc.com</u> 606-474-5136

### SECTION 2: REPORTING YEAR

CALENDAR YEAR OF REPORT

2015

### SECTION 3: MAJOR EVENT DAYS (MED)

| Тмер                             | 53.18      |  |
|----------------------------------|------------|--|
|                                  | 1/1/2015   |  |
| LAST DATE USED TO DETERMINE TMED | 12/31/2015 |  |
| NUMBER OF MED IN REPORT YEAR     | 6          |  |

NOTE: Per IEEE Tmed should be calculated using the daily SAIDI values for the five prior years. If five years of data are not available, then utilities should use what is available until five years are accumulated

| SECTION 4: SYSTEM RELIABILITY INFORMATION AND RESULTS |   |   |  |  |
|---|---|---|--|--|
| System-wide Information                               |   |   |  |  |
| 14,969  | TOTAL CIRCUITS  | 42  |  |  |
| Excluding MED   |   |   |  |  |
| 5 YEAR AVERAGE  |   | REPORTING YEAR  |  |  |
| 366.5   | SAIDI   | 423.7   |  |  |
| 2.74  | SAIFI   | 3.13  |  |  |
| Including MED   |   |   |  |  |
| 5 YEAR AVERAGE  | _   | REPORTING YEAR  |  |  |
| 1315.3  | SAIDI   | 1642.0  |  |  |
| 3.57  | SAIFI   | 3.13  |  |  |
|   | System-wid<br>14,969<br>Exclud<br>5 YEAR AVERAGE<br>366.5<br>2.74<br>Includ<br>5 YEAR AVERAGE<br>1315.3 | System-wide Information14,969TOTAL CIRCUITSExcluding MED5 YEAR AVERAGESAIDI2.74SAIFIIncluding MED5 YEAR AVERAGESAIDI1315.3SAIDI |  |  |

NOTES:

.

ł

1) All durations indices (SAIDI) are to be reported in units of minutes.

2) Reports are due on the first business day of April of each year.

3) Reports cover the calendar year ending in the December before the reports are due.

4) IEEE 1366 (latest version) issued to define SAIDI, SAIFI and TMED

### SECTION 5: CIRCUIT REPORTING

#### (CIRCUITS WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE)

#### (CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

| 3. Feeder 1   |         |
|---|---------|
| 4. South along Rt. 7 toward Elliott County                                      |         |
| 5. Approximately 28.1 Primary Miles   |         |
| 6. 199 Active Consumers   |         |
| 7. Circuit has been 'hot spot' cut for years. Records don't indicate a full cut | t year. |
| 8. Causes of last years outages:  |         |
| 590 Weather, other  | 44.0%   |
| 430 Tree failure from overhang or dead tree without ice/snow                    | 26.0%   |
| 110 Maintenance   | 10.0%   |
| 500 Lightning   | 4.0%    |
| 600 Small animal/bird   | 4.0%    |
| 740 Public cuts tree  | 4.0%    |
| 410 Corrosion/abrasion of material/equipment                                    | 2.0%    |
| 431 Tree Failure-off ROW  | 2.0%    |
| 800 Other   | 2.0%    |
| 999 Cause unknown   | 2.0%    |
| 9. The average SAIDI is 457.34  |         |
| 10. The SAIDI for 2015 was 364.34   |         |

11. The average SAIFI is 2.9

1. Airport Road (Sub 12)

2. The sub is located on Rt. 986 (Airport Road)

12. The SAIFI for 2015 was 3.10

13. See Section 7

#### SECTION 5: CIRCUIT REPORTING Continued

| 1. | Airport | Road | (Sub | 12) |
|----|---------|------|------|-----|
|----|---------|------|------|-----|

- 2. The sub is located on Rt. 986 (Airport Road)
- 3. Feeder 2

- 4. Follows Airport Road
- 5. Approximately 77.3 Primary Miles
- 6. 505 Active Consumers
- 7. Circuit was partically cut in 2009 and is in progress of a being cut now.
- 8. Causes of last years outages: 590 Weather, other 39.0% 110 Maintenance 18.3% 431 Tree Failure-off ROW 11.0% 300 Material or equipment fault/failure 9.8% 600 Small animal/bird 7.3% 999 Cause unknown 7.3% 520 lce, sleet, frost, not trees 4.9% 500 Lightning 1.2% 800 Other 1.2% 9. The average SAIDI is 762.51
- 10. The SAIDI for 2015 was 1215.12
- 11. The average SAIFI is 5.07
- 12. The SAIFI for 2015 was 5.31
- 13. See Section 7

# SECTION 5: CIRCUIT REPORTING

Continued

| 1. | Airport Road (Sub 12)    |   |
|----|--------------------------|---|
| 0  | The sub is leasted on DA | 0 |

- 2. The sub is located on Rt. 986 (Airport Road)
- 3. Feeder 3

•

- 4. North along Rt. 7 toward Grayson Lake
- 5. Approximately 19.0 Primary Miles
- 6. 102 Active Consumers
- 7. Records indicate this circuit has only been spot cut.

| 8. Causes of last years outages:        |       |
|---|-------|
| 590 Weather, other                      | 43.3% |
| 110 Maintenance                         | 20.0% |
| 300 Material or equipment fault/failure | 13.3% |
| 431 Tree Failure-off ROW                | 6.7%  |
| 600 Small animal/bird                   | 6.7%  |
| 400 Decay/age of material/equipment     | 3.3%  |
| 800 Other                               | 3.3%  |
| 999 Cause unknown                       | 3.3%  |
| 9. The average SAIDI is 831.1           |       |
|   |       |

- 10. The SAIDI for 2015 was 1021.44
- 11. The average SAIFI is 7.49
- 12. The SAIFI for 2015 was 6.22
- 13. See Section 7

#### SECTION 5: CIRCUIT REPORTING Continued

| 1. Argentum Sub | (1) |
|-----------------|-----|
|-----------------|-----|

- 2. Located approx. one half mile north of AA Highway on Rt. 7
- 3. Feeder 1

.

- 4. North along Rt. 7 / Schultz
- 5. Approximately 56.8 Primary Miles
- 6. 549 Active Consumers
- 7. Circuit was last cut in 2011
  8. Causes of last years outages:

| o. Causes of last years outages:             |       |
|--|-------|
| 110 Maintenance                              | 22.1% |
| 590 Weather, other                           | 22.1% |
| 300 Material or equipment fault/failure      | 20.6% |
| 999 Cause unknown                            | 11.8% |
| 431 Tree Failure-off ROW                     | 5.9%  |
| 520 lce, sleet, frost, not trees             | 4.4%  |
| 600 Small animal/bird                        | 4.4%  |
| 500 Lightning                                | 2.9%  |
| 100 Construction                             | 1.5%  |
| 400 Decay/age of material/equipment          | 1.5%  |
| 410 Corrosion/abrasion of material/equipment | 1.5%  |
| 510 Wind, not trees                          | 1.5%  |
| 9. The average SAIDI is 831.1                |       |
|  |       |

- 10. The SAIDI for 2015 was 1021.44
- 11. The average SAIFI is 7.49
- 12. The SAIFI for 2015 was 6.22

13. See Section 7

#### SECTION 5: CIRCUIT REPORTING Continued

- 1. Carter City Sub (10)
- 2. Located approx 0.2 miles north of Jct of 474 on Rt. 2 & 7
- 3. Feeder 1

ŝ

- 4. Sand Suck to Adkins Loop
- 5. Approximately 41.4 Primary Miles
- 6. 226 Active Consumers
- 7. Records indicate circuit has only be 'spot cut'.

| 8. Causes of last years outages:                             |       |
|--|-------|
| 590 Weather, other   | 24.0% |
| 110 Maintenance  | 14.0% |
| 431 Tree Failure-off ROW                                     | 14.0% |
| 600 Small animal/bird  | 12.0% |
| 300 Material or equipment fault/failure                      | 8.0%  |
| 520 Ice, sleet, frost, not trees                             | 6.0%  |
| 340 Overload   | 4.0%  |
| 420 Tree growth  | 4.0%  |
| 700 Customer-caused  | 4.0%  |
| 400 Decay/age of material/equipment                          | 2.0%  |
| 430 Tree failure from overhang or dead tree without ice/snow | 2.0%  |
| 500 Lightning  | 2.0%  |
| 800 Other  | 2.0%  |
| 999 Cause unknown  | 2.0%  |
| 9. The average SAIDI is 486.87                               |       |
|  |       |

- 10. The SAIDI for 2015 was 915.91
- 11. The average SAIFI is 3.62
- 12. The SAIFI for 2015 was 5.79
- 13. See Section 7

### SECTION 5: CIRCUIT REPORTING

#### Continued

- 1. Carter City Sub (10)
- 2. Located approx 0.2 miles north of Jct of 474 on Rt. 2 & 7
- 3. Feeder 2

.

.

.

- 4. Follows Rt. 2
- 5. Approximately 52.4 Primary Miles
- 6. 282 Active Consumers
- 7. Records indicate circuit has only be 'spot cut'.

| 8. Causes of last years outages:             |       |
|--|-------|
| 590 Weather, other                           | 42.9% |
| 110 Maintenance                              | 12.2% |
| 431 Tree Failure-off ROW                     | 10.2% |
| 300 Material or equipment fault/failure      | 6.1%  |
| 520 Ice, sleet, frost, not trees             | 6.1%  |
| 600 Small animal/bird                        | 6.1%  |
| 410 Corrosion/abrasion of material/equipment | 4.1%  |
| 100 Construction                             | 2.0%  |
| 340 Overload                                 | 2.0%  |
| 360 Other equipment installation/design      | 2.0%  |
| 420 Tree growth                              | 2.0%  |
| 500 Lightning                                | 2.0%  |
| 800 Other                                    | 2.0%  |
| 9. The average SAIDI is 356.65               |       |
|  |       |

10. The SAIDI for 2015 was 798.41

11. The average SAIFI is 2.36

- 12. The SAIFI for 2015 was 3.75
- 13. See Section 7

### SECTION 5: CIRCUIT REPORTING

### Continued

- 1. Carter City Sub (10)
- 2. Located approx 0.2 miles north of Jct of 474 on Rt. 2 & 7
- 3. Feeder 3

4

- 4. Follows Rt. 474 (Smith Creek)
- 5. Approximately 27 Primary Miles
- 6. 149 Active Consumers
- 7. Records indicate circuit has only be 'spot cut'.
- 8. Causes of last years outages:

| 431 Tree Failure-off ROW                                     | 23.1% |
|--|-------|
| 400 Decay/age of material/equipment                          | 11.5% |
| 590 Weather, other   | 11.5% |
| 999 Cause unknown  | 11.5% |
| 300 Material or equipment fault/failure                      | 7.7%  |
| 520 lce, sleet, frost, not trees                             | 7.7%  |
| 110 Maintenance  | 5.8%  |
| 340 Overload   | 3.8%  |
| 420 Tree growth  | 3.8%  |
| 430 Tree failure from overhang or dead tree without ice/snow | 3.8%  |
| 600 Small animal/bird  | 3.8%  |
| 470 Borrower crew cuts tree                                  | 1.9%  |
| 730 Fire   | 1.9%  |
| 740 Public cuts tree   | 1.9%  |
| 9. The average SAIDI is 335.78                               |       |
| 10. The SAIDI for 2015 was 751.17                            |       |

- 10. The SAID for 2015 was 751.1
- 11. The average SAIFI is 2.57 12. The SAIFI for 2015 was 4.81
- 13. See Section 7

### SECTION 5: CIRCUIT REPORTING

.

Continued

| 1. Carter City Sub (10)  |       |
|--|-------|
| 2. Located approx 0.2 miles north of Jct of 474 on Rt. 2 & 7       |       |
| 3. Feeder 4  |       |
| 4. Follows Rt. 2 & 7 North   |       |
| 5. Approximately 78 Primary Miles                                  |       |
| 6. 541 Active Consumers  |       |
| <ol><li>Records indicate circuit has only be 'spot cut'.</li></ol> |       |
| 8. Causes of last years outages:                                   |       |
| 590 Weather, other   | 34.9% |
| 520 Ice, sleet, frost, not trees                                   | 15.9% |
| 600 Small animal/bird  | 15.9% |
| 110 Maintenance  | 6.3%  |
| 431 Tree Failure-off ROW   | 6.3%  |
| 300 Material or equipment fault/failure                            | 4.8%  |
| 430 Tree failure from overhang or dead tree without ice/snow       | 4.8%  |
| 100 Construction   | 1.6%  |
| 400 Decay/age of material/equipment                                | 1.6%  |
| 410 Corrosion/abrasion of material/equipment                       | 1.6%  |
| 500 Lightning  | 1.6%  |
| 730 Fire   | 1.6%  |
| 740 Public cuts tree   | 1.6%  |
| 999 Cause unknown  | 1.6%  |
| 9. The average SAIDI is 211.70                                     |       |
| 10. The SAIDI for 2015 was 281.89                                  |       |
| 11 The everyone SAIEL is 1.96                                      |       |

- 11. The average SAIFI is 1.86
- 12. The SAIFI for 2015 was 2.05
- 13. See Section 7

•

#### SECTION 5: CIRCUIT REPORTING Continued

1. Elliotville (Sub 7)

- 2. Located on Fouch Rd off Rt. 32 approx 1.5 miles east of Jct Rt. 504 and Rt. 32
- 3. Feeder 2
- 4. Follows Rt. 32 toward Morehead/Triangle Tower
- 5. Approximately 40 Primary Miles
- 6. 551 Active Consumers
- 7. Records indicate circuit has only be 'spot cut'.
- 8. Causes of last years outages: 110 Maintenance 20.5% 590 Weather, other 15.1% 431 Tree Failure-off ROW 13.7% 600 Small animal/bird 12.3% 999 Cause unknown 12.3% 300 Material or equipment fault/failure 6.8% 500 Lightning 4.1% 400 Decay/age of material/equipment 2.7% 420 Tree growth 2.7% 710 Motor vehicle 2.7% 800 Other 2.7% 1.4% 490 Maintenance, other 520 Ice, sleet, frost, not trees 1.4% 740 Public cuts tree 1.4% 9. The average SAIDI is 405.29
- 10. The SAIDI for 2015 was 463.00
- 11. The average SAIFI is 3.17
- 12. The SAIFI for 2015 was 4.69
- 13. See Section 7

## SECTION 5: CIRCUIT REPORTING

Continued

| 1. Low Gap (Sub 12)  |       |
|--|-------|
| 2. Junction Rt. 2 and Rt. 1459 (Low Gap Road)                      |       |
| 3. Feeder 2  |       |
| <ol><li>Follows Rt. 2 toward Whetstone/River Park</li></ol>        |       |
| 5. Approximately 46.4 Primary Miles                                |       |
| 6. 728 Active Consumers  |       |
| <ol><li>Records indicate circuit has only be 'spot cut'.</li></ol> |       |
| 8. Causes of last years outages:                                   |       |
| 300 Material or equipment fault/failure                            | 20.5% |
| 590 Weather, other   | 17.9% |
| 110 Maintenance  | 12.5% |
| 999 Cause unknown  | 10.7% |
| 431 Tree Failure-off ROW   | 8.9%  |
| 600 Small animal/bird  | 6.3%  |
| 430 Tree failure from overhang or dead tree without ice/snow       | 5.4%  |
| 520 Ice, sleet, frost, not trees                                   | 5.4%  |
| 400 Decay/age of material/equipment                                | 4.5%  |
| 700 Customer-caused  | 1.8%  |
| 800 Other  | 1.8%  |
| 100 Construction   | 0.9%  |
| 360 Other equipment installation/design                            | 0.9%  |
| 420 Tree growth  | 0.9%  |
| 500 Lightning  | 0.9%  |
| 730 Fire   | 0.9%  |
| 9. The average SAIDI is 650.61                                     |       |
| 10. The SAIDI for 2015 was 890.92                                  |       |
| 11 The everage SAIEL is 4 FR                                       |       |

11. The average SAIFI is 4.56

12. The SAIFI for 2015 was 7.25

13. See Section 7

.

### SECTION 5: CIRCUIT REPORTING

Continued

- 1. Mazie Sub (Sub 4)
- 2. Located on Rt. 32 at Mazie
- 3. Feeder 1

,

- 4. Follows Rt. e2 toward Isonville
- 5. Approximately 42.8 Primary Miles
- 6. Active Consumers 288
- 7. Records indicate circuit has only be 'spot cut'.

8. Causes of last years outages:

| 430 Tree failure from overhang or dead tree without ice/snow | 30.8% |
|--|-------|
| 600 Small animal/bird  | 15.4% |
| 431 Tree Failure-off ROW                                     | 11.5% |
| 400 Decay/age of material/equipment                          | 7.7%  |
| 470 Borrower crew cuts tree                                  | 7.7%  |
| 590 Weather, other   | 7.7%  |
| 110 Maintenance  | 3.8%  |
| 340 Overload   | 3.8%  |
| 420 Tree growth  | 3.8%  |
| 520 Ice, sleet, frost, not trees                             | 3.8%  |
| 700 Customer-caused  | 3.8%  |
| 9. The average SAIDI is 642.77                               |       |
|  |       |

10. The SAIDI for 2015 was 1152.36

11. The average SAIFI is 4.09

12. The SAIFI for 2015 was 4.83

13. See Section 7

### SECTION 5: CIRCUIT REPORTING

Continued

| 1. Pelfrey Sub (Sub 5)   |       |
|--|-------|
| 2. Located on US 60 at Pleasant Valley                             |       |
| 3. Feeder 2  |       |
| <ol><li>Goes East toward Cascade Road/Biggs Hill</li></ol>         |       |
| 5. Approximately 27 Primary Miles                                  |       |
| 6. Active Consumers 353  |       |
| <ol><li>Records indicate circuit has only be 'spot cut'.</li></ol> |       |
| 8. Causes of last years outages:                                   |       |
| 590 Weather, other   | 24.6% |
| 600 Small animal/bird  | 18.8% |
| 431 Tree Failure-off ROW   | 11.6% |
| 110 Maintenance  | 8.7%  |
| 300 Material or equipment fault/failure                            | 8.7%  |
| 420 Tree growth  | 5.8%  |
| 500 Lightning  | 5.8%  |
| 340 Overload   | 4.3%  |
| 430 Tree failure from overhang or dead tree without ice/snow       | 4.3%  |
| 520 lce, sleet, frost, not trees                                   | 2.9%  |
| 999 Cause unknown  | 2.9%  |
| 190 Other planned  | 1.4%  |
| 9. The average SAIDI is 221.63                                     |       |
| 10. The SAIDI for 2015 was 238.54                                  |       |

11. The average SAIFI is 2.52

12. The SAIFI for 2015 was 2.47

13. See Section 7

•

÷

## SECTION 5: CIRCUIT REPORTING

Continued

- 1. Pactolus Sub (Sub 8)
- 2. Substation Road off Rt. 1959
- 3. Feeder 2

•

- 4. Follows Along 1947/Sunset Hill/Radio Station
- 5. Approximately 11 Primary Miles
- 6. Active Consumers 244
- 7. Records indicate circuit has only be 'spot cut'.
- 8. Causes of last years outages:

| 110 Maintenan      | 3%           | 24.6% |
|--------------------|--------------|-------|
| 300 Material or    | 10%          | 18.8% |
| 340 Overload       | 3%           | 11.6% |
| 400 Decay/age      | 7%           | 8.7%  |
| 410 Corrosion/     | 3%           | 8.7%  |
| 431 Tree Failu     | 17%          | 5.8%  |
| 520 Ice, sleet,    | 3%           | 5.8%  |
| 590 Weather, (     | 24%          | 4.3%  |
| 600 Small anin     | 24%          | 4.3%  |
| 800 Other          | 3%           | 2.9%  |
| 9. The average SAI | Ol is 283.27 |       |
|                    |              |       |

- 10. The SAIDI for 2015 was 343.34
- 11. The average SAIFI is 2.35
- 12. The SAIFI for 2015 was 2.37
- 13. See Section 7

### SECTION 5: CIRCUIT REPORTING

Continued

| 2. Located on Bank Street in Sandy Hook                            |       |
|--|-------|
| 3. Feeder 1  |       |
| 4. Follows Rt. 7 South then Rt 173                                 |       |
| 5. Approximately 90 Primary Miles                                  |       |
| 6. Active Consumers 635  |       |
| <ol><li>Records indicate circuit has only be 'spot cut'.</li></ol> |       |
| 8. Causes of last years outages:                                   |       |
| 999 Cause unknown  | 23.1% |
| 300 Material or equipment fault/failure                            | 20.0% |
| 590 Weather, other   | 13.8% |
| 110 Maintenance  | 10.8% |
| 360 Other equipment installation/design                            | 4.6%  |
| 400 Decay/age of material/equipment                                | 4.6%  |
| 500 Lightning  | 4.6%  |
| 600 Small animal/bird  | 4.6%  |
| 470 Borrower crew cuts tree  | 3.1%  |
| 100 Construction   | 1.5%  |
| 190 Other planned  | 1.5%  |
| 431 Tree Failure-off ROW   | 1.5%  |
| 610 Large animal   | 1.5%  |
| 700 Customer-caused  | 1.5%  |
| 730 Fire   | 1.5%  |
| 800 Other  | 1.5%  |
| 9. The average SAIDI is 198.79                                     |       |
| 10. The SAIDI for 2015 was 409.40                                  |       |
|  |       |

11. The average SAIFI is 1.96

1. Sandy Hook Sub (Sub 9)

- 12. The SAIFI for 2015 was 3.12
- 13. See Section 7

•

### SECTION 5: CIRCUIT REPORTING

Continued

| <ol><li>Follows Rt. 32 East toward Isonville</li></ol>             |       |
|--|-------|
| 5. Approximately 75 Primary Miles                                  |       |
| 6. Active Consumers 430  |       |
| <ol><li>Records indicate circuit has only be 'spot cut'.</li></ol> |       |
| 8. Causes of last years outages:                                   |       |
| 999 Cause unknown  | 23.1% |
| 300 Material or equipment fault/failure                            | 20.0% |
| 590 Weather, other   | 13.8% |
| 110 Maintenance  | 10.8% |
| 360 Other equipment installation/design                            | 4.6%  |
| 400 Decay/age of material/equipment                                | 4.6%  |
| 500 Lightning  | 4.6%  |
| 600 Small animal/bird  | 4.6%  |
| 470 Borrower crew cuts tree  | 3.1%  |
| 100 Construction   | 1.5%  |
| 190 Other planned  | 1.5%  |
| 431 Tree Failure-off ROW   | 1.5%  |
| 610 Large animal   | 1.5%  |
| 700 Customer-caused  | 1.5%  |
| 730 Fire   | 1.5%  |
| 800 Other  | 1.5%  |
| 9. The average SAIDI is 697.06                                     |       |
| 10. The SAIDI for 2015 was 792.23                                  |       |
|  |       |

11. The average SAIFI is 6.02

1. Sandy Hook Sub (Sub 9)

3. Feeder 3

2. Located on Bank Street in Sandy Hook

- 12. The SAIFI for 2015 was 7.14
- 13. See Section 7

## SECTION 5: CIRCUIT REPORTING

Continued

- 1. Warnock 2 (Sub 6)
- 2. Located about 1/2 mile up Hoods Run from Rt. 2
- 3. Feeder 2

.

- 4. Rt. 2 to Greenbo
- 5. Approximately 3.7 Primary Miles
- 6. Active Consumers 18
- 7. Records indicate circuit has only be 'spot cut'.
- Causes of last years outages: 590 Weather, other 300 Material or equipment fault/failure

80.0% 20.0%

- 9. The average SAIDI is 11.69 10. The SAIDI for 2015 was 13.32
- 11. The average SAIFI is 0.2
- 12. The SAIFI for 2015 was 0.28
- 13. See Section 7

### SECTION 5: CIRCUIT REPORTING Continued

| 1. Warnock Sub (Sub 6)<br>2. Located about 1/2 mile up Hoods Run from Rt. 2 |       |
|---|-------|
| 3. Feeder 4   |       |
| 4. Rt. 2 & 7 South toward Lost Creek  |       |
| 5. Approximately 90 Primary Miles   |       |
| 6. Active Consumers 512   |       |
| 7. Records indicate circuit has only be 'spot cut'.                         |       |
| 8. Causes of last years outages:  |       |
| 110 Maintenance   | 25.5% |
| 520 lce, sleet, frost, not trees  | 20.2% |
| 590 Weather, other  | 10.6% |
| 999 Cause unknown   | 9.6%  |
| 431 Tree Failure-off ROW  | 7.4%  |
| 300 Material or equipment fault/failure                                     | 5.3%  |
| 430 Tree failure from overhang or dead tree without ice/snow                | 5.3%  |
| 400 Decay/age of material/equipment   | 4.3%  |
| 600 Small animal/bird   | 3.2%  |
| 500 Lightning   | 2.1%  |
| 700 Customer-caused   | 2.1%  |
| 100 Construction  | 1.1%  |
| 420 Tree growth   | 1.1%  |
| 730 Fire  | 1.1%  |
| 800 Other   | 1.1%  |
| 9. The average SAIDI is 401.51  |       |
| 10. The SAIDI for 2015 was 572.65   |       |

11. The average SAIFI is 2.82

- 12. The SAIFI for 2015 was 3.56
- 13. See Section 7

•

#### INCLUDE CURRENT VEGETATION MANAGEMENT PLAN Additional pages may be attached as needed.

In 2015 we cleared 109 miles through our circuit cutting program. We also re-cleared 149 miles, bush hogged 30 mines, sprayed 55 miles of overhead lines. We removed 12,364 individual trees and trimmed 7059 yard trees.

Our plans for 2016 include cutting three full circuits: Newfoundland Feeders 1 & 3 and Elliottville Feeder 3 We will also spray Airport Road Feeder #1, Carter City Feeder #3 and Newfoundland Feeder #1.

### SECTION 7: UTILITY COMMENTS

After analyzing our data, we believe our indicies are not a true reflection of the system outage data. We have improved the accuracy of our outage data somewhat over the past year. But, beginning this year we are undertaking a GIS project that will create a complete new set of OMS maps allowing for much more accurate indicies in the future. We will also continue to train and oversee the accuracy of the data being entered.