

P.O. Box 18 \* 6402 Old Corydon Road Henderson, Kentucky 42419-0018 1.800.844.4832

March 30, 2016

RECEIVED

MAR 3 1 2016

PUBLIC SERVICE COMMISSION

Mr. Jeff Derouen Executive Director Public Service Commission of Kentucky 211 Sower Boulevard Frankfort, KY 40602

Subject: Administrative Case No. 2011-00450

Dear Mr. Derouen:

This letter is provided to serve notice that Kenergy has completed and submitted the 2015 Electric Distribution Utility Annual Reliability Report pursuant to Administrative Case Number 2011-00450.

The report accompanies this letter for your review. Please contact me at 270-689-6160 with any questions regarding this report.

Sincerely,

Kennett & Stock

Kenneth R Stock VP of Operations



## Electric Distribution Utility Annual Reliability Report

#### SECTION 1: CONTACT INFORMATION

UTILITY NAME REPORT PREPARED BY E-MAIL ADDRESS OF PREPARER PHONE NUMBER OF PREPARER Kenergy Corp. Kenneth Stock, Robert Hayden, Kevin Holland rhayden@kenergycorp.com

800-844-4832

#### SECTION 2: REPORTING YEAR

CALENDAR YEAR OF REPORT

2015

#### SECTION 3: MAJOR EVENT DAYS (MED)

 $T_{\text{MED}}$ FIRST DATE USED TO DETERMINE T\_{\text{MED}}
LAST DATE USED TO DETERMINE T\_{\text{MED}}
NUMBER OF MED IN REPORT YEAR

15.6328	
1/1/2010	
12/31/2014	
0	

NOTE: Per IEEE 1366 T<sub>MED</sub> should be calculated using the daily SAIDI values for the five prior years. If five years of data are not available, then utilities should use what is available until five years are accumulated.

#### SECTION 4: SYSTEM RELIABILITY INFORMATION AND RESULTS

		System-wide Inform	ation	
т	OTAL CUSTOMERS	56,663	TOTAL CIRCUITS	196
		Excluding MED		
	<b>5 YEAR AVERAGE</b>		REPORTING YEAR	
SAIDI	115.69	SAIDI	94.53	
SAIFI	1.73	SAIFI	1.40	
		Including MED		
	<b>5 YEAR AVERAGE</b>		REPORTING YEAR	
SAIDI	150.55	SAIDI	94.53	
SAIFI	1.90	SAIFI	1.40	

Notes:

1) All duration indices (SAIDI) are to be reported in units of minutes.

2) Reports are due on the first business day of May of each year

3) Reports cover the calendar year ending in the December before the reports are due.

4) IEEE 1366 (latest version) is used to define SAIDI, SAIFI, and T<sub>MED</sub>

#### SECTION 5: CIRCUIT REPORTING SEE ADDITIONAL TABS.

## SECTION 6: VEGETATION MANAGEMENT PLAN REVIEW INCLUDE CURRENT VEGETATION MANAGEMENT PLAN

Additional page may be attached as needed.

Kenergy's vegetation management efforts are continually evaluated to ensure adequacy and effectiveness. During 2015, approximately 1,108 miles of line were cleared which is consistent with the cycle length outlined in Kenergy's Vegetation Management Plan (not to exceed six years). The 2016 scope of work has been developed and is also consistent with Kenergy's cycle length. At this point, Kenergy does not anticipate any significant modifications to the vegetation management program in 2015.

#### SECTION 8: UTILITY COMMENTS

In section 5, "Resolved at time of outage" means that the issue, whether a mechanical failure, public hit pole, tree on the line, animal with guard being installed, or any other means where the issue was corrected and is most likely not going to repeat.

Section 5:1	Substation name and Number	Adams Lane 105			
Section 5:2	Substation Location	CountyHenderson	RoadUS Hwy 41	TownHenderson	
Section 5:3	Circuit Name and Number	Happy Acres Feeder 1			
Section 5:4	Circuit Location	Hwy 41 South			
Section 5:5	Total Circuit Length	16.71			
Section 5:6	Member count for this circuit	223			
Section 5:7	Date of last circuit trim (VM)	2011/2016			
Section 5:8	List outage causes for circuit along	with % of total outage num	bers represented by eac	h cause	
POWER SUPPL	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	T
		25.0%	6 16.7%	25.0%	5

Section 5:9	Circuit 5 year average (SAIDI)	0.246637187	
Section 5:10	Reporting year (SAIDI)	0.302609146	
Section 5:11	Circuit 5 year average (SAIFI)	0.002671923	
Section 5:12	Reporting year (SAIFI)	0.004546561	
Section 5:13	List of corrective action, if any, taken or to be taken		

Replaced critter guard in substation, VM to trim circuit.

PUBLIC

.

8.3%

UNKNOWN

ANIMAL

25.0%

.

Section 5:1	Substation name and Number	Adams Lane 106			
Section 5:2	Substation Location	CountyHenderson	RoadUS Hwy 41	TownHenderson	
Section 5:3	Circuit Name and Number	Happy Acres Feeder 1			
Section 5:4	Circuit Location	Hwy 41 South			
Section 5:5	Total Circuit Length	16.71			
Section 5:6	Member count for this circuit	223			
Section 5:7	Date of last circuit trim (VM)	2011/2016			
Section 5:8	List outage causes for circuit along	with % of total outage num	nbers represented by ea	ich cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
		25.0%	6 16.79	6 25.0%	25.0

.

Section 5:9	Circuit 5 year average (SAIDI)	0.246637187	
Section 5:10	Reporting year (SAIDI)	0.302609146	
Section 5:11	Circuit 5 year average (SAIFI)	0.002671923	
Section 5:12	Reporting year (SAIFI)	0.004546561	
Continu L17	the effective realized of energy actions are been actions.		

Section 5:13 List of corrective action, if any, taken or to be taken----

`

.

Replaced critter guard in substation, VM to trim circuit.

PUBLIC

8.3%

25.0%

١

h.

.

Section 5:1	Substation name and Number	Adams Lane 106			
Section 5:2	Substation Location	CountyHenderson	RoadUS Hwy 41	TownHenderson	
Section 5:3	Circuit Name and Number	Adams Lane Feeder 2			
Section 5:4	Circuit Location	Carriage Home Park			
Section 5:5	Total Circuit Length	36.39			
Section 5:6	Member count for this circuit	441			
Section 5:7	Date of last circuit trim (VM)	2011/2016			
Section 5:8	List outage causes for circuit along	with % of total outage num	bers represented by eac	ch cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
		36.4%	18.2%	)	27.3

Section 5:9	Circuit 5 year average (SAIDI)	0.310586627	
Section 5:10	Reporting year (SAIDI)	0.649621453	
Section 5:11	Circuit 5 year average (SAIFI)	0.005529813	
Section 5:12	Reporting year (SAIFI)	0.013573203	
Soction 5-12	List of corrective action if any taken as to be taken		

Section 5:13 List of corrective action, if any, taken or to be taken---

Replaced critter guard in substation, VM to trim circuit.

PUBLIC

18.2%

27.3%

Section 5:1	Substation name and Number	Adams Lane 106		
Section 5:2	Substation Location	CountyHenderson	RoadUS Hwy 41	TownHenderson
Section 5:3	Circuit Name and Number	Cresline Feeder 3		
Section 5:4	Circuit Location	Cresline Plastics		
Section 5:5	Total Circuit Length	3.02		
Section 5:6	Member count for this circuit	30		
Section 5:7	Date of last circuit trim (VM)	2011/2016		
Section 5:8	List outage causes for circuit along	with % of total outage num	bers represented by e	ach cause
POWER SUPPL	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER

Section 5:9	Circuit 5 year average (SAIDI)	0.030248988		
Section 5:10	Reporting year (SAIDI)	0.01013363		
Section 5:11	Circuit 5 year average (SAIFI)	0.000497622		
Section 5:12	Reporting year (SAIFI) 0.00016296			
Section 5:13	List of corrective action, if any, taken or to be taken			

-

.

Replaced critter guard in substation, VM to trim circuit.

ANÌMAL

100.0%

PUBLIC

-

Section 5:3 Circu Section 5:4 Circu	uit Name and Number uit Location	CountyOhio 231 North Feeder 1 231 N, Beda, Shinkle C	RoadHwy 136 happiel Rd	TownHartford			
Section 5:4 Circu	uit Location		happiel Rd				
		231 N, Beda, Shinkle C	happiel Rd				
	Circuit Longth						
Section 5:5 Total		67.72					
Section 5:6 Mem	nber count for this circuit	509					
Section 5:7 Date	e of last circuit trim (VM)	2012					
Section 5:8 List o	outage causes for circuit along with	n % of total outage num	bers represented by a	ach cause			ı
POWER SUPPLY PLAN	NNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
		15.2%	12.19	27.39	6 24.2%	6.1%	15.2%

Section 5:9	Circuit 5 year average (SAIDI)	1.351770334
Section 5:10	Reporting year (SAIDI)	2.104914989
Section 5:11	Circuit 5 year average (SAIFI)	0.015152283
Section 5:12	Reporting year (SAIFI)	0.018842382

.

Section 5:13 List of corrective action, if any, taken or to be taken--- System improvement work order scheduled.

Section 5:1	Substation name and Number	Beda 41			
Section 5:2	Substation Location	CountyOhio	RoadHwy 136	TownHartford	
Section 5:3	Circuit Name and Number	Whoopee Hill Feeder	2		
Section 5:4	Circuit Location	Hwy 1414			
Section 5:5	Total Circuit Length	50.39			
Section 5:6	Member count for this circuit	326			
Section 5:7	Date of last circuit trim (VM)	2012			
Section 5:8	List outage causes for circuit along v	with % of total outage nu	mbers represented by e	each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
		28.6%	14.3%	í 14.3%	35.7%

PUBLIC

.

.

UNKNOWN

7.1%

Section 5:9	Circuit 5 year average (SAIDI)	1.242907487
Section 5:10	Reporting year (SAIDI)	3.830434394
Section 5:11	Circuit 5 year average (SAIFI)	0.010154681
Section 5:12	Reporting year (SAIFI)	0.021062388
C	I the first of the second term of	

÷.

.

.

Section 5:13 List of corrective action, if any, taken or to be taken---- Resolved at time of outage.

ANIMAL

.

19.2%

.

PUBLIC

3.9%

UNKNOWN

,

11.5%

Section 5:1	Substation name and Number	Beda 41			
Section 5:2	Substation Location	CountyOhio	RoadHwy 136	TownHartford	
Section 5:3	Circuit Name and Number	Heflin Feeder 3			
Section 5:4	Circuit Location	Hwy 136			
Section 5:5	Total Circuit Length	57.99			
Section 5:6	Member count for this circuit	270 ·			
Section 5:7	Date of last circuit trim (VM)	2012			
Section 5:8	List outage causes for circuit along wit	th % of total outage nu	mbers represented by e	ach cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	RÓW	WEATHER	
	3.9%	7.7%	11.5%	42.3%	
				·	

Section 5:9	Circuit 5 year average (SAIDI)	0.654111542
Section 5:10	Reporting year (SAIDI)	0.913863103
Section 5:11	Circuit 5 year average (SAIFI)	0.007546498
Section 5:12	Reporting year (SAIFI)	0.007934085
Continue C.17	The standard standard the standard standard	· · · · · · · · · · · · · · · · · · ·

.

Section 5:13 List of corrective action, if any, taken or to be taken--- Look at adding additional lightning protection.

Section 5:1	Substation name and Number	Beda 41			-
Section 5:2	Substation Location	CountyOhio	RoadHwy 136	TownHartford	
Section 5:3	Circuit Name and Number	Iron Mountain Feeder	4		
Section 5:4	Circuit Location	Wal-Mart, Iron Moun	tain		
Section 5:5	Total Circuit Length	36.87			
Section 5:6	Member count for this circuit	343			
Section 5:7	Date of last circuit trim (VM)	2012			
Section 5:8	List outage causes for circuit along w	ith % of total outage num	bers represented by ea	ach cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
		26.3%		21.1%	26.3%

PUBLIC

15.8%

UNKNOWN

10.5%

Section 5:9	Circuit 5 year average (SAIDI)	1.218752922	]
Section 5:10	Reporting year (SAIDI)	1.341346498	
Section 5:11	Circuit 5 year average (SAIFI)	0.016284141	
Section 5:12	Reporting year (SAIFI)	0.020757826	
Section 5:13	List of corrective action, if any, taken o	r to be taken	Resolved at time of outag

C							
Section 5:2 Subs	ostation Location	County <b>McLean</b>	RoadHwy 256	TownBeech Grove			
Section 5:3 Circu	cuit Name and Number	Webster Co Water Fee	der 1				
Section 5:4 Circu	cuit Location	Hwy 256					
Section 5:5 Tota	al Circuit Length	31.89					
Section 5:6 Men	mber count for this circuit	135					_
Section 5:7 Date	te of last circuit trim (VM)	2015					
Section 5:8 List of	outage causes for circuit along with	h % of total outage num	bers represented by (	each cause	_		
POWER SUPPLY PLAT	ANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
		27.8%		33.3%	22.2%	5.6%	11.1%

Section 5:9	Circuit 5 year average (SAIDI)	0.204453213	
Section 5:10	Reporting year (SAIDI)	0.1423403	
Section 5:11	Circuit 5 year average (SAIFI)	0.002614858	
Section 5:12	Reporting year (SAIFI)	0.001712701	
Section 5:13	List of corrective action, if any, taken o	or to be taken	Circuit scheduled for inspection.

PUBLIC

11.1%

UNKNOWN

33.3%

Section 5:2       Substation Location       CountyMcLean       RoadHwy 256       TownBeech Grove         Section 5:3       Circuit Name and Number       Beech Grove Feeder 2       TownBeech Grove         Section 5:4       Circuit Location       Hwy 136       TownBeech Grove	Section 5:1	Substation name and Number	Beech Grove 33			
Section 5:4 Circuit Location Hwy 136	Section 5:2	Substation Location	CountyMcLean	RoadHwy 256	TownBeech Grove	
	Section 5:3	Circuit Name and Number	Beech Grove Feeder 2	2		
Construct Full Transfer and AD 04	Section 5:4	Circuit Location	Hwy 136			
Section 5:5 Fotal Ulrcuit Length 18.24	Section 5:5	Total Circuit Length	18.24			
Section 5:6 Member count for this circuit 152	Section 5:6	Member count for this circuit	152			
Section 5:7 Date of last circuit trim (VM) 2015	Section 5:7	Date of last circuit trim (VM)	2015			
Section 5:8 List outage causes for circuit along with % of total outage numbers represented by each cause	Section 5:8	List outage causes for circuit along wit	th % of total outage nu	mbers represented by	y each cause	
POWER SUPPLY PLANNED EQUIPMENT FAILURE ROW WEATHER ANIMA	POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
11.1% 44.4%		11.1%	44.4%	5		] 11.1

Section 5:9	Circuit 5 year average (SAIDI)	0.230049431	
Section 5:10	Reporting year (SAIDI)	0.061115026	
Section 5:11	Circuit 5 year average (SAIFI)	0.003053463	
Section 5:12	Reporting year (SAIFI)	0.00085898	
Section 5:13	List of corrective action, if any, taken or to be taken		Circuit scheduled for inspection.

.

UNKNOWN

18.8%

.

PUBLIC 12.5%

.

Section 5:1	Substation name and Number	Beech Grove 33			
Section 5:2	Substation Location	CountyMcLean	RoadHwy 256	TownBeech Grove	
Section 5:3	Circuit Name and Number	Elba Feeder 3			
Section 5:4	Circuit Location	Hwy 56			
Section 5:5	Total Circuit Length	31.89			
Section 5:6	Member count for this circuit	227			
Section 5:7	Date of last circuit trim (VM)	2015			
Section 5:8	List outage causes for circuit along v	vith % of total outage nu	mbers represented by	/ each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
		6.3%		31.3%	31.3%

Section 5:9	Circuit 5 year average (SAIDI)	0.38590137	
Section 5:10	Reporting year (SAIDI)	0.982589582	
Section 5:11	Circuit 5 year average (SAIFI)	0.004924464	
Section 5:12	Reporting year (SAIFI)	0.012815006	
Section 5:13	List of corrective action, if any, taken or to be taken		

.

Circuit scheduled for inspection.

Section 5:1	Substation name and Number	Beech Grove 33			
Section 5:2	Substation Location	CountyMcLean	RoadHwy 256	TownBeech Grove	
Section 5:3	Circuit Name and Number	Hudson Food Feeder	4		
Section 5:4	Circuit Location	Rangers Landing			
Section 5:5	Total Circuit Length	38.5			
Section 5:6	Member count for this circuit	155			
Section 5:7	Date of last circuit trim (VM)	2015			
Section 5:8	List outage causes for circuit along wit	h <u>%</u> of total outage nu	mbers represented by	each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ŘOW	WEATHER	ANIMAL
	5.3%	21.1%		10.5	5% 21.1
	·				

Section 5:9	Circuit 5 year average (SAIDI)	0.54064707	
Section 5:10	Reporting year (SAIDI)	0.971969087	
Section 5:11	Circuit 5 year average (SAIFI)	0.007138588	
Section 5:12	Reporting year (SAIFI)	0.012381602	
Section 5:13	List of corrective action, if any, taken or to be taken		

-

Circuit scheduled for inspection.

PUBLIC

10.5%

21.1%

4

.

.

UNKNOWN

31.6%

Section 5:1	Substation name and Number	Bon Harbor 27				
Section 5:2	Substation Location	CountyDaviess	RoadWorthington Rd	TownOwensboro		
Section 5:3	Circuit Name and Number	Post Office Feeder 1				
Section 5:4	Circuit Location	Bon Harbor, Tradewir	nds			
Section 5:5	Total Circuit Length	16.23				
Section 5:6	Member count for this circuit	355				
Section 5:7	Date of last circuit trim (VM)	2011/2016				
Section 5:8	List outage causes for circuit along wit	h % of total outage nu	mbers represented by each	cause		
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC
	16.7%	33.3%	16.7%	6 16.7%		16.7%

Section 5:9	Circuit 5 year average (SAIDI)	0.174346487
Section 5:10	Reporting year (SAIDI)	0.557997546
Section 5:11	Circuit 5 year average (SAIFI)	0.003571264
Section 5:12	Reporting year (SAIFI)	0.005330874
Section 5:13	List of corrective action, if any, taken of	or to be taken VM to trim circuit

ANIMAL

33.3%

PUBLIC

33.3%

UNKNOWN

33.3%

Section 5:1	Substation name and Number	Bon Harbor 27			
Section 5:2	Substation Location	CountyDaviess	RoadWorthington Rd	TownOwensboro	
Section 5:3	Circuit Name and Number	Ben Hawes Park Fee	der 2		
Section 5:4	Circuit Location	Audubon, Boothfield	Rd.		
Section 5:5	Total Circuit Length	31.49			
Section 5:6	Member count for this circuit	357			
Section 5:7	Date of last circuit trim (VM)	2011/2016			
Section 5:8	List outage causes for circuit along v	with % of total outage nu	umbers represented by each	cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILUR	E ROW	WEATHER	

Section 5:9	Circuit 5 year average (SAIDI)	0.355036284
Section 5:10	Reporting year (SAIDI)	0.612359897
Section 5:11	Circuit 5 year average (SAIFI)	0.005491357
Section 5:12	Reporting year (SAIFI)	0.013665852
Section 5:13	List of corrective action, if any, taken of	or to be taken VM to trim circuit

.

PUBLIC

33.3%

UNKNOWN

Section 5:1	Substation name and Number	Bon Harbor 27			
Section 5:2	Substation Location	CountyDaviess	RoadWorthington Rd	TownOwensboro	
Section 5:3	Circuit Name and Number	Worthington Rd Feed	ler 3		
Section 5:4	Circuit Location	Worthington Rd , Peo	an Ridge		
Section 5:5	Total Circuit Length	5.03			
Section 5:6	Member count for this circuit	86			
Section 5:7	Date of last circuit trim (VM)	2011/2016			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by each	cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
		50.0%	6 16.79	6	33.3

Section 5:9	Circuit 5 year average (SAIDI)	0.049205563
Section 5:10	Reporting year (SAIDI)	0.144974997
Section 5:11	Circuit 5 year average (SAIFI)	0.000789954
Section 5:12	Reporting year (SAIFI)	0.002270891
Section 5:13	List of corrective action, if any, taken of	or to be taken VM to trim circuit

PUBLIC

UNKNOWN

.

Section 5:1	Substation name and Number	Bon Harbor 27			
Section 5:2	Substation Location	CountyDaviess	RoadWorthington Rd	TownOwensboro	
Section 5:3	Circuit Name and Number	STh Street Rd Feeder	4		
Section 5:4	Circuit Location	5Th Street Road			
Section 5:5	Total Circuit Length	23.01			
Section 5:6	Member count for this circuit	441			
Section 5:7	Date of last circuit trim (VM)	2011/2016			
Section 5:8	List outage causes for circuit along v	vith % of total outage nu	mbers represented by each	cause	
POWER SUPPL	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
		25.0%	12.5%	6 25.0%	37.5%

Section 5:9	Circuit 5 year average (SAIDI)	0.427587372	
Section 5:10	Reporting year (SAIDI)	0.603337432	
Section 5:11	Circuit 5 year average (SAIFI)	0.009853606	
Section 5:12	Reporting year (SAIFI)	0.01979221	
Section 5:13	List of corrective action, if any, taken of	r to be taken VM to trim circu	it

-

PUBLIC

9.1%

UNKNOWN

18.2%

Section 5:1	Substation name and Number	Bon Harbor 27			
Section 5:2	Substation Location	CountyDaviess	RoadWorthington Rd	Town <b>Owensboro</b>	
Section 5:3	Circuit Name and Number	Lee Rudy/ Hwy 60 Fe	eder 5		
Section 5:4	Circuit Location	Hwy 279			
Section 5:5	Total Circuit Length	37.89			
Section 5:6	Member count for this circuit	392			
Section 5:7	Date of last circuit trim (VM)	2011/2016			
Section 5:8	List outage causes for circuit along v	vith % of total outage nu	imbers represented by each	cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROŴ	WEATHER	ANIMAL
		18.2%	6 18.2%	6 18.2	% 18.2%
•					

Section 5:9	Circuit 5 year average (SAIDI)	0.427587372	
Section 5:10	Reporting year (SAIDI)	0.603337432	
Section 5:11	Circuit 5 year average (SAIFI)	0.009853606	
Section 5:12	Reporting year (SAIFI)	0.01979221	
Section 5:13	List of corrective action, if any, taken of	VM to trim circuit	

.

,

.

UNKNOWN

100.0%

PUBLIC

.

.

Section 5:1	Substation name and Number	Caldwell Springs 60			
Section 5:2	Substation Location	CountyCrittenden	RoadHwy 855	Town <b>Fredoni</b> a	
Section 5:3	Circuit Name and Number	March Oliver Road Fee	eder 1		
Section 5:4	Circuit Location	March Oliver Road			
Section 5:5	Total Circuit Length	15.43			
Section 5:6	Member count for this circuit	53			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along v	vith % of total outage nur	nbers represented by	each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	, ANIMAL

Section 5:9	Circuit 5 year average (SAIDI)	0.082517362	
Section 5:10	Reporting year (SAIDI)	0.256580413	
Section 5:11	Circuit 5 year average (SAIFI)	0.000947253	
Section 5:12	Reporting year (SAIFI)	0.002624225	
Section 5:13	List of corrective action, if any, taken of	Circuit scheduled for inspection.	

Section 5:1	Substation name and Number	Caldwell Springs 60					
Section 5:2	Substation Location	CountyCrittenden	RoadHwy 855	TownFredonia			
Section 5:3	Circuit Name and Number	Dycusburg Feeder 2					
Section 5:4	Circuit Location	Hwy 1943					
Section 5:5	Total Circuit Length	72.52					
Section 5:6	Member count for this circuit	343					
Section 5:7	Date of last circuit trim (VM)	2014					
Section 5:8	List outage causes for circuit along v	vith % of total outage nun	nbers represented by	y each cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
		13.1%	6.	7%	26.7% 33.	3% 6.7%	13.3%

Section 5:9	Circuit 5 year average (SAIDI)	0.777883003	1
Section 5:10	Reporting year (SAIDI)	1.120054104	
Section 5:11	Circuit 5 year average (SAIFI)	0.006484427	
Section 5:12	Reporting year (SAIFI)	0.011338714	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Circuit schedı

Circuit scheduled for inspection.

Section 5:1	Substation name and Number	Caldwell Springs 60			
Section 5:2	Substation Location	CountyCrittenden	Road <b>Hwy 855</b>	TownFredonia	
Section 5:3	Circuit Name and Number	Caldwell Springs Churc	ch Feeder 3		
Section 5:4	Circuit Location	Seven Springs, Reiter C	Corner		
Section 5:5	Total Circuit Length	70.9			
Section 5:6	Member count for this circuit	270		د	
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along wit	h % of total o <u>utage nur</u>	nbers represented by ea	ich cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
	6.7%	40.0%		20.0%	

Section 5:9	Circuit 5 year average (SAIDI)	0.837953156		
Section 5:10	Reporting year (SAIDI)	2.872987475		
Section 5:11	Circuit 5 year average (SAIFI)	0.007410447		
Section 5:12	Reporting year (SAIFI)	0.026642207		
Section 5:13 List of corrective action, if any, taken or to be taken				

o be taken---- Circuit scheduled for inspection.

ANIMAL

6.7%

PUBLIC

6.7%

UNKNOWN

20.0%

ANIMAL

PUBLIC

25.0%

Section 5:1	Substation name and Number	Centertown 40			
Section 5:2	Substation Location	County <b>Ohio</b>	RoadPitts Lane	TownCentertown	
Section 5:3	Circuit Name and Number	Matanzas Feeder 1			
Section 5:4	Circuit Location	Mantazas, Hwy 85			
Section 5:5	Total Circuit Length	29.66			
Section 5:6	Member count for this circuit	139			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along with	h % of total outage num	bers represented by ea	ach cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
	25.0%	25.0%	,	25.0%	

Section 5:9	Circuit 5 year average (SAIDI)	0.347792543	
Section 5:10	Reporting year (SAIDI)	0.6475328	
Section 5:11	Circuit 5 year average (SAIFI)	0.004198077	
Section 5:12	Reporting year (SAIFI)	0.00596078	
Section 5:13	List of corrective action, if any, taken o	r to be taken	System improve

Section 5:1	Substation name and Number	Centertown 40		
Section 5:2	Substation Location	County <b>Ohio</b>	RoadPitts Lane	Town <b>Centertown</b>
Section 5:3	Circuit Name and Number	Goshen Rd. Feeder 2		
Section 5:4	Circuit Location	Mantazas		
Section 5:5	Total Circuit Length	29.66		
Section 5:6	Member count for this circuit	98		
Section 5:7	Date of last circuit trim (VM)	2014		
Section 5:8	List outage causes for circuit along v	with % of total outage nu	mbers represented by	each cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
1		00.00/		

POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
		60.0%			40.0%		

Section 5:9	Circuit 5 year average (SAIDI)	0.409812315
Section 5:10	Reporting year (SAIDI)	0.750979506
Section 5:11	Circuit 5 year average (SAIFI)	0.004722735
Section 5:12	Reporting year (SAIFI)	0.007916261
Cashian E.13	I tak of an an attack and the strength of the second second second second second second second second second se	n da ha dalkan Da

Section 5:13 List of corrective action, if any, taken or to be taken--- Resolved at time of outage.

PUBLIC

9.1%

13.6%

.

UNKNOWN

18.2%

Section 5:1	Substation name and Number	Centertown 40			
Section 5:2	Substation Location	CountyOhio	RoadPitts Lane	TownCentertown	
Section 5:3	Circuit Name and Number	Rockport Feeder 3			
Section 5:4	Circuit Location	Hwy 85 South			
Section 5:5	Total Circuit Length	45.43			
Section 5:6	Member count for this circuit	275			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along wit	h % of total outage nun	bers represented by ea	ch cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
	4.6%	22.7%	18.2%	13.6%	13.6

Section 5:9	Circuit 5 year average (SAIDI)	2.499149798	
Section 5:10	Reporting year (SAIDI)	8.030282525	
Section 5:11	Circuit 5 year average (SAIFI)	0.016128559	
Section 5:12	Reporting year (SAIFI)	0.024269971	
Section 5:13	List of corrective action, if any, taken or to be taken		Replace old copper conductor.

•

े: Circuit Reporting 2015 ıd /or SAIFI exceeding 5 year average)

.

hould be reported excluding MED

•

Section 5:1	Substation name and Number	Centertown 40			
Section 5:2	Substation Location-	CountyOhio	RoadPitts Lane	Town—Centertown	
Section 5:3	Circuit Name and Number	Bishner Lane Feeder 4			
Section 5:4	Circuit Location	Bishner Lane			
Section 5:5	Total Circuit Length	2			
Section 5:6	Member count for this circuit—	10			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along v	vith % of total outage nur	nbers represented by e	ach cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
				100.0%	Γ

ANIMAL

.

PUBLIC

UNKNOWN

Section 5:9	Circuit 5 year average (SAIDI)	0.012223243	
Section 5:10	Reporting year (SAIDI)	0.040463614	
Section 5:11	Circuit 5 year average (SAIFI)	0.000169624	
Section 5:12	Reporting year (SAIFI)	0.000325346	
Section 5:13	List of corrective action, if any, taken o	Resolved at time of outage.	

Section 5:1	Substation name and Number	Crossroads 61	•		
Section 5:2	Substation Location	CountyCaldwell	RoadHwy 70	TownPrinceton	
Section 5:3	Circuit Name and Number	Old Barnes Store Feed	ler 2		
Section 5:4	Circuit Location	Hwy 293 South			
Section 5:5	Total Circuit Length	97.01			
Section 5:6	Member count for this circuit	3.76			
Section 5:7	Date of last circuit trim (VM)	2013		د.	
Section 5:8	List outage causes for circuit along wi	th % of total outage nur	mbers represented by e	ach cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
4%		39.3%	7.1%	35.79	6 3.6

Section 5:9	Circuit 5 year average (SAIDI)	1.300747454	
Section 5:10	Reporting year (SAIDI)	1.732510857	
Section 5:11	Circuit 5 year average (SAIFI)	0.013568214	
Section 5:12	Reporting year (SAIFI)	0.01569875	
Section 5:13	List of corrective action, if any, taken of	Look at add	

.

.

Look at adding lighting protection.

PUBLIC

3.6%

3.6%

UNKNOWN

7.1%

ANIMAL

5.9%

PUBLIC

5.9%

UNKNOWN

.

17.7%

Section 5:1	Substation name and Number	Crossroads 61		
Section 5:2	Substation Location	CountyCaldwell	Road <b>Hwy 70</b>	TownPrinceton
Section 5:3	Circuit Name and Number	Flatrock Feeder 2		
Section 5:4	Circuit Location	Hwy 70 west, Ferry Rd	l.	
Section 5:5	Total Circuit Length	46.88		
Section 5:6	Member count for this circuit	168		
Section 5:7	Date of last circuit trim (VM)	2013		
Section 5:8	List outage causes for circuit along wi	ith % of total outage nur	nbers represented by ea	ch cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
6%			11.8%	52.9%

Section 5:9	Circuit 5 year average (SAIDI)	0.419851185	
Section 5:10	Reporting year (SAIDI)	0.989302106	
Section 5:11	Circuit 5 year average (SAIFI)	0.004514555	
Section 5:12	Reporting year (SAIFI)	0.012628417	
Section 5:13	List of corrective action, if any, taken or to be taken		Look at adding lighting protection.

ANIMAL

5.0%

PUBLIC

5.0%

UNKNOWN

7.5%

Section 5:1	Substation name and Number	Crossroads 61		
Section 5:2	Substation Location	CountyCaldwell	RoadHwy 70	TownPrinceton
Section 5:3	Circuit Name and Number	Morganhill/Farmersvil	lle Feeder 2	
Section 5:4	Circuit Location	Hwy 1119		
Section 5:5	Total Circuit Length	142.97		
Section 5:6	Member count for this circuit	715		
Section 5:7	Date of last circuit trim (VM)	2013		
Section 5:8	List outage causes for circuit along wit	h % of total outage nur	nbers represented by ea	ch cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
3%		20.0%	10.0%	50.0%

Section 5:9	Circuit 5 year average (SAIDI)	3.437074907	
Section 5:10	Reporting year (SAIDI)	5.312378145	
Section 5:11	Circuit 5 year average (SAIFI)	0.032533784	
Section 5:12	Reporting year (SAIFI)	0.046923626	
Section 5:13	List of corrective action, if any, taken or to be taken		Look at adding lighting protection.

.

Section 5:1	Substation name and Number	Crossroads 61		
Section 5:2	Substation Location	CountyCaldwell	RoadHwy 70	TownPrinceton
Section 5:3	Circuit Name and Number	Creswell Feeder 4	-	
Section 5:4	Circuit Location	Hwy 902, Hwy 139		
Section 5:5	Total Circuit Length	29.09		
Section 5:6	Member count for this circuit	128		
Section 5:7	Date of last circuit trim (VM)	2013		
Section 5:8	List outage causes for circuit along w	ith % of total outage nu	mbers represented by e	ach cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER

POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL		UNKNOWN
12.5%		50.0%		12.5%		12.5%	12.5%

Section 5:9	Circuit 5 year average (SAIDI)	0.1549616	
Section 5:10	Reporting year (SAIDI)	0.38306141	
Section 5:11	Circuit 5 year average (SAIFI)	0.002241318	
Section 5:12	Reporting year (SAIFI)	0.006423502	
Section 5:13	List of corrective action, if any, taken or to be taken		

.

Resolved at time of outage.

.

UNKNOWN

PUBLIC

25.0%

ANIMAL

25.0%

Substation name and Number	Dermont 17			
Substation Location	CountyDaviess	RoadPleasant Valley Rd	TownOwensboro	
Circuit Name and Number	Reid Road Feeder 1			
Circuit Location	Reid Rd., Lane Rd.			
Total Circuit Length	18.01			
Member count for this circuit	218			
Date of last circuit trim (VM)	2015			
List outage causes for circuit along v	with % of total outage nu	mbers represented by each ca	use	
PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
	25.0%		25.0	%
	Substation Location Circuit Name and Number Circuit Location Total Circuit Length Member count for this circuit Date of last circuit trim (VM) List outage causes for circuit along	Substation Location       CountyDaviess         Circuit Name and Number       Reid Road Feeder 1         Circuit Location       Reid Rd., Lane Rd.         Total Circuit Length       18.01         Member count for this circuit       218         Date of last circuit trim (VM)       2015         List outage causes for circuit along with % of total outage numplant       PLANNED         EQUIPMENT FAILURE       EQUIPMENT FAILURE	Substation Location       CountyDaviess       RoadPleasant Valley Rd         Circuit Name and Number       Reid Road Feeder 1         Circuit Location       Reid Rd., Lane Rd.         Total Circuit Length       18.01         Member count for this circuit       218         Date of last circuit trim (VM)       2015         List outage causes for circuit along with % of total outage numbers represented by each card	Substation Location       CountyDaviess       RoadPleasant Vailey Rd       TownOwensboro         Circuit Name and Number       Reid Road Feeder 1       TownOwensboro         Circuit Location       Reid Rd., Lane Rd.       Total Circuit Length       18.01         Member count for this circuit       218       Total Circuit trim (VM)       2015         List outage causes for circuit along with % of total outage numbers represented by each cause       PLANNED       EQUIPMENT FAILURE       ROW       WEATHER

Section 5:9	Circuit 5 year average (SAIDI)	0.945718637	
Section 5:10	Reporting year (SAIDI)	0.481465104	
Section 5:11	Circuit 5 year average (SAIFI)	0.015036735	
Section 5:12	Reporting year (SAIFI)	0.001758085	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Circuit scheduled for inspection.

	Section 5:1	Substation name and Number	Dermont 17		
	Section 5:2	Substation Location	CountyDaviess	RoadPleasant Valley Rd	Town <b>Owensboro</b>
	Section 5:3	Circuit Name and Number	Dee Acres Feeder 2		
	Section 5:4	Circuit Location	Pleasant Valley Rd		
	Section 5:5	Total Circuit Length	11.26		
	Section 5:6	Member count for this circuit	113		
	Section 5:7	Date of last circuit trim (VM)	2015		
	Section 5:8	List outage causes for circuit along v	with % of total outage nu	mbers represented by each ca	ause
•	POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
			50.0%		16

POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN	
		50.0%		16.7%	16.7%	16.7%		
								4

r

2

Section 5:9	Circuit 5 year average (SAIDI)	0.032829531	
Section 5:10	Reporting year (SAIDI)	0.057990973	
Section 5:11	Circuit 5 year average (SAIFI)	0.001035604	
Section 5:12	Reporting year (SAIFI)	0.000750761	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Circuit sc

Circuit scheduled for inspection.

.

PUBLIC

6.7%

UNKNOWN

46.7%

Section 5:1	Substation name and Number	Dermont 17				
Section 5:2	Substation Location	CountyDaviess	RoadPleasant Valley Rd	Town <b>Owensboro</b>		
Section 5:3	Circuit Name and Number	Timber Ridge Subdivi	sion Feeder 3			
Section 5:4	Circuit Location	Hwy 142, Hwy 54, Fie	lds Rd			
Section 5:5	Total Circuit Length	22.9				
Section 5:6	Member count for this circuit	306				
Section 5:7	Date of last circuit trim (VM)	2015				
Section 5:8	List outage causes for circuit along w	ith % of total outage nu	mbers represented by each ca	use		
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	
		6.7%	b	26.7%	13.3%	

.

Section 5:9	Circuit 5 year average (SAIDI)	0.158390617	
Section 5:10	Reporting year (SAIDI)	0.723512909	
Section 5:11	Circuit 5 year average (SAIFI)	0.002751441	
Section 5:12	Reporting year (SAIFI)	0.012365762	
Section 5:13	List of corrective action, if any, taken of	Circuit scheduled for inspection.	

.

ANIMAL

21.4%

PUBLIC

7.1%

UNKNOWN

21.4%

Section 5:1	Substation name and Number	Dermont 17		
Section 5:2	Substation Location	CountyDaviess	RoadPleasant Valley Rd	Town <b>Owensboro</b>
Section 5:3	Circuit Name and Number	Locust Hills Feeder 4		
Section 5:4	Circuit Location	Fields Rd north		
Section 5:5	Total Circuit Length	33.12		
Section 5:6	Member count for this circuit	585		
Section 5:7	Date of last circuit trim (VM)	2015		
Section 5:8	List outage causes for circuit along wit	h % of total outage num	bers represented by each caus	e
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		21.4%	14.3%	

		21.4%	14.3%	14.3%	
Section 5:9	Circuit 5 year average (SAIDI)	1.064242721	<u>.</u>		
Section 5:10	Reporting year (SAIDI)	1.337623915			
Section 5:11	Circuit 5 year average (SA1FI)	0.012766721			
Section 5:12	Reporting year (SAIFI)	0.014323099			

Section 5:13 List of corrective action, if any, taken or to be taken---Circuit scheduled for inspection.

ANIMAL

18.8%

PUBLIC

6.3%

UNKNOWN

25.0%

Section 5:1	Substation name and Number	Dermont 17			
Section 5:2	Substation Location	CountyDaviess	RoadPleasant Valley Rd	TownOwensboro	
Section 5:3	Circuit Name and Number	Ensor Feeder 5			
Section 5:4	Circuit Location	Hwy 144			
Section 5:5	Total Circuit Length	50.78			
Section 5:6	Member count for this circuit	497			
Section 5:7	Date of last circuit trim (VM)	2015			
Section 5:8	List outage causes for circuit along	with % of total outage nur	nbers represented by each caus	se	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		18.8%	6.3%	25.0%	

Section 5:9	Circuit 5 year average (SAIDI)	0.141067988	
Section 5:10	Reporting year (SAIDI)	0.700220727	
Section 5:11	Circuit 5 year average (SAIFI)	0.00265287	
Section 5:12	Reporting year (SAIFI)	0.013136815	
Section 5:13	List of corrective action, if any, taken o	Evaluate & inspection circuit.	

Section 5:1	Substation name and Number	Dixon 62						
Section 5:2	Substation Location	CountyWebster	RoadSR 1063	Tov	vnDixon			
Section 5:3	Circuit Name and Number	Hwy 41A North Feed	er 1					
Section 5:4	Circuit Location	Oak Heights				1		
Section 5:5	Total Circuit Length	41.53						
Section 5:6	Member count for this circuit	250						•
Section 5:7	Date of last circuit trim (VM)	2015						
Section 5:8	List outage causes for circuit along v	vith % of total outage nu	mbers represented by	each cause				
POWER SUPPLY	PLANNED	EQUIPMENT FAILUR	ROW		WEATHER	ANIMAL	PUBLIC	UNKNOWN
		22.29	6	11.1%	33.3%	11.1%	32.2%	
Section 5:9	Circuit 5 year average (SAIDI)	0.6263370	3]					
Section 5:10	Reporting year (CAIDI)	1 11745664	<u> </u>					

.

Section 5:10 Reporting year (SAIDI)	1.117456649
Section 5:11 Circuit 5 year average (SAIFI)	0.007905587
Section 5:12 Reporting year (SAIFI)	0.015987045

.

.

Section 5:13 List of corrective action, if any, taken or to be taken--- Look at adding additional lightning protection.

Section 5:1	Substation name and Number	Dixon 62		
Section 5:2	Substation Location	CountyWebster	Road <b>SR 1063</b>	TownDixon
Section 5:3	Circuit Name and Number	Dixon Feeder 2		
Section 5:4	Circuit Location	Hwy 132 West		
Section 5:5	Total Circuit Length	45.15		
Section 5:6	Member count for this circuit	261		
Section 5:7	Date of last circuit trim (VM)	2015		
Section 5:8	List outage causes for circuit along wi	ith % of total outage nun	nbers represented by each caus	e
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER

		18.2%	9.1%	45.5%	9.1%	
		<b>_</b>				
Continue FrO	Charles E commence (CAIDI)	0.440000400				

PUBLIC

ANIMAL

UNKNOWN

.

18.2%

Section 5:9	Circuit 5 year average (SAIDI)	0.149000429
Section 5:10	Reporting year (SAIDI)	0.280015045
Section 5:11	Circuit 5 year average (SAIFI)	0.001930014
Section 5:12	Reporting year (SAIFI)	0.006035933
a	14 C 4 C 4 C 4 C 4 C 4 C 4 C 4 C 4 C 4 C	

Section 5:13 List of corrective action, if any, taken or to be taken--- Look at adding additional lightning protection.

•

•

.

Section 5:1	Substation name and Number	Dixon 62						
Section 5:2	Substation Location	CountyWebster	RoadSR 1063	TownDi	xon			
Section 5:3	Circuit Name and Number	Clay Feeder 3						
Section 5:4	Circuit Location	Free Union, Little Zion	I					
Section 5:5	Total Circuit Length	75.16						
Section 5:6	Member count for this circuit	341						
Section 5:7	Date of last circuit trim (VM)	2015						
Section 5:8	List outage causes for circuit along wit	h % of total outage nur	nbers represented by eac	ch cause				
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW		WEATHER	ANIMAL	PUBLIC	UNKNOWN
	6.7%	40.0%	)	6.7%	13.3%	13.3%	6.7%	13.3%
L	• • • • • • • • • • • • • • • • • • •	· · · ·						

Section 5:9	Circuit 5 year average (SAIDI)	0.804225112	
Section 5:10	Reporting year (SAIDI)	1.13029912	
Section 5:11	Circuit 5 year average (SAIFI)	0.011155871	
Section 5:12	Reporting year (SAIFI)	0.011941252	
Section 5:13	List of corrective action, if any, taken o	Resolved at time of outage.	

.

,

PUBLIC

16.7%

ANIMAL

16.7%

UNKNOWN

33.3%

Section 5:1	Substation name and Number	East Owensboro 19		
Section 5:2	Substation Location	CountyDaviess	RoadHayden Rd	TownOwensboro
Section 5:3	Circuit Name and Number	Covent Gardens Feed	er 2	
Section 5:4	Circuit Location	Hayden Road		
Section 5:5	Total Circuit Length	28.78		
Section 5:6	Member count for this circuit	456		
Section 5:7	Date of last circuit trim (VM)	2015		
Section 5:8	List outage causes for circuit along v	vith % of total outage nu	mbers represented by each	cause
<b>POWER SUPPLY</b>	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		16.7%	6	16.7%

Section 5:9	Circuit 5 year average (SAIDI)	0.79554508	
Section 5:10	Reporting year (SAIDI)	0.040673106	
Section 5:11	Circuit 5 year average (SAIFI)	0.010711266	
Section 5:12	Reporting year (SAIFI)	0.000641443	
Section 5:13	List of corrective action, if any, taken o	Evaluate & inspection circuit.	

Section 5:1	Substation name and Number	East Owensboro 19				
Section 5:2	Substation Location	CountyDaviess	RoadHayden Rd	Town <b>Owensboro</b>		
Section 5:3	Circuit Name and Number	Thruston/Dermont Fi	re Station Feeder 3			
Section 5:4	Circuit Location	Pleasant View, Fire St	ation			
Section 5:5	Total Circuit Length	12.13				
Section 5:6	Member count for this circuit	159				
Section 5:7	Date of last circuit trim (VM)	2015				
Section 5:8	List outage causes for circuit along v	ith % of total outage nur	mbers represented by each	cause		
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC
					100.0%	

Section 5:9	Circuit 5 year average (SAIDI)	0.115910602
Section 5:10	Reporting year (SAIDI)	0.041515256
Section 5:11	Circuit 5 year average (SAIFI)	0.001716135
Section 5:12	Reporting year (SAIFI)	0.000772708
Section 5:13	List of corrective action, if any, taken o	or to be taken

UNKNOWN

Section 5:1	Substation name and Number	East Owensboro 19							
Section 5:2	Substation Location	CountyDaviess	RoadHayden Rd	TownOwensboro					
Section 5:3	Circuit Name and Number	Memorial Gardens Fe	norial Gardens Feeder 4						
Section 5:4	Circuit Location	Reid Orchard, Town 8	l Orchard, Town & Country						
Section 5:5	Total Circuit Length	6.66	66						
Section 5:6	Member count for this circuit	33							
Section 5:7	Date of last circuit trim (VM)	2015				-			
Section 5:8	List outage causes for circuit along wi	th % of total outage nur	nbers represented by ea	ch cause			· · · · · · · · · · · · · · · · · · ·		
POWER SUPPLY	Y PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PÜBLIC	UNKNOWN		
		20.0%	6	20.0%	20.0%	20.0%	20.0%		
			_						

Section 5:9	Circuit 5 year average (SAIDI)	0.067738263	
Section 5:10	Reporting year (SAIDI)	0.015251481	
Section 5:11	Circuit 5 year average (SAIFI)	0.001268073	
Section 5:12	Reporting year (SAIFI)	0.000267164	
Section 5:13	List of corrective action, if any, taken o	r to be taken	Evaluate & inspection circuit.

1

•

Section 5:1	Substation name and Number	East Owensboro 19					
Section 5:2	Substation Location	CountyDaviess	RoadHayden Rd	Town <b>Owensboro</b>			
Section 5:3	Circuit Name and Number	Brownwood Manor Fe	eder 5				
Section 5:4	Circuit Location	Brown Wood Maner,	Sterling Park				
Section 5:5	Total Circuit Length	19.52					
Section 5:6	Member count for this circuit	358					
Section 5:7	Date of last circuit trim (VM)	2015					
Section 5:8	List outage causes for circuit along w	ith % of total outage nun	nbers represented by eac	h cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
		18.2%	,		27.3%	36.4%	18.2
	<u> </u>						

18.2%

.

Section 5:9	Circuit 5 year average (SAIDI)	0.36564978	]
Section 5:10	Reporting year (SAIDI)	0.348191079	
Section 5:11	Circuit 5 year average (SAIFI)	0.005665419	
Section 5:12	Reporting year (SAIFI)	0.003149729	
Section 5:13	List of corrective action, if any, taken o	r to be taken	Evaluate & inspection circ

.

,

ANIMAL

.

6.3%

PUBLIC

6.3%

UNKNOWN

12.5%

Section 5:1	Substation name and Number	Geneva 63			
Section 5:2	Substation Location	CountyHenderson	RoadHwy 136	TownCorydon	
Section 5:3	Circuit Name and Number	Alzey Feeder 1			
Section 5:4	Circuit Location	Hwy 268			
Section 5:5	Total Circuit Length	55.11			
Section 5:6	Member count for this circuit	171			
Section 5:7	Date of last circuit trim (VM)	2012			
Section 5:8	List outage causes for circuit along wit	h % of total outage num	bers represented by eac	h cause	_
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	1
		4.1%	6.3%	25.0%	,

Section 5:9	Circuit 5 year average (SAIDI)	1.095072397
Section 5:10	Reporting year (SAIDI)	0.873658377
Section 5:11	Circuit 5 year average (SAIFI)	0.008901226
Section 5:12	Reporting year (SAIFI)	0.011690004
Section 5:13	List of corrective action, if any, taken of	r to be taken Evaluate & inspection circuit

ANIMAL

Υ.

42.9%

7.1%

PUBLIC

7.1%

UNKNOWN

21.4%

Section 5:1	Substation name and Number	Geneva 63		
Section 5:2	Substation Location	CountyHenderson	Road <b>Hwy 136</b>	Town <b>Corydon</b>
Section 5:3	Circuit Name and Number	Airport/Office Feeder	2	
Section 5:4	Circuit Location	Kenergy HQ, Hwy 60 M	Vest	
Section 5:5	Total Circuit Length	55.76		
Section 5:6	Member count for this circuit	564		
Section 5:7	Date of last circuit trim (VM)	2012		
Section 5:8	List outage causes for circuit along wit	h % of total outage num	bers represented by ea	ch cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		7.1%	14.3%	,

Section 5:9	Circuit 5 year average (SAIDI)	0.922178602
Section 5:10	Reporting year (SAIDI)	1.729521284
Section 5:11	Circuit 5 year average (SAIFI)	0.017817343
Section 5:12	Reporting year (SAIFI)	0.035504501

Section 5:13 List of corrective action, if any, taken or to be taken--- Evaluate & inspection circuit.

-

ANIMAL

12.1%

PUBLIC

6.1%

UNKNOWN

18.2%

Section 5:1	Substation name and Number	Geneva 63			
Section 5:2	Substation Location	CountyHenderson	RoadHwy 136	TownCorydon	
Section 5:3	Circuit Name and Number	Smith Mills Feeder 3			
Section 5:4	Circuit Location	Smith Mills			
Section 5:5	Total Circuit Length	118.51			
Section 5:6	Member count for this circuit	570			
Section 5:7	Date of last circuit trim (VM)	2012			
Section 5:8	List outage causes for circuit along w	ith % of total outage num	bers represented by eac	h cause	_
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		24.2%	15.2%	24.2%	[

Section 5:9	Circuit 5 year average (SAIDI)	2.688570919	
Section 5:10	Reporting year (SAIDI)	5.657943184	
Section 5:11	Circuit 5 year average (SAIFI)	0.025847823	
Section 5:12	Reporting year (SAIFI)	0.057732923	
Section 5:13	List of corrective action, if any, taken or to be taken		Evaluate & inspection circuit.

Section 5:1	Substation name and Number	Guffie 31			
Section 5:2	Substation Location	CountyMclean	RoadHwy 140	TownCalhoun	
Section 5:3	Circuit Name and Number	Glenville Feeder 1			
Section 5:4	Circuit Location	Hwy 81, Hwy 815 nort	h, Hwy 554		
Section 5:5	Total Circuit Length	98.66			
Section 5:6	Member count for this circuit	679			
Section 5:7	Date of last circuit trim (VM)	2013			
Section 5:8	List outage causes for circuit along wit	h % of t <u>otal outage nun</u>	nbers represented by ea	ch cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
	3.3%	23.3%	6.7%	26.7%	ŀ

Section 5:9	Circuit 5 year average (SAIDI)	2.64234387	
Section 5:10	Reporting year (SAIDI)	3.084927506	
Section 5:11	Circuit 5 year average (SAIFI)	0.039492653	
Section 5:12	Reporting year (SAIFI)	0.056548404	
Section 5:13	List of corrective action, if any, taken of	Evaluate & in	

Evaluate & inspection circuit.

ANIMAL

10.0%

PUBLIC

6.7%

UNKNOWN

23.3%

~

PUBLIC

21.1%

15.8%

UNKNOWN

10.5%

.

Section 5:1	Substation name and Number	Guffie 31			
Section 5:2	Substation Location	CountyMclean	RoadHwy 140	Town <b>Calhoun</b>	
Section 5:3	Circuit Name and Number	Hwy 815 South Feede	er 2		
Section 5:4	Circuit Location	Brookschool Rd, Hwy	815 south		
Section 5:5	Total Circuit Length	52.08			
Section 5:6	Member count for this circuit	442			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along v	vith % of total outage <u>nu</u>	mbers represented by	each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
		36.8%	b	15.8%	15.8

Section 5:9	Circuit 5 year average (SAIDI)	0.75192156	
Section 5:10	Reporting year (SAIDI)	1.278997258	
Section 5:11	Circuit 5 year average (SAIFI)	0.006916286	
Section 5:12	Reporting year (SAIFI)	0.023495273	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

~

÷

PUBLIC

20.0%

,

UNKNOWN

30.0%

Section 5:1	Substation name and Number	Guffie 31			
Section 5:2	Substation Location	CountyMclean	RoadHwy 140	TownCalhoun	
Section 5:3	Circuit Name and Number	Poverty Feeder 3			
Section 5:4	Circuit Location	Hwy 140, Hwy 136, I	Hwy 256		
Section 5:5	Total Circuit Length	30.35			
Section 5:6	Member count for this circuit	82			
Section 5:7	Date of last circuit trim (VM)	2013			
Section 5:8	List outage causes for circuit along	with % of total outage n	umbers represented b	y each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILUP	RE ROW	WEATHER	ANIMAL
		30.0	%	20.	0% 20.0
			_		

Section 5:9	Circuit 5 year average (SAIDI)	0.268804132	
Section 5:10	Reporting year (SAIDI)	0.250622654	
Section 5:11	Circuit 5 year average (SAIFI)	0.001829565	
Section 5:12	Reporting year (SAIFI)	0.001377562	
Section 5:13	List of corrective action, if any, taken of	or to be taken	System improvement work order scheduled.

UNKNOWN

25.0%

PUBLIC

8.3%

16.7%

Substation name and Number	Guffie 31			
Substation Location	CountyMclean	RoadHwy 140	TownCalhoun	
Circuit Name and Number	Cleopatra Feeder 4			
Circuit Location	Beulah Rd., Cleopatra	a Rd.		
Total Circuit Length	30.92			
Member count for this circuit	120			
Date of last circuit trim (VM)	2013			
List outage causes for circuit along	with % of total outage nu	mbers represented b	y each cause	
PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
	16.7%	<u> </u>	33.3%	16.7
	Substation Location Circuit Name and Number Circuit Location Total Circuit Length Member count for this circuit Date of last circuit trim (VM) List outage causes for circuit along	Substation LocationCountyMcleanCircuit Name and NumberCleopatra Feeder 4Circuit LocationBeulah Rd., CleopatraTotal Circuit Length30.92Member count for this circuit120Date of last circuit trim (VM)2013List outage causes for circuit along with % of total outage nutPLANNEDEQUIPMENT FAILURE	Substation Location       CountyMclean       RoadHwy 140         Circuit Name and Number       Cleopatra Feeder 4         Circuit Location       Beulah Rd., Cleopatra Rd.         Total Circuit Length       30.92         Member count for this circuit       120         Date of last circuit trim (VM)       2013         List outage causes for circuit along with % of total outage numbers represented b	Substation Location       CountyMclean       RoadHwy 140       TownCalhoun         Circuit Name and Number       Cleopatra Feeder 4       Circuit Location       Beulah Rd., Cleopatra Rd.         Circuit Location       Beulah Rd., Cleopatra Rd.       30.92         Member count for this circuit       120         Date of last circuit trim (VM)       2013         List outage causes for circuit along with % of total outage numbers represented by each cause         PLANNED       EQUIPMENT FAILURE

Section 5:9	Circuit 5 year average (SAIDI)	0.139335287	
Section 5:10	Reporting year (SAIDI)	0.117912972	
Section 5:11	Circuit 5 year average (SAIFI)	0.002079726	
Section 5:12	Reporting year (SAIFI)	0.001054573	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

•

PUBLIC

50.0%

UNKNOWN

ANIMAL

Section 5:1	Substation name and Number	Hanson 51			
Section 5:2	Substation Location	CountyHopkins	RoadBrown Road	TownMadisonville	
Section 5:3	Circuit Name and Number	Stringtown Feeder F3			
Section 5:4	Circuit Location	Hwy 254			
Section 5:5	Total Circuit Length	10.93			
Section 5:6	Member count for this circuit	58			
Section 5:7	Date of last circuit trim (VM)	2015			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by e	ach cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
			50.0%	, b	

Section 5:9	Circuit 5 year average (SAIDI)	0.198388864	
Section 5:10	Reporting year (SAIDI)	0.308609387	
Section 5:11	Circuit 5 year average (SAIFI)	0.002182573	
Section 5:12	Reporting year (SAIFI)	0.004408889	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Resolved at time of outage.

.

PUBLIC

10.0%

ANIMAL

.

.

35.0%

UNKNOWN

.

5.0%

	5.0%	25.0%	5.0%	15.0%	\.
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
Section 5:8	List outage causes for circuit along wit	h % of total outage nu	mbers represented by e	ach cause	_
Section 5:7	Date of last circuit trim (VM)	2015			
Section 5:6	Member count for this circuit	478			
Section 5:5	Total Circuit Length	76.83			
Section 5:4	Circuit Location	Hwy 254, Hwy 260			
Section 5:3	Circuit Name and Number	Brown Road Feeder 4			
Section 5:2	Substation Location	CountyHopkins	RoadBrown Road	TownMadisonville	
Section 5:1	Substation name and Number	Hanson 51			

Section 5:9	Circuit 5 year average (SAIDI)	1.123734888	
Section 5:10	Reporting year (SAIDI)	0.693419551	
Section 5:11	Circuit 5 year average (SAIFI)	0.018716426	
Section 5:12	Reporting year (SAIFI)	0.012489706	
Section 5:13	List of corrective action, if any, taken of	Resolved at time of outage.	

ANIMAL

57.1%

PUBLIC

7.1%

UNKNOWN

7.1%

Section 5:1	Substation name and Number	Hawesville 13		
Section 5:2	Substation Location	CountyHancock	RoadHwy 1389	TownHawesville
Section 5:3	Circuit Name and Number	Downtown Hawesvill	e Feeder 1	
Section 5:4	Circuit Location	Hwy 334, Downtown,	Pear Tree Lane	
Section 5:5	Total Circuit Length	16.95		
Section 5:6	Member count for this circuit	270		
Section 5:7	Date of last circuit trim (VM)	2015		
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by	each cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
				28.6%

Section 5:9	Circuit 5 year average (SAIDI)	0.232491807	
Section 5:10	Reporting year (SAIDI)	0.145043152	
Section 5:11	Circuit 5 year average (SAIFI)	0.002956671	
Section 5:12	Reporting year (SAIFI)	0.002435387	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

.

ANIMAL

29.4%

PUBLIC

UNKNOWN

11.8%

~

Section 5:1	Substation name and Number	Hawesville 13		
Section 5:2	Substation Location	CountyHancock	Road <b>Hwy 1389</b>	TownHawesville
Section 5:3	Circuit Name and Number	Kelly Heights Feeder (	2	
Section 5:4	Circuit Location	Kelly Heights, Skkillm	an Rd	
Section 5:5	Total Circuit Length	44.94		
Section 5:6	Member count for this circuit	417		
Section 5:7	Date of last circuit trim (VM)	2015		
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by	each cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		14.2%	17.79	%

.

Section 5:9	Circuit 5 year average (SAIDI)	1.190363413	]
Section 5:10	Reporting year (SAIDI)	2.53992366	
Section 5:11	Circuit 5 year average (SAIFI)	0.012524876	
Section 5:12	Reporting year (SAIFI)	0.032657856	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

.

UNKNOWN

13.0%

ANIMAL

21.7%

PUBLIC

Section 5:1	Substation name and Number	Hawesville 13			
Section 5:2	Substation Location	CountyHancock	RoadHwy 1389	TownHawesville	
Section 5:3	Circuit Name and Number	Hwy 69 Feeder 3			
Section 5:4	Circuit Location	Hwy 69, Tick Ridge R	d		
Section 5:5	Total Circuit Length	61.32			
Section 5:6	Member count for this circuit	479			
Section 5:7	Date of last circuit trim (VM)	2015			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by	each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		43.5%	6 8.79	6 13.0 <sup>4</sup>	%

Section 5:9	Circuit 5 year average (SAIDI)	0.441974318	
Section 5:10	Reporting year (SAIDI)	0.52101855	
Section 5:11	Circuit 5 year average (SAIFI)	0.005934555	
Section 5:12	Reporting year (SAIFI)	0.004756223	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

.

•

,

9.5%

UNKNOWN

ANIMAL

28.6%

PUBLIC

.

19.1%

Section 5:1	Substation name and Number	Hawesville 13				
Section 5:2	Substation Location	CountyHancock	RoadHwy 1389	TownHawesville		
Section 5:3	Circuit Name and Number	Utility/Hwy 1389				
Section 5:4	Circuit Location	Frank Gaynor Rd.				
Section 5:5	Total Circuit Length	68.21				
Section 5:6	Member count for this circuit	369				
Section 5:7	Date of last circuit trim (VM)	2015				
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by e	ach cause		
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER		
		19.1%	b 19.1%		4.8%	

Section 5:9	Circuit 5 year average (SAIDI)	0.560952137	
Section 5:10	Reporting year (SAIDI)	0.39987567	
Section 5:11	Circuit 5 year average (SAIFI)	0.008969845	
Section 5:12	Reporting year (SAIFI)	0.012072029	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

ANIMAL

29.4%

PUBLIC

11.8%

UNKNOWN

11.8%

Section 5:1	Substation name and Number	Hawesville 13		
Section 5:2	Substation Location	CountyHancock	RoadHwy 1389	TownHawesville
Section 5:3	Circuit Name and Number	Windward Heights Fe	eder 5	
Section 5:4	Circuit Location	Hwy 1847		
Section 5:5	Total Circuit Length	25.31		
Section 5:6	Member count for this circuit	241		
Section 5:7	Date of last circuit trim (VM)	2014		
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by	each cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		11.8%	b	35.3%

Section 5:9	Circuit 5 year average (SAIDI)	0.427718463	
Section 5:10	Reporting year (SAIDI)	0.439749574	
Section 5:11	Circuit 5 year average (SAIFI)	0.005498873	
Section 5:12	Reporting year (SAIFI)	0.009062116	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

.

ANIMAL

20.0%

PUBLIC

UNKNOWN

30.0%

Section 5:1	Substation name and Number	Horse Fork 20		
Section 5:2	Substation Location	CountyDaviess	RoadVeach Road	TownOwensboro
Section 5:3	Circuit Name and Number	Foors Lane Feeder 1		
Section 5:4	Circuit Location	Deer Park, Stone Cree	k, Foors Lane	
Section 5:5	Total Circuit Length	15.66		
Section 5:6	Member count for this circuit	232		
Section 5:7	Date of last circuit trim (VM)	2015		
Section 5:8	List outage causes for circuit along wit	h % of total outage nu	mbers represented by e	each cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
	10.0%	20.0%	10.0%	6 10.0%

Section 5:9	Circuit 5 year average (SAIDI)	0.187250795	
Section 5:10	Reporting year (SAIDI)	0.388715749	
Section 5:11	Circuit 5 year average (SAIFI)	0.003467648	
Section 5:12	Reporting year (SAIFI)	0.004818166	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

.

-

:

PUBLIC

11.1%

ANIMAL

UNKNOWN

11.1%

Section 5:1	Substation name and Number	Horse Fork 20			
Section 5:2	Substation Location	CountyDaviess	RoadVeach Road	Town <b>Owensboro</b>	
Section 5:3	Circuit Name and Number	Springbank Feeder 2			
Section 5:4	Circuit Location	Forest Hills, Bridle Rid	ge		
Section 5:5	Total Circuit Length	22.76			
Section 5:6	Member count for this circuit	353			
Section 5:7	Date of last circuit trim (VM)	2015			
Section 5:8	List outage causes for circuit along wit	h % of total outage <u>nu</u>	mbers represented by e	each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
	11.1%	44.4%		22.2%	

Section 5:9	Circuit 5 year average (SAIDI)	0.507105958	
Section 5:10	Reporting year (SAIDI)	0.553114446	
Section 5:11	Circuit 5 year average (SAIFI)	0.006997548	
Section 5:12	Reporting year (SAIFI)	0.005401938	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

.

.

-

PUBLIC

UNKNOWN

ANIMAL

Substation name and Number	Horse Fork 20			
Substation Location	CountyDaviess	RoadVeach Road	Town <b>Owensboro</b>	
Circuit Name and Number	Sutherland Road Fee	eder 3		
Circuit Location	Sutherland Road			
Total Circuit Length	3.74			
Member count for this circuit	8			
Date of last circuit trim (VM)	2014			
List outage causes for circuit along v	with % of total outage n	umbers represented by	each cause	•
PLANNED	EQUIPMENT FAILUR	E ROW	WEATHER	
	100.09	%		
	Substation Location Circuit Name and Number Circuit Location Total Circuit Length Member count for this circuit Date of last circuit trim (VM) List outage causes for circuit along y	Substation Location       CountyDaviess         Circuit Name and Number       Sutherland Road Fee         Circuit Location       Sutherland Road         Total Circuit Length       3.74         Member count for this circuit       8         Date of last circuit trim (VM)       2014         List outage causes for circuit along with % of total outage n         PLANNED       EQUIPMENT FAILUR	Substation Location       CountyDaviess       RoadVeach Road         Circuit Name and Number       Sutherland Road Feeder 3         Circuit Location       Sutherland Road         Total Circuit Length       3.74         Member count for this circuit       8         Date of last circuit trim (VM)       2014         List outage causes for circuit along with % of total outage numbers represented by	Substation Location       CountyDaviess       RoadVeach Road       TownOwensboro         Circuit Name and Number       Sutherland Road Feeder 3       Sutherland Road         Circuit Location       Sutherland Road       3.74         Member count for this circuit       8         Date of last circuit trim (VM)       2014         List outage causes for circuit along with % of total outage numbers represented by each cause       PLANNED         EQUIPMENT FAILURE       ROW       WEATHER

Section 5:9	Circuit 5 year average (SAIDI)	0.026090722	
Section 5:10	Reporting year (SAIDI)	0	
Section 5:11	Circuit 5 year average (SAIFI)	0.000341899	
Section 5:12	Reporting year (SAIFI)	0	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

.

•

UNKNOWN

,

PUBLIC

25.0%

ANIMAL

25.0%

Section 5:2       Substation Location       CountyDaviess       RoadVeach Road       TownOwensboro         Section 5:3       Circuit Name and Number       Marlboro Apartments Feeder 4       Lowes, Staples         Section 5:4       Circuit Location       Lowes, Staples       Section 5:6       Member count for this circuit       9.33         Section 5:5       Total Circuit trim (VM)       2014       Section 5:7       Date of last circuit trim (VM)       2014         Section 5:8       List outage causes for circuit along with % of total outage numbers represented by each cause       POWER SUPPLY       PLANNED       EQUIPMENT FAILURE       ROW       WEATHER	Section 5:1	Substation name and Number	Horse Fork 20				
Section 5:4       Circuit Location       Lowes, Staples         Section 5:5       Total Circuit Length       9.33         Section 5:6       Member count for this circuit       173         Section 5:7       Date of last circuit trim (VM)       2014         Section 5:8       List outage causes for circuit along with % of total outage numbers represented by each cause         POWER SUPPLY       PLANNED       EQUIPMENT FAILURE       ROW       WEATHER	Section 5:2	Substation Location	CountyDaviess	RoadVeach Road	TownOwensboro		
Section 5:5       Total Circuit Length       9.33         Section 5:6       Member count for this circuit       173         Section 5:7       Date of last circuit trim (VM)       2014         Section 5:8       List outage causes for circuit along with % of total outage numbers represented by each cause         POWER SUPPLY       PLANNED       EQUIPMENT FAILURE       ROW       WEATHER	Section 5:3	Circuit Name and Number	Marlboro Apartments Feeder 4				
Section 5:6       Member count for this circuit       173         Section 5:7       Date of last circuit trim (VM)       2014         Section 5:8       List outage causes for circuit along with % of total outage numbers represented by each cause         POWER SUPPLY       PLANNED       EQUIPMENT FAILURE       ROW       WEATHER	Section 5:4	Circuit Location	Lowes, Staples				
Section 5:7       Date of last circuit trim (VM)       2014         Section 5:8       List outage causes for circuit along with % of total outage numbers represented by each cause         POWER SUPPLY       PLANNED       EQUIPMENT FAILURE       ROW       WEATHER	Section 5:5	Total Circuit Length	9.33				
Section 5:8         List outage causes for circuit along with % of total outage numbers represented by each cause           POWER SUPPLY         PLANNED         EQUIPMENT FAILURE         ROW         WEATHER	Section 5:6	Member count for this circuit	173				
POWER SUPPLY PLANNED EQUIPMENT FAILURE ROW WEATHER	Section 5:7	Date of last circuit trim (VM)	2014				
	Section 5:8	List outage causes for circuit along y	with % of total outage nu	imbers represented by	each cause	-	
	POWER SUPPLY	PLANNED	EQUIPMENT FAILURI	ROW	WEATHER		
25.0% 25.0%			25.0%	6	25.0%		

Section 5:9	Circuit 5 year average (SAIDI)	0.33273536	
Section 5:10	Reporting year (SAIDI)	0.123693862	
Section 5:11	Circuit 5 year average (SAIFI)	0.001611298	
Section 5:12	Reporting year (SAIFI)	0.004015053	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

PUBLIC

UNKNOWN

Section 5:1	Substation name and Number	Horse Fork 20			
Section 5:2	Substation Location	CountyDaviess	RoadVeach Road	TownOwensboro	
Section 5:3	Circuit Name and Number	Hampton Inn Feeder	5		
Section 5:4	Circuit Location	Salem Drive, Comfor	t lnn		
Section 5:5	Total Circuit Length	9.61			
Section 5:6	Member count for this circuit	232			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along v	with % of total outage nu	umbers represented by	each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILUR	E ROW	WEATHER	ANIMAL
		100.0%	6		

Section 5:9	Circuit 5 year average (SAIDI)	1.18127746	
Section 5:10	Reporting year (SAIDI)	0.4401 <u>004</u> 4	
Section 5:11	Circuit 5 year average (SAIFI)	0.007709211	
Section 5:12	Reporting year (SAIFI)	0.004560821	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

.

		No Ou	tages 2015				
Section 5:1	Substation name and Number	Hudson 65					
Section 5:2	Substation Location	CountyHenderson	RoadQuinns Landing	TownRobards			
Section 5:3	Circuit Name and Number	Protein Feeder 1					
Section 5:4	Circuit Location	Tyson Plant					
Section 5:5	Total Circuit Length	0.95					
Section 5:6	Member count for this circuit	1					
Section 5:7	Date of last circuit trim (VM)	2013					
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by ea	ch cause			
POWER SUPPL	Y PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN

Section 5:9	Circuit 5 year average (SAIDI)	0.0000	
Section 5:10	Reporting year (SAIDI)	0.0000	
Section 5:11	Circuit 5 year average (SAIFI)	0.0000	
Section 5:12	Reporting year (SAIFI)	0.0000	
Section 5:13	List of corrective action, if any, tal	en or to be taken	Evaluate & inspection circuit.

-

PUBLIC

25.0%

ANIMAL

UNKNOWN

25.0%

Section 5:1	Substation name and Number	Hudson 65			
Section 5:2	Substation Location	CountyHenderson	RoadQuinns Landing	TownRobards	
Section 5:3	Circuit Name and Number	Sebree #1 Feeder 4			
Section 5:4	Circuit Location	Feed Mill, Southern S	tates		
Section 5:5	Total Circuit Length	8.67			
Section 5:6	Member count for this circuit	29			
Section 5:7	Date of last circuit trim (VM)	2013			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by e	ach cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
25%		25.0%	, 0		

Section 5:9	Circuit 5 year average (SAIDI)	0.036434878	
Section 5:10	Reporting year (SAIDI)	0.055426949	
Section 5:11	Circuit 5 year average (SAIFI)	0.000418543	
Section 5:12	Reporting year (SAIFI)	0.00048424	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

.

PUBLIC

---

45.5%

ANIMAL

UNKNOWN

18.2%

Section 5:1	Substation name and Number	Hudson 65		
Section 5:2	Substation Location	CountyHenderson	RoadQuinns Landing	TownRobards
Section 5:3	Circuit Name and Number	Water #2 Feeder 6		
Section 5:4	Circuit Location	Hwy 41, Truck Stop		,
Section 5:5	Total Circuit Length	21.76		
Section 5:6	Member count for this circuit	146		
Section 5:7	Date of last circuit trim (VM)	2013		
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by e	ach cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
9%		27.3%		

Section 5:9	Circuit 5 year average (SAIDI)	0.115046651
Section 5:10	Reporting year (SAIDI)	0.069687782
Section 5:11	Circuit 5 year average (SAIFI)	0.002758976
Section 5:12	Reporting year (SAIFI)	0.002052279
Section 5:13	List of corrective action, if any, taken of	r to be taken Evaluate & inspection circuit.

.

•

.

PUBLIC

.

.

UNKNOWN

Section 5:1	Substation name and Number	Hudson 65			
Section 5:2	Substation Location	CountyHenderson	RoadQuinns Landing	TownRobards	
Section 5:3	Circuit Name and Number	Energy #2 Feeder 7			
Section 5:4	Circuit Location	Tyson Plant			
Section 5:5	Total Circuit Length	0.57			
Section 5:6	Member count for this circuit	1			
Section 5:7	Date of last circuit trim (VM)	2013			
Section 5:8	List outage causes for circuit along v	vith % of total outage nu	mbers represented by ea	ach cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
50.0%		50.0%			

Section 5:9	Circuit 5 year average (SAIDI)	0.115046651
Section 5:10	Reporting year (SAIDI)	0.069687782
Section 5:11	Circuit 5 year average (SAIFI)	0.002758976
Section 5:12	Reporting year (SAIFI)	0.002052279
Section 5:13	List of corrective action, if any, taken	or to be taken Evaluate & inspection circuit.

.

PUBLIC

9.1%

UNKNOWN

Section 5:1	Substation name and Number	Lewisport 12					
Section 5:2	Substation Location	CountyHancock	RoadHwy 657	TownLewisport			
Section 5:3	Circuit Name and Number	Morton Lane Feeder	1				
Section 5:4	Circuit Location	Old Hwy 60					
Section 5:5	Total Circuit Length	23.63				•	
Section 5:6	Member count for this circuit	430					
Section 5:7	Date of last circuit trim (VM)	2012					
Section 5:8	List outage causes for circuit along	with % of total outage nu	imbers represented by	each cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	E ROW	WEATHER		ANIMAL	
		54.6%	6	9	).1%	27.3%	
	<u> </u>						

Section 5:9	Circuit 5 year average (SAIDI)	0.272211013	
	Reporting year (SAIDI)	0.771707588	
Section 5:11	Circuit 5 year average (SAIFI)	0.004967279	
Section 5:12	Reporting year (SAIFI)	0.018185685	
Section 5:13	List of corrective action, if any, taken of	or to be taken	System improvement work order scheduled.

-

.

15.4%

	7.7%	23.1%	7.7%		30.8%	15.4%	15.4
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
Section 5:8	List outage causes for circuit along wit	th % of total outage nu	mbers represented by e	ach cause			
Section 5:7	Date of last circuit trim (VM)	2012					
Section 5:6	Member count for this circuit	444					
Section 5:5	Total Circuit Length	20.28					
Section 5:4	Circuit Location	Downtown					
Section 5:3	Circuit Name and Number	Lewisport Feeder 2					
Section 5:2	Substation Location	CountyHancock	RoadHwy 657	Town <b>Lewisport</b>			
Section 5:1	Substation name and Number	Lewisport 12					

Section 5:9	Circuit 5 year average (SAIDI)	0.59647069
Section 5:10	Reporting year (SAIDI)	0.385016714
Section 5:11	Circuit 5 year average (SAIFI)	0.008886425
Section 5:12	Reporting year (SAIFI)	0.013508373
Section 5:13	List of corrective action, if any, taken of	or to be taken VM to trim circuit

Section 5:1	Substation name and Number	Lewisport 12					
Section 5:2	Substation Location	CountyHancock	RoadHwy 657	TownLewisport			
Section 5:3	Circuit Name and Number	Shopping Center Feed	er 3				
Section 5:4	Circuit Location	Subway, Hancock Banl	k				
Section 5:5	Total Circuit Length	35.27					
Section 5:6	Member count for this circuit	229					
Section 5:7	Date of last circuit trim (VM)	2012					
Section 5:8	List outage causes for circuit along wi	th % of total outage num	nbers represented by e	ach cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
		25.0%	5.0%	35.0%	20.0%		15.0%

Section 5:9	Circuit 5 year average (SAIDI)	0.535919938		
Section 5:10	Reporting year (SAIDI)	1.232536754		
Section 5:11	Circuit 5 year average (SAIFI)	0.005189178		
Section 5:12	Reporting year (SAIFI)	0.017521528		
Section 5:13	List of corrective action, if any, taken or to be taken			

.

•

PUBLIC

9.1%

27.3%

.

UNKNOWN

9.1%

Substation name and Number	Lewisport 12				
Substation Location	CountyHancock	RoadHwy 657	TownLewisport		
Circuit Name and Number	Hwy 657 Feeder 4				
Circuit Location	Hwy 657, Hwy 661				
Total Circuit Length	39.64				
Member count for this circuit	223				
Date of last circuit trim (VM)	2014				
List outage causes for circuit along	with % of total outage nu	mbers represented by e	ach cause		
PLANNED	EQUIPMENT FAILURE	ROW	WEATHER		ANIMAL
	27.3%	9.1%	<u> </u>	3.2%	27.3
	Substation Location Circuit Name and Number Circuit Location Total Circuit Length Member count for this circuit Date of last circuit trim (VM) List outage causes for circuit along	Substation LocationCountyHancockCircuit Name and NumberHwy 657 Feeder 4Circuit LocationHwy 657, Hwy 661Total Circuit Length39.64Member count for this circuit223Date of last circuit trim (VM)2014List outage causes for circuit along with % of total outage nuPLANNEDEQUIPMENT FAILURE	Substation Location       CountyHancock       RoadHwy 657         Circuit Name and Number       Hwy 657 Feeder 4       Circuit Location         Circuit Location       Hwy 657, Hwy 661       Sold         Total Circuit Length       39.64       Sold         Member count for this circuit       223       Sold         Date of last circuit trim (VM)       2014       List outage causes for circuit along with % of total outage numbers represented by end         PLANNED       EQUIPMENT FAILURE       ROW	Substation Location       CountyHancock       RoadHwy 657       TownLewisport         Circuit Name and Number       Hwy 657 Feeder 4       Image: CountyLewisport         Circuit Location       Hwy 657, Hwy 661       Image: CountyLewisport         Total Circuit Length       39.64       Image: CountyLewisport         Member count for this circuit       223       Image: CountyLewisport         Date of last circuit trim (VM)       2014       Image: CountyLewisport         List outage causes for circuit along with % of total outage numbers represented by each cause       Image: County         PLANNED       EQUIPMENT FAILURE       ROW       WEATHER	Substation Location       CountyHancock       RoadHwy 657       TownLewisport         Circuit Name and Number       Hwy 657 Feeder 4       Image: County

Section 5:9	Circuit 5 year average (SAIDI)	0.513405582	
Section 5:10	Reporting year (SAIDI)	0.704165088	
Section 5:11	Circuit 5 year average (SAIFI)	. 0.007036217	
Section 5:12	Reporting year (SAIFI)	0.012242584	
Section 5:13	List of corrective action, if any, taken of	or to be taken VM to trim circuit	

		No Ou	itages 2015				
Section 5:1	Substation name and Number	Lewisport 12					
Section 5:2	Substation Location	CountyHancock	RoadHwy 657	TownLewisport			
Section 5:3	Circuit Name and Number	Dal Tile Feeder 5					
Section 5:4	Circuit Location	Dal Tile					
Section 5:5	Total Circuit Length	1.77					
Section 5:6	Member count for this circuit	2					
Section 5:7	Date of last circuit trim (VM)	2012					
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented b	y each cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOW

Section 5:9	Circuit 5 year average (SAIDI)	0.033680037	
Section 5:10	Reporting year (SAIDI)	0.00	
Section 5:11	Circuit 5 year average (SAIFI)	0.000247815	
Section 5:12	Reporting year (SAIFI)	0.00	
Section 5:13	List of corrective action, if any, taken of	VM to trim circuit	

Section 5:1	Substation name and Number	Lewisport 12				
Section 5:2	Substation Location	CountyHancock	RoadHwy 657	TownLewisport		
Section 5:3	Circuit Name and Number	Mcgill Lane Feeder 6				
Section 5:4	Circuit Location	Mroton Lane				
Section 5:5	Total Circuit Length	6.62				
Section 5:6	Member count for this circuit	75				
Section 5:7	Date of last circuit trim (VM)	2012				
Section 5:8	List outage causes for circuit along w	ith % of total outage nu	mbers represented by	each cause		
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC
		25.0%	b	25.0%		25.0%
<u> </u>	·					

UNKNOWN

25.0%

Section 5:9	Circuit 5 year average (SAIDI)	0.089356335	
Section 5:10	Reporting year (SAIDI)	0.192022065	
Section 5:11	Circuit 5 year average (SAIFI)	0.001377882	
Section 5:12	Reporting year (SAIFI)	0.00389867	
Section 5:13	List of corrective action, if any, taken or to be taken		M to trim circuit

PUBLIC

UNKNOWN

ANIMAL

.

18.8%

Section 5:1	Substation name and Number	Lewisport 12			
Section 5:2	Substation Location	CountyHancock	RoadHwy 657	TownLewisport	
Section 5:3	Circuit Name and Number	Maxwell Brothers Lur	nber Feeder 7		
Section 5:4	Circuit Location	Sand hill Rd., Hwy 334	4		
Section 5:5	Total Circuit Length	49.92			
Section 5:6	Member count for this circuit	309			
Section 5:7	Date of last circuit trim (VM)	2012			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by ea	ach cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		12.5%	18.8%	50.0%	Ţ

Section 5:9	Circuit 5 year average (SAIDI)	1.452559696
Section 5:10	Reporting year (SAIDI)	2.594602631
Section 5:11	Circuit 5 year average (SAIFI)	0.011551513
Section 5:12	Reporting year (SAIFI)	0.024001442
Section 5:13	List of corrective action, if any, taken of	or to be taken VM to trim circuit

PUBLIC

4.0%

ANIMAL

24.0%

UNKNOWN

24.0%

Section 5:1	Substation name and Number	Little Dixie 66			
Section 5:2	Substation Location	CountyHenderson	RoadLod Powell Rd	TownCorydon	
Section 5:3	Circuit Name and Number	Little Dixie Feeder 1			
Section 5:4	Circuit Location	Hwy 145			
Section 5:5	Total Circuit Length	65.53			
Section 5:6	Member count for this circuit	408			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along v	with % of total outage num	mbers represented by ea	ach cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		24.0%	16.0%		8.0%

Section 5:9	Circuit 5 year average (SAIDI)	1.328774232	
Section 5:10	Reporting year (SAIDI)	1.910098091	
Section 5:11	Circuit 5 year average (SAIFI)	0.016071083	
Section 5:12	Reporting year (SAIFI)	0.036991893	
Section 5:13	List of corrective action, if any, taken or to be taken		Evaluate & inspection circuit.

•

.

ANIMAL

PUBLIC

22.2%

UNKNOWN

22.2%

Section 5:1	Substation name and Number	Little Dixie 66			
Section 5:2	Substation Location	CountyHenderson	RoadLod Powell Rd	TownCorydon	
Section 5:3	Circuit Name and Number	Jonestand Feeder 2			
Section 5:4	Circuit Location	Jack Allen Rd.			
Section 5:5	Total Circuit Length	49.64		;	
Section 5:6	Member count for this circuit	220			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by ea	ch cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		. 22.2%		33.3%	Ď

Section 5:9	Circuit 5 year average (SAIDI)	1.622536951	
Section 5:10	Reporting year (SAIDI)	0.654272168	
Section 5:11	Circuit 5 year average (SAIFI)	0.010425913	
Section 5:12	Reporting year (SAIFI)	0.008589468	
Section 5:13	List of corrective action, if any, taken or to be taken		Evaluate & inspection circuit.

ANIMAL

8.3%

PUBLIC

8.3%

UNKNOWN

Section 5:3 Section 5:4	Circuit Name and Number Circuit Location	Candyland Feeder 3 Hwy 141			
		43.66			
Section 5:5	Total Circuit Length				
Section 5:6	Member count for this circuit	<b>161</b>			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by ea	ich cause	-
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		25.0%	16.7%	41.7%	

Section 5:9	Circuit 5 year average (SAIDI)	0.781035611	
Section 5:10	Reporting year (SAIDI)	0.727157602	
Section 5:11	Circuit 5 year average (SAIFI)	0.008999065	
Section 5:12	Reporting year (SAIFI)	0.005948844	
Section 5:13	List of corrective action, if any, taken or to be taken		Evaluate & inspection circuit.

Section 5:1	Substation name and Number	Lyon County 69			
Section 5:2	Substation Location	CountyLyon	RoadHwy 810	TownKuttawa	
Section 5:3	Circuit Name and Number	Sunnyside Feeder 1			
Section 5:4	Circuit Location	Hwy 810 North			
Section 5:5	Total Circuit Length	56.78			
Section 5:6	Member count for this circuit	313			
Section 5:7	Date of last circuit trim (VM)	2013			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by e	ach cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
5%		13.6%	18.2%	27.3%	18.2%
·					

Section 5:9	Circuit 5 year average (SAIDI)	0.5893736	
Section 5:10	Reporting year (SAIDI)	0.964596659	
Section 5:11	Circuit 5 year average (SAIFI)	0.006507895	
Section 5:12	Reporting year (SAIFI)	0.008530318	
Section 5:13	List of corrective action, if any, taken or to be taken		Evalua

Evaluate & inspection circuit.

.

.

.

PUBLIC

4.6%

UNKNOWN

13.6%

Section 5:1	Substation name and Number	Lyon County 69			
Section 5:2	Substation Location	CountyLyon	RoadHwy 810	TownKuttawa	
Section 5:3	Circuit Name and Number	Iron Hill Feeder 2			
Section 5:4	Circuit Location	Suwaee, Moon Bay			
Section 5:5	Total Circuit Length	52.8			
Section 5:6	Member count for this circuit	835			
Section 5:7	Date of last circuit trim (VM)	2013			
Section 5:8	List outage causes for circuit along wit	h % of total outage nu	mbers represented by ea	ach cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
3%	3.1%	15.6%	6 12.5%	15.6%	32.3%

Section 5:13	List of corrective action, if any, taken or to be taken		Evaluat
Section 5:12	Reporting year (SAIFI)	0.148162376	
Section 5:11	Circuit 5 year average (SAIFI)	0.052539095	
Section 5:10	Reporting year (SAIDI)	12.46192766	
Section 5:9	Circuit 5 year average (SAIDI)	5.503485576	

Evaluate & inspection circuit.

PUBLIC

12.5%

•

UNKNOWN

6.3%

ANIMAL

28.6%

PUBLIC

UNKNOWN

19.1%

-

Section 5:1	Substation name and Number	Lyon County 69		
Section 5:2	Substation Location	CountyLyon	Road <b>Hwy 810</b>	TownKuttawa
Section 5:3	Circuit Name and Number	Barkley Dam F3		
Section 5:4	Circuit Location	Hwy 62		
Section 5:5	Total Circuit Length	29.25		
Section 5:6	Member count for this circuit	299		
Section 5:7	Date of last circuit trim (VM)	2013		
Section 5:8	List outage causes for circuit along wi	th % of total outage nur	nbers represented by ea	ch cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
5%	4.8%	19.1%	9.5%	14.3%

Section 5:9	Circuit 5 year average (SAIDI)	0.896176165
Section 5:10	Reporting year (SAIDI)	0.477574395
Section 5:11	Circuit 5 year average (SAIFI)	0.008909152
Section 5:12	Reporting year (SAIFI)	0.005770435
Section 5:13	List of corrective action, if any, taken of	br to be taken Evaluate & inspection circuit.

PUBLIC

6.3%

ANIMAL

.

-

18.8%

UNKNOWN

12.5%

Section 5:1	Substation name and Number	Maceo 28		
Section 5:2	Substation Location	CountyDaviess	RoadYelvington Grandview	Town <b>Maceo</b>
Section 5:3	Circuit Name and Number	Chestnut Grove Rd I	Feeder 1	
Section 5:4	Circuit Location	Kelly Cemetery Roa	d	
Section 5:5	Total Circuit Length	22.57	-	
Section 5:6	Member count for this circuit	89		
Section 5:7	Date of last circuit trim (VM)	2015		
Section 5:8	List outage causes for circuit along	with % of total outage n	umbers represented by each caus	e
POWER SUPPLY	PLANNED	EQUIPMENT FAILUF	RE ROW	WEATHER
		25.0	%	3% 18.8%

Section 5:9	Circuit 5 year average (SAIDI)	0.249549528	
Section 5:10	Reporting year (SAIDI)	0.509751874	
Section 5:11	Circuit 5 year average (SAIFI)	0.002702891	
Section 5:12	Reporting year (SAIFI)	0.006327706	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Resolved at time of outage.

Section 5:1	Substation name and Number	Maceo 28		
Section 5:2	Substation Location	CountyDaviess	RoadYelvington Grandview Rd	TownMaceo
Section 5:3	Circuit Name and Number	Maceo Feeder 2		
Section 5:4	Circuit Location	Hwy 60		
Section 5:5	Total Circuit Length	20.75		
Section 5:6	Member count for this circuit	207		
Section 5:7	Date of last circuit trim (VM)	2015	-	
Section 5:8	List outage causes for circuit along	with % of total outage n	umbers represented by each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		28.6%	6 <u>1</u> 4.39	/6

Section 5:9	Circuit 5 year average (SAIDI)	0.410460628	
Section 5:10	Reporting year (SAIDI)	0.876096274	
Section 5:11	Circuit 5 year average (SAIFI)	0.005928265	
Section 5:12	Reporting year (SAIFI)	0.011778433	
Section 5:13	List of corrective action, if any, taken	or to be taken Resolved a	t 1

.

.

Resolved at time of outage.

.

PUBLIC

14.3% 14.3%

UNKNOWN

14.3%

ANIMAL

14.3%

.

Section 5:1	Substation name and Number	Maceo 28					
Section 5:2	Substation Location	CountyDaviess	RoadYelvington Grandview Rd	TownMaceo			
Section 5:3	Circuit Name and Number	Daviess co. Fish/Gam	e Feeder 3				
Section 5:4	Circuit Location	Hwy 662					
Section 5:5	Total Circuit Length	34.38					
Section 5:6	Member count for this circuit	197					
Section 5:7	Date of last circuit trim (VM)	2015					
Section 5:8	List outage causes for circuit along wi	th % of total outage n	umbers represented by each cause				
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
	6.3%	12.5%	18.8	% 37.5%	6.3%	18.8%	
L							
Section 5:9	Circuit 5 year average (SAIDI)	1.52955633	4				

Section 5:13	List of corrective action, if any, taken	or to be taken	Resolved at time of outage.
Section 5:12	Reporting year (SAIFI)	0.011488245	
Section 5:11	Circuit 5 year average (SAIFI)	0.011683344	
Section 5:10	Reporting year (SAIDI)	1.106679148	
Section 5:9	Circuit 5 year average (SAIDI)	1.529556334	

.

.

21.4%

Section 5:1	Substation name and Number	Maceo 28						
Section 5:2	Substation Location	CountyDaviess	RoadYelvington Grandview	Rd <sup>-</sup>	TownMaceo			
Section 5:3	Circuit Name and Number	Carpenters Lake Feed	er 4					
Section 5:4	Circuit Location	Saur Rd., Hwy 405						
Section 5:5	Total Circuit Length	18.79						
Section 5:6	Member count for this circuit	251						
Section 5:7	Date of last circuit trim (VM)	2015						
Section 5:8	List outage causes for circuit along w	ith % of total outage nu	mbers represented by each caus	e				
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW		WEATHER	ANIMAL	PUBLIC	UNKNOWN
		28.6%		28.6%	7.1%	14.3%		21.
Section 5:9	Circuit 5 year average (SAIDI)	0.721833799	).					
Section 5:10	Reporting year (SAIDI)	0.706443959						
Section 5:11	Circuit 5 year average (SAIFI)	0.00679233	5					

Section 5:12 Reporting year (SAIFI)

~

Section 5:13 List of corrective action, if any, taken or to be taken

Resolved at time of outage.

.

ANIMAL

-

25.0%

PUBLIC

UNKNOWN

25.0%

Section 5:1	Substation name and Number	Maceo 28			
Section 5:2	Substation Location	CountyDaviess	RoadYelvington Grandview Rd	TownMaceo	
Section 5:3	Circuit Name and Number	Stinnet Road Feeder	5		
Section 5:4	Circuit Location	Stinnet Rd.			
Section 5:5	Total Circuit Length	12.58			
Section 5:6	Member count for this circuit	95			
Section 5:7	Date of last circuit trim (VM)	2015			
Section 5:8	List outage causes for circuit along	with % of total outage n	umbers represented by each cause	•	
POWER SUPPLY	PLANNED	EQUIPMENT FAILUR	E ROW	WEATHER	
		25.0%	6	25.0%	

Section 5:9	Circuit 5 year average (SAIDI)	0.091216916	
Section 5:10	Reporting year (SAIDI)	0.10823277	
Section 5:11	Circuit 5 year average (SAIFI)	0.001220079	
Section 5:12	Reporting year (SAIFI)	0.002073491	
Section 5:13	List of corrective action, if any, taken	or to be taken	Resolved at time of outage.

Section 5:1	Substation name and Number	Madisonville 49					
Section 5:2	Substation Location	CountyHopkins	RoadNebo Road	TownMadisonville			
Section 5:3	Circuit Name and Number	Industrial Park Feede	r 1				
Section 5:4	Circuit Location	Tucker Schoolhouse F	ld.				
Section 5:5	Total Circuit Length	12.77					
Section 5:6	Member count for this circuit	168					
Section 5:7	Date of last circuit trim (VM)	2013					
Section 5:8	List outage causes for circuit along w	ith % of total outage nu	mbers represented by each caus	<u>e</u>			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
		20.0%			80.0%		
<u></u>							

.

-

Section 5:9	Circuit 5 year average (SAIDI)	0.428263289	
Section 5:10	Reporting year (SAIDI)	0.220753541	
Section 5:11	Circuit 5 year average (SAIFI)	0.006908362	
Section 5:12	Reporting year (SAIFI)	0.002848029	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Resolved a

.

-

.

Resolved at time of outage.

.

Section 5:1	Substation name and Number	Madisonville 49					
Section 5:2	Substation Location	CountyHopkins	RoadNebo Road	TownMadisonville			
Section 5:3	Circuit Name and Number	Manitou Feeder 2					
Section 5:4	Circuit Location	Hwy 41A					
Section 5:5	Total Circuit Length	36.36					
Section 5:6	Member count for this circuit	283					
Section 5:7	Date of last circuit trim (VM)	2013					
Section 5:8	List outage causes for circuit along	with % of total outage nu	umbers represented by each ca	ause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
		33.3%					50.0%
L	·						
Section 5:9	Circuit 5 year average (SAIDI)	0.0171589	3				

.

Section 5:13	List of corrective action, if any, taken (	or to be taken Resolved at time of outage.
Section 5:12	Reporting year (SAIFI)	0.000409413
Section 5:11	Circuit 5 year average (SAIFI)	0.000187556
Section 5:10	Reporting year (SAIDI)	0.029014917
Section 5:9	Circuit 5 year average (SAIDI)	0.01/15895

•

			No Outage 2015				
Section 5:1	Substation name and Number	Madisonville 49					
Section 5:2	Substation Location	CountyHopkins	RoadNebo Road	TownMadisonville			
Section 5:3	Circuit Name and Number	Land of Frost Feeder	3				
Section 5:4	Circuit Location	Land of Frost					
Section 5:5	Total Circuit Length	0.8					
Section 5:6	Member count for this circuit	1					
Section 5:7	Date of last circuit trim (VM)	2013					
Section 5:8	List outage causes for circuit along v	with % of total outage nu	mbers represented by each cau	se			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN

-

Section 5:9	Circuit 5 year average (SAIDI)	0.000224742	
Section 5:10	Reporting year (SAIDI)	0	
Section 5:11	Circuit 5 year average (SAIFI)	0.000010918	
Section 5:12	Reporting year (SAIFI)	0	
Section 5:13	List of corrective action, if any, taken or to be taken		

ANIMAL

.

15.2%

PUBLIC

6.1%

UNKNOWN

12.1%

. .

Section 5:1	Substation name and Number	Marion 70		
Section 5:2	Substation Location	CountyCrittenden	RoadSparmill Rd	TownMarion
Section 5:3	Circuit Name and Number	Mattoon Feeder 1		
Section 5:4	Circuit Location	Hwy 120		
Section 5:5	Total Circuit Length	102.57		
Section 5:6	Member count for this circuit	449		
Section 5:7	Date of last circuit trim (VM)	2012		
Section 5:8	List outage causes for circuit along w	ith % of total outage nur	mbers represented by ea	ch cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		12.1%	6.1%	48.5%

Section 5:9	Circuit 5 year average (SAIDI)	0.629454577	
Section 5:10	Reporting year (SAIDI)	0.448561963	
Section 5:11	Circuit 5 year average (SAIFI)	0.007604857	
Section 5:12	Reporting year (SAIFI)	0.005121274	
Section 5:13	List of corrective action, if any, take	n or to be taken	Evaluate & inspection circuit.

. -

-

~

PUBLIC

4.6%

UNKNOWN

13.6%

Section 5:1	Substation name and Number	Marion 70			
Section 5:2	Substation Location	County <b>Crittenden</b>	Road <b>Sparmill Rd</b>	TownMarion	
Section 5:3	Circuit Name and Number	Princeton Feeder 2			
Section 5:4	Circuit Location	Piney Creek Rd.			
Section 5:5	Total Circuit Length	78.23			
Section 5:6	Member count for this circuit	314			
Section 5:7	Date of last circuit trim (VM)	2012			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by	each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
		9.1%		54.6%	18.2%

Section 5:9	Circuit 5 year average (SAIDI)	0.73779533	
Section 5:10	Reporting year (SAIDI)	2.45621864	
Section 5:11	Circuit 5 year average (SAIFI)	0.005712687	
Section 5:12	Reporting year (SAIFI)	0.014220126	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

ANIMAL

7.1%

PUBLIC

7.1%

UNKNOWN

21.4%

`

Section 5:1	Substation name and Number	Marion 70	,		
Section 5:2	Substation Location	CountyCrittenden	RoadSparmill Rd	TownMarion	
Section 5:3	Circuit Name and Number	Sheridan Feeder 3			
Section 5:4	Circuit Location	Crittenden Springs Rd			
Section 5:5	Total Circuit Length	171.1			
Section 5:6	Member count for this circuit	267			
Section 5:7	Date of last circuit trim (VM)	2012			
Section 5:8	List outage causes for circuit along v	vith % of total outage nu	mbers represented by e	each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		7.1%	35.7%	6 21.4%	

Section 5:9	Circuit 5 year average (SAIDI)	1.533393509	]
Section 5:10	Reporting year (SAIDI)	0.64824704	
Section 5:11	Circuit 5 year average (SAIFI)	0.014321164	
Section 5:12	Reporting year (SAIFI)	0.005735358	
Section 5:13	List of corrective action, if any, taken of	Evaluate & inspection circuit.	

PUBLIC

4.3%

-

UNKNOWN

21.3%

ANIMAL

8.5%

Section 5:1	Substation name and Number	Marion 70		
Section 5:2	Substation Location	CountyCrittenden	RoadSparmill Rd	TownMarion
Section 5:3	Circuit Name and Number	Dam 50 Feeder 4		
Section 5:4	Circuit Location	Hwy 91 North		
Section 5:5	Total Circuit Length	78.34		
Section 5:6	Member count for this circuit	729		
Section 5:7	Date of last circuit trim (VM)	2012		
Section 5:8	List outage causes for circuit along wit	h % of total outage nur	nbers represented by ea	ich cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
	2.1%	34.0%	8.5%	21.3%

Section 5:9	Circuit 5 year average (SAIDI)	2.775967849	
Section 5:10	Reporting year (SAIDI)	8.291445357	
Section 5:11	Circuit 5 year average (SAIFI)	0.02775269	
Section 5:12	Reporting year (SAIFI)	0.070877464	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

.

ANIMAL

25.0%

PUBLIC

UNKNOWN

25.0%

Section 5:1	Substation name and Number	Masonville 23		
Section 5:2	Substation Location	CountyDaviess	RoadHill Bridge Rd	TownMasonville
Section 5:3	Circuit Name and Number	Velvet Farms Pump Fe	eder 1	
Section 5:4	Circuit Location	Hwy 231 North		
Section 5:5	Total Circuit Length	16.79		
Section 5:6	Member count for this circuit	193		
Section 5:7	Date of last circuit trim (VM)	2015		
Section 5:8	List outage causes for circuit along w	vith % of total outage nur	nbers represented by e	ach cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		25.0%		25.0%

Section 5:9	Circuit 5 year average (SAIDI)	0.115876332	
Section 5:10	Reporting year (SAIDI)	0.02499199	
Section 5:11	Circuit 5 year average (SAIFI)	0.000866519	
Section 5:12	Reporting year (SAIFI)	0.000356011	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Resolved at time of outage.

7

PUBLIC

5.0%

UNKNOWN

10.0%

٠

ANIMAL

25.0%

Section 5:1	Substation name and Number	Masonville 23		
Section 5:2	Substation Location	CountyDaviess	RoadHill Bridge Rd	TownMasonville
Section 5:3	Circuit Name and Number	Stoney Brook Subdivi	sion Feeder 2	
Section 5:4	Circuit Location	Old Hartford Road		
Section 5:5	Total Circuit Length	28.36		
Section 5:6	Member count for this circuit	546		
Section 5:7	Date of last circuit trim (VM)	2015		
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by e	ach cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		50.0%	510.0%	, D

Section 5:9	Circuit 5 year average (SAIDI)	0.581382514	
Section 5:10	Reporting year (SAIDI)	2.155819665	
Section 5:11	Circuit 5 year average (SAIFI)	0.007562309	
Section 5:12	Reporting year (SAIFI)	0.024306462	
Section 5:13	List of corrective action, if any, taken of	or to be taken	System improvement work order scheduled.

PUBLIC

10.0%

ANIMAL

30.0%

UNKNOWN

23.3%

Section 5:1	Substation name and Number	Masonville 23			
Section 5:2	Substation Location	CountyDaviess	RoadHill Bridge Rd	Town <b>Masonville</b>	-
Section 5:3	Circuit Name and Number	Msonville Feeder 3			
Section 5:4	Circuit Location	Hwy 231 South			
Section 5:5	Total Circuit Length	54.45			
Section 5:6	Member count for this circuit	684			
Section 5:7	Date of last circuit trim (VM)	2015			
Section 5:8	List outage causes for circuit along with	h % of total outage num	bers represented by each	cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		23.3%		13	3.3%

Section 5:9	Circuit 5 year average (SAIDI)	1.335259319	] .
Section 5:10	Reporting year (SAIDI)	1.713017146	
Section 5:11	Circuit 5 year average (SAIFI)	0.026308291	
Section 5:12	Reporting year (SAIFI)	0.055078223	
Section 5:13	List of corrective action, if any, taken of	or to be taken	System improvement work order scheduled.

ANIMAL

.

23.3%

PUBLIC

14.0%

UNKNOWN

4.7%

Section 5:1	Substation name and Number	Morganfield 71			
Section 5:2	Substation Location	CountyUnion	RoadTina Waggener Rd	TownMorganfield	
Section 5:3	Circuit Name and Number	Waverly Feeder 1			
Section 5:4	Circuit Location	Hwy 141, Hwy 666			
Section 5:5	Total Circuit Length	103.29			
Section 5:6	Member count for this circuit	502			
Section 5:7	Date of last circuit trim (VM)	2013			
Section 5:8	List outage causes for circuit along wi	th % of total outage num	bers represented by each caus	e	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		20.9%	4.7%	32.69	6

Section 5:9	Circuit 5 year average (SAIDI)	1.596002282	
Section 5:10	Reporting year (SAIDI)	2.419359647	
Section 5:11	Circuit 5 year average (SAIFI)	0.032723771	
Section 5:12	Reporting year (SAIFI)	0.018499233	
Section 5:13	List of corrective action, if any, taken o	r to be taken	Look at adding additional lightning protection.

.

Section 5:1	Substation name and Number	Morganfield 71		
Section 5:2	Substation Location	CountyUnion	RoadTina Waggener Rd	TownMorganfield
Section 5:3	Circuit Name and Number	Boxville Feeder 2		
Section 5:4	Circuit Location	Blueberry Hill		
Section 5:5	Total Circuit Length	121.43		
Section 5:6	Member count for this circuit	551		
Section 5:7	Date of last circuit trim (VM)	2013		
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by each c	ause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
2%		28.8%	8.5%	6 30.5%

Section 5:9	Circuit 5 year average (SAIDI)	3.936125714	
Section 5:10	Reporting year (SAIDI)	8.046134468	
Section 5:11	Circuit 5 year average (SAIFI)	0.042171018	
Section 5:12	Reporting year (SAIFI)	0.065211287	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate

.

.

,

Evaluate & inspection circuit.

ANIMAL

17.0%

PUBLIC

3.4%

UNKNOWN

10.2%

-

PUBLIC

2.8%

ANIMAL

UNKNOWN

30.6%

Contine Er2 Su				
Section 5:2 Su	ubstation Location	CountyUnion	RoadTina Waggener Rd	TownMorganfield
Section 5:3 Cir	rcuit Name and Number	Caseyville Feeder 3		
Section 5:4 Cir	rcuit Location	Hwy 109, Hwy 1508		
Section 5:5 To	otal Circuit Length	84.96		
Section 5:6 M	lember count for this circuit	427		
Section 5:7 Da	ate of last circuit trim (VM)	2013 –		
Section 5:8 Lis	st outage causes for circuit along with	h % of total outage nur	mbers represented by each car	use
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
	2.8%	13.9%	11.1%	38.9%

Section 5:9	Circuit 5 year average (SAIDI)	0.818959477	
Section 5:10	Reporting year (SAIDI)	1.561603136	
Section 5:11	Circuit 5 year average (SAIFI)	0.008782034	
Section 5:12	Reporting year (SAIFI)	0.020581056	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

PUBLIC

16.7%

UNKNOWN

16.7%

ANIMAL

4.8%

Section 5:1	Substation name and Number	Morganfield 71			
Section 5:2	Substation Location	CountyUnion	RoadTina Waggener Rd	TownMorganfield	
Section 5:3	Circuit Name and Number	Spring Grove Feeder 4			
Section 5:4	Circuit Location	Hwy 56, Hwy 360			
Section 5:5	Total Circuit Length	74.84			
Section 5:6	Member count for this circuit	343			
Section 5:7	Date of last circuit trim (VM)	2013			
Section 5:8	List outage causes for circuit along wit	h % of total outage num	bers represented by each cau	Ise	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	_
	4.8%	21. <u>4%</u>		35.7%	ı

Section 5:9 Circuit 5 year average (SAIDI)	1.476465711
Section 5:10 Reporting year (SAIDI)	4.42330036
Section 5:11 Circuit 5 year average (SAIFI)	0.017633758
Section 5:12 Reporting year (SAIFI)	0.062587985
Section 5:13 List of corrective action, if any, take	en or to be taken <b>Evaluate &amp; inspection circuit</b> .

Section 5:1	Substation name and Number	Niagara 80				
Section 5:2	Substation Location	CountyHenderson	RoadHwy 136	TownHenderson		
Section 5:3	Circuit Name and Number	Niagara Feeder 1				
Section 5:4	Circuit Location	Hwy 136				
Section 5:5	Total Circuit Length	102.75				
Section 5:6	Member count for this circuit	709				
Section 5:7	Date of last circuit trim (VM)	2011/2016				
Section 5:8	List outage causes for circuit along	with % of total outage num	nbers represented by e	ach cause		
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER		
	<u> </u>	20.4%	Г <u>6 1 %</u>	. 9	1%	

Jection 3.0	List Outdee couses for circuit along the						r [
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
		39.4%	6.1%	9.1%	24.2%	6.1%	15.2%

Section 5:13	List of corrective action, if any, taken o	or to be taken	Evaluate & inspection circuit, VM
Section 5:12	Reporting year (SAIFI)	0.01123611	
Section 5:11	Circuit 5 year average (SAIFI)	0.020913428	
Section 5:10	Reporting year (SAIDI)	1.020860496	
Section 5:9	Circuit 5 year average (SAIDI)	1.975303344	
	•		1

Evaluate & inspection circuit, VM to trim circuit.

Section 5:1	Substation name and Number	Niagara 80		
Section 5:2	Substation Location	CountyHenderson	RoadHwy 136	TownHenderson
Section 5:3	Circuit Name and Number	Hwy 283 South Feede	r 2	
Section 5:4	Circuit Location	Pleasant Valley Rd		
Section 5:5	Total Circuit Length	58.47		
Section 5:6	Member count for this circuit	439		
Section 5:7	Date of last circuit trim (VM)	2011/2016		
Section 5:8	List outage causes for circuit along with % of total outage numbers represented by each cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER

POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
	4.6%	18.2%	18.2%	22.7%	22.7%	4.6%	9.1%

Section 5:9	Circuit 5 year average (SAIDI)	0.783609327		
Section 5:10	Reporting year (SAIDI)	1.502743973		
Section 5:11	Circuit 5 year average (SAIFI)	0.007986552		
Section 5:12	Reporting year (SAIFI)	0.015011727		
Section 5:13	ection 5:13 List of corrective action, if any, taken or to be taken			

Evaluate & inspection circuit, VM to trim circuit.

•

PUBLIC

UNKNOWN

38.5%

Section 5:1	Substation name and Number	Niagara 80			
Section 5:2	Substation Location	CountyHenderson	RoadHwy 136	TownHenderson	
Section 5:3	Circuit Name and Number	Anthoston Feeder 3			
Section 5:4	Circuit Location	Hwy 41 south			
Section 5:5	Total Circuit Length	38			
Section 5:6	Member count for this circuit	369			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by	each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
		7.7%		15.4%	38.5%
	•				

Section 5:9	Circuit 5 year average (SAIDI)	0.412488814	
Section 5:10	Reporting year (SAIDI)	0.346721117	
Section 5:11	Circuit 5 year average (SAIFI)	0.006799908	
Section 5:12	Reporting year (SAIFI)	0.011121585	
Section 5.12	List of corrective action if any taken of	or to be taken	Evaluate & inspection circuit. VM to tri

Evaluate & inspection circuit, VM to trim circuit. Section 5:13 List of corrective action, if any, taken or to be taken---

1

Section 5:1	Substation name and Number	Nuckols 42			
Section 5:2	Substation Location	CountyMcLean	RoadHwy 431	TownLivia	
Section 5:3	Circuit Name and Number	Barmet #1 Feeder 1			
Section 5:4	Circuit Location	Hwy 431			
Section 5:5	Total Circuit Length	1.59			
Section 5:6	Member count for this circuit	13			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented b	y each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
					50.0

.

.

Section 5:9	Circuit 5 year average (SAIDI)	0.010315351		
Section 5:10	Reporting year (SAIDI)	0.014098045		
Section 5:11	Circuit 5 year average (SAIFI)	0.000165939		
Section 5:12	Reporting year (SAIFI)	0.000284809		
Section 5:13	13 List of corrective action, if any, taken or to be taken			

k inspection circuit.

UNKNOWN

50.0%

PUBLIC

50.0%

.

----

No Outages 2015							
Section 5:1	Substation name and Number	Nuckols 42		_	-		
Section 5:2	Substation Location	CountyMcLean	RoadHwy 431	TownLivia			
Section 5:3	Circuit Name and Number	Barmet #2 Feeder 2					
Section 5:4	Circuit Location	Hwy 431					
Section 5:5	Total Circuit Length	0.74					
Section 5:6	Member count for this circuit	1					
Section 5:7	Date of last circuit trim (VM)	2014					
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented b	y each cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	

Section 5:9	Circuit 5 year average (SAIDI)	0.000335614			
Section 5:10	Reporting year (SAIDI)	0			
Section 5:11	Circuit 5 year average (SAIFI)	3.63874536			
Section 5:12	Reporting year (SAIFI)	0			
Section 5:13	List of corrective action, if any, taken or to be taken				

Section 5:1	Substation name and Number	Nuckols 42					
Section 5:2	Substation Location	CountyMcLean	RoadHwy 431	TownLivia			
Section 5:3	Circuit Name and Number	Nuckols Feeder 3					
Section 5:4	Circuit Location	Hwy 136, Hwy 1080					
Section 5:5	Total Circuit Length	61.1					
Section 5:6	Member count for this circuit	409					
Section 5:7	Date of last circuit trim (VM)	2014					
Section 5:8	List outage causes for circuit along wit	h % of total outage nu	mbers represented by	each cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
	4.2%	8.3%	8.39	6 25.0%	33.3%	4.2%	16.
	•						
			7				

Section 5:9	Circuit 5 year average (SAIDI)	0.80123992	
Section 5:10	Reporting year (SAIDI)	2.263785699	
Section 5:11	Circuit 5 year average (SAIFI)	0.007670171	
Section 5:12	Reporting year (SAIFI)	0.020801703	
Section 5:13	List of corrective action, if any, taken o	Evaluate & inspection circuit.	

.

· .

16.7%

Section 5:1	Substation name and Number	Nuckols 42					
Section 5:2	Substation Location	CountyMcLean	RoadHwy 431	TownLivia			
Section 5:3	Circuit Name and Number	Hwy 250/Buel Feeder	r 4				
Section 5:4	Circuit Location	Hwy 250/Hwy 798					
Section 5:5	Total Circuit Length	61.1					
Section 5:6	Member count for this circuit	370					
Section 5:7	Date of last circuit trim (VM)	2014					
Section 5:8	List outage causes for circuit along w	ith % of total outage nu	imbers represented b	y each cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER		PUBLIC	UNKNOWN
		38.9%	ó	22.2%	16.7%	5.6%	16.7%
<b></b>	•						

Section 5:9	Circuit 5 year average (SAIDI)	0.897995433		
Section 5:10	Reporting year (SAIDI)	0.482520123	1	
Section 5:11	Circuit 5 year average (SAIFI)	0.01017728		
Section 5:12	Reporting year (SAIFI)	0.004848734		
Section 5:13	List of corrective action, if any, taken or to be taken			

.

Evaluate & inspection circuit.

PUBLIC

UNKNOWN

8.7%

Section 5:1	Substation name and Number	Onton 52			
Section 5:2	Substation Location	CountyWebster	RoadHwy 41	TownSlaughters	
Section 5:3	Circuit Name and Number	Hwy 120 Feeder 1			
Section 5:4	Circuit Location	Hwy 1069, Texas Gas	Rd.		
Section 5:5	Total Circuit Length	83.96	,		
Section 5:6	Member count for this circuit	403			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along v	vith % of total outage nu	mbers represented by ea	ach cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
		26.1%	8.7%	21.7%	34.8%

Section 5:9	Circuit 5 year average (SAIDI)	0.869983434	
Section 5:10	Reporting year (SAIDI)	1.543648383	
Section 5:11	Circuit 5 year average (SAIFI)	0.009343842	
Section 5:12	Reporting year (SAIFI)	0.02013497	
Section 5:13	List of corrective action, if any, taken of	Add more critter guard.	

Section 5:1	Substation name and Number	Onton 52					
Section 5:2	Substation Location	CountyWebster - F	load <b>Hwy 41</b>	TownSlaughters			
Section 5:3	Circuit Name and Number	Sebree Feeder 2					
Section 5:4	Circuit Location	Hwy 41, Hwy 147					
Section 5:5	Total Circuit Length	66.8					
Section 5:6	Member count for this circuit	387					
Section 5:7	Date of last circuit trim (VM)	2014					
Section 5:8	List outage causes for circuit along v	with % of total outage num	bers represented by ea	ach cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
		13.3%	6.7%	40.0%	20.0%	13.3%	6.
	· · ·						

Section 5:9 (	Circuit 5 year average (SAIDI)	1.652180126	
Section 5:10 F	Reporting year (SAIDI)	0.561147849	
Section 5:11	Circuit 5 year average (SAIFI)	0.00758558	
Section 5:12	Reporting year (SAIFI)	0.009316951	
Section 5:13 1	ist of corrective action, if any, taken o	Look at adding additional lightnir	

ning protection.

6.7%

Section 5:1	Substation name and Number	Onton 52		-			
Section 5:2	Substation Location	CountyWebster	RoadHwy 41	TownSlaughters			
Section 5:3	Circuit Name and Number	Vandetta Road Feede	er 3				
Section 5:4	Circuit Location	Hwy 1033, Hwy 281					
Section 5:5	Total Circuit Length	47.12					
Section 5:6	Member count for this circuit	235					
Section 5:7	Date of last circuit trim (VM)	2014					
Section 5:8	List outage causes for circuit along wit	th % of total outage nu	mbers represented b	y each cause			·
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	
	6.3%	37.5%	, o	18.8%	25.0%		12.5%
L	·	<u> </u>					

Section 5:9	Circuit 5 year average (SAIDI)	0.360251797	
Section 5:10	Reporting year (SAIDI)	0.382020459	
Section 5:11	Circuit 5 year average (SAIFI)	0.003136437	
Section 5:12	Reporting year (SAIFI)	0.004142394	
Section 5:13	List of corrective action, if any, taken or to be taken		esc

Resolved at time of outage.

٨

ANIMAL

33.3%

PUBLIC

26.7%

UNKNOWN

Section 5:1	Substation name and Number	Philpot 25					
Section 5:2	Substation Location	CountyDaviess	RoadWinkler	TownPhilpot			
Section 5:3	Circuit Name and Number	Pleasant Valley Rd. F	eeder 1				
Section 5:4	Circuit Location	Knottsville, Pleasant	Point				
Section 5:5	Total Circuit Length	56.12					
Section 5:6	Member count for this circuit	449					
Section 5:7	Date of last circuit trim (VM)	2015					
Section 5:8	Section 5:8 List outage causes for circuit along with % of total outage numbers represented by each cause						
POWER SUPPLY	PLANNED	EQUIPMENT FAILURI	ROW	WEATHER			
		33.3%	6	6.	7%		

Section 5:9	Circuit 5 year average (SAIDI)	0.64972193	]
Section 5:10	Reporting year (SAIDI)	1.076429989	]
Section 5:11	Circuit 5 year average (SAIFI)	0.009857951	
Section 5:12	Reporting year (SAIFI)	0.015041968	]
	List of corrective action, if any, taken of	Add more critter guard.	

Section 5:1	Substation name and Number	Philpot 25						
Section 5:2	Substation Location	CountyDaviess	RoadWinkler	TownPhilpot				
Section 5:3	Circuit Name and Number	Old State Road Feede	er 3					
Section 5:4	Circuit Location	Old 54, Habit						
Section 5:5	Total Circuit Length	32.95						
Section 5:6	Member count for this circuit	292						
Section 5:7	Date of last circuit trim (VM)	2015						
Section 5:8	List outage causes for circuit along w	ith % of total outage nu	mbers represented by	each cause				
POWER SUPPLY	PLANNED	EQUIPMENT FAILURI	E ROW	WEATHER		ANÎMAL	PUBLIC	UNKNOWN
		27.89	6 5.0	5%	16.7%	16.7%	22.2%	<u>11.1%</u>
	<u> </u>							

.

,

1

.

.

Section 5:9	Circuit 5 year average (SAIDI)	0.606139452	
Section 5:10	Reporting year (SAIDI)	0.605894355	
Section 5:11	Circuit 5 year average (SAIFI)	0.010464541	
Section 5:12	Reporting year (SAIFI)	0.008996655	
Section 5:13	List of corrective action, if any, taken o	r to be taken Resolved at time of outage.	

•

Section 5:1	Substation name and Number	Philpot 25					
Section 5:2	Substation Location	CountyDaviess	RoadWinkler	TownPhilpot			
Section 5:3	Circuit Name and Number	Premium Alled Tool F	4				
Section 5:4	Circuit Location	Cedar Hills, Hagans					
Section 5:5	Total Circuit Length	6.55					
Section 5:6	Member count for this circuit	94					
Section 5:7	Date of last circuit trim (VM)	2015					
Section 5:8	List outage causes for circuit along w	vith % of total outage nu	imbers represented by	each cause		,	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	' ANIMAL	PUBLIC	UNKNOWN
			50.0%	6	50.0%		<u> </u>

Section 5:9	Circuit 5 year average (SAIDI)	0.072870989	
Section 5:10	Reporting year (SAIDI)	0.066302274	
Section 5:11	Circuit 5 year average (SAIFI)	0.001882412	
Section 5:12	Reporting year (SAIFI)	0.002100429	
Section 5:13	List of corrective action, if any, taken of	Resolved at time of outage.	

PUBLIC

12.5%

37.5%

UNKNOWN

18.8%

Section 5:1	Substation name and Number	Philpot 25			
Section 5:2	Substation Location	CountyDaviess	RoadWinkler	TownPhilpot	
Section 5:3	Circuit Name and Number	Karnes Grove Road Fe	eder 5		
Section 5:4	Circuit Location	Hwy 54			
Section 5:5	Total Circuit Length	56.22			
Section 5:6	Member count for this circuit	410			
Section 5:7	Date of last circuit trim (VM)	2015			
Section 5:8	List outage causes for circuit along v	with % of total outage nu	mbers represented by	each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL ,
		12.5%	18.89	6	37.5%

Section 5:9	Circuit 5 year average (SAIDI)	0.272217292	
Section 5:10	Reporting year (SAIDI)	0.449098506	
Section 5:11	Circuit 5 year average (SAIFI)	0.00529744	
Section 5:12	Reporting year (SAIFI)	0.006119396	
Section 5:13	List of corrective action, if any, taken of	or to be taken	System improvement work order scheduled.

Section 5:1	Substation name and Number	Philpot 25					
Section 5:2	Substation Location	CountyDaviess	RoadWinkler	Town <b>Philpot</b>			
Section 5:3	Circuit Name and Number	Cedar Hills Feeder 7					
Section 5:4	Circuit Location	Jack Hinton Rd., Shor	t Station Rd.				
Section 5:5	Total Circuit Length	51.54					
Section 5:6	Member count for this circuit	444					
Section 5:7	Date of last circuit trim (VM)	2015					
Section 5:8	List outage causes for circuit along w	ith % of total outage <u>nu</u>	mbers represented by	each cause		· .	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
		29.4%	6 _ 11.8	% 11.8%	41.2%		5.9%
	· · · · · · · · · · · · · · · · · · ·	-					

Section 5:9	Circuit 5 year average (SAIDI)	0.895107574	
Section 5:10	Reporting year (SAIDI)	1.555450205	
Section 5:11	Circuit 5 year average (SAIFI)	0.010705485	
Section 5:12	Reporting year (SAIFI)	0.019198583	
Section 5:13	List of corrective action, if any, taken of	Add more critter guard.	

PUBLIC

7.1%

UNKNOWN

14.3%

Section 5:1	Substation name and Number	Pleasant Ridge 26						
Section 5:2	Substation Location	CountyOhio	RoadHwy 764	TownPleasant Ridge				
Section 5:3	Circuit Name and Number	Bells Run Feeder 1						
Section 5:4	Circuit Location	Hwy 764						
Section 5:5	Total Circuit Length	34.65						
Section 5:6	Member count for this circuit	253						
Section 5:7	Date of last circuit trim (VM)	2014						
Section 5:8	on 5:8 List outage causes for circuit along with % of total outage numbers represented by each cause							
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL			
		21.4%	14.3%	21.49	6 21.4%			

Section 5:9	Circuit 5 year average (SAIDI)	0.554330433	
Section 5:10	Reporting year (SAIDI)	0.991324098	
Section 5:11	Circuit 5 year average (SAIFI)	0.00724038	
Section 5:12	Reporting year (SAIFI)	0.013493949	
Section 5:13	List of corrective action, if any, taken o	Evaluate & inspection circuit.	

Section 5:1	Substation name and Number	Pleasant Ridge 26		
Section 5:2	Substation Location	CountyOhio	Road <b>Hwy 764</b>	TownPleasant Ridge
Section 5:3	Circuit Name and Number	Maple Leaf Laké Feed	ler 2	
Section 5:4	Circuit Location	Hwy 231		
Section 5:5	Total Circuit Length	56.12		
Section 5:6	Member count for this circuit	531		
Section 5:7	Date of last circuit trim (VM)	2011/2016		
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by a	each cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		3.9%	7.7%	6 19.2%

Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit,
Section 5:12	Reporting year (SAIFI)	0.020171019	
Section 5:11	Circuit 5 year average (SAIFI)	0.011705586	
Section 5:10	Reporting year (SAIDI)	1.533155014	
Section 5:9	Circuit 5 year average (SAIDI)	0.776922196	

.

.

t, VM to trim circuit.

.

UNKNOWN

19.2%

PUBLIC

7.7%

ANIMAL

•

42.3%

,

ANIMAL

25.0%

PUBLIC

8.3%

UNKNOWN

33.3%

Section 5:1	Substation name and Number	Pleasant Ridge 26			
Section 5:2	Substation Location	CountyOhio	RoadHwy 764	TownPleasant Ridge	
Section 5:3	Circuit Name and Number	Poplar Log Bridge Fee	der 3		
Section 5:4	Circuit Location	Hwy 231, Crane Pond			
Section 5:5	Total Circuit Length	39.81			
Section 5:6	Member count for this circuit	253			
Section 5:7	Date of last circuit trim (VM)	2011/2016			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by ea	ach cause	_
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	•
		8.3%	8.3%	16.7%	

Section 5:9	Circuit 5 year average (SAIDI)	0.717885089	
Section 5:10	Reporting year (SAIDI)	0.611306389	
Section 5:11	Circuit 5 year average (SAIFI)	0.005323266	
Section 5:12	Reporting year (SAIFI)	0.008244035	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit, VM to trim circuit.

.

Section 5:1	Substation name and Number	Pleasant Ridge 26					
Section 5:2	Substation Location	CountyOhio	RoadHwy 764	TownPleasant Ridge			
Section 5:3	Circuit Name and Number	Hwy 140 west Feeder	4				
Section 5:4	Circuit Location	Hwy 140, Girl Scout R	d.				
Section 5:5	Total Circuit Length	19.51					
Section 5:6	Member count for this circuit	146					
Section 5:7	Date of last circuit trim (VM)	2014					
Section 5:8	List outage causes for circuit along w	ith % of total outage nu	mbers represented by e	each cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	l
		12.5%		12.5%	37.5%	12.5%	

~`

UNKNOWN

25.0%

Section 5:9	Circuit 5 year average (SAIDI)	0.161641502	
Section 5:10	Reporting year (SAIDI)	0.299107722	
Section 5:11	Circuit 5 year average (SAIFI)	0.002471921	
Section 5:12	Reporting year (SAIFI)	0.004181925	
Section 5:13	List of corrective action, if any, taken of	Evaluate & inspection circuit.	

.

.

1

# Section 5: Circuit Reporting 2015

# (Circuits with SAIDI and /or SAIFI exceeding 5 year average)

.

ROW

.

	• • • • • • • • •	Removed	from service 2015	. · · · ·	4	
Section 5:1	Substation name and Number	Portable 59				
Section 5:2	Substation Location	CountyHancock	RoadSkillman	TownHawesville		
Section 5:3	Circuit Name and Number	Cannelton F1				
Section 5:4	Circuit Location	Mason Rd., Skillman R	d.			
Section 5:5	Total Circuit Length	1.4				
Section 5:6	Member count for this circuit	26				
Section 5:7	Date of last circuit trim (VM)	2011				
Section 5:8	List outage causes for circuit along	with % of total outage nur	nbers represented by	/ each cause		
POWER SUPP	LYPLANNED	EQUIPMENT FAILURE	WEATHER	ANIMAL	PUBLIC	UNKNOWN
			100.0	)%		1

.

.

Section 5:9	Circuit 5 year average (SAIDI)	0.057869708	
Section 5:10	Reporting year (SAIDI)	0.176624176	
Section 5:11	Circuit 5 year average (SAIFI)	0.000517166	
Section 5:12	Reporting year (SAIFI)	0.001414796	
Section 5:13	List of corrective action, if any, taken of	Removed from service.	

•

ANIMAL

.

10.0%

PUBLIC

10.0%

UNKNOWN

10.0%

Section 5:1	Substation name and Number	Providence 81		
Section 5:2	Substation Location	CountyHopkins	RoadCutoff Rd	TownProvidence
Section 5:3	Circuit Name and Number	Providence Feeder 1		
Section 5:4	Circuit Location	Hwy 120, Hwy 293		
Section 5:5	Total Circuit Length	64.06		
Section 5:6	Member count for this circuit	310		
Section 5:7	Date of last circuit trim (VM)	2015		
Section 5:8 1	List outage causes for circuit along wi	th % of total outage nur	nbers represented by ea	ch cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		30.0%	10.0%	30.0%

Section 5:9	Circuit 5 year average (SAIDI)	1.741151882	
Section 5:10	Reporting year (SAIDI)	1.675046201	
Section 5:11	Circuit 5 year average (SAIFI)	0.015107538	
Section 5:12	Reporting year (SAIFI)	0.021111562	
Section 5:13	List of corrective action, if any, taken of	Resolved at time of outage.	

,

•

UNKNOWN

31.0%

ANIMAL

20.7%

PUBLIC

Section 5:1	Substation name and Number	Providence 81		
Section 5:2	Substation Location	CountyHopkins	RoadCutoff Rd	TownProvidence
Section 5:3	Circuit Name and Number	Dalton Feeder 2		
Section 5:4	Circuit Location	Hwy 109		
Section 5:5	Total Circuit Length	66.72		
Section 5:6	Member count for this circuit	336		
Section 5:7	Date of last circuit trim (VM)	2013		
Section 5:8	List outage causes for circuit along	with % of total outage nur	nbers represented by	each cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		10.3%	b	37.9%

Section 5:9	Circuit 5 year average (SAIDI)	0.881093215	]
Section 5:10	Reporting year (SAIDI)	2.807332648	
Section 5:11	Circuit 5 year average (SAIFI)	0.007958109	
Section 5:12	Reporting year (SAIFI)	0.023126656	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Look at adding additional lightning protection

PUBLIC

13.0%

UNKNOWN

4.4%

21.7%

Section 5:1	Substation name and Number	Providence 81		
Section 5:2	Substation Location	CountyHopkins	RoadCutoff Rd	TownProvidence
Section 5:3	Circuit Name and Number	Liberty Feeder 4		
Section 5:4	Circuit Location	Hwy 120 East, Hwy 42	lA	
Section 5:5	Total Circuit Length	80.47		
Section 5:6	Member count for this circuit	418		
Section 5:7	Date of last circuit trim (VM)	2015		
Section 5:8	List outage causes for circuit along v	with % of total outage nu	mbers represented by e	ach cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		30.4%	4.4%	26.1%

Section 5:9	Circuit 5 year average (SAIDI)	0.84044433	
Section 5:10	Reporting year (SAIDI)	2.836637127	
Section 5:11	Circuit 5 year average (SAIFI)	0.009290564	
Section 5:12	Reporting year (SAIFI)	0.02922194	
Section 5:13	List of corrective action, if any, taken of	Look at adding additional lightning protection.	

ANIMAL

35.3%

PUBLIC

UNKNOWN

Section 5:1	Substation name and Number	Race Creek 82			
Section 5:2	Substation Location	CountyHenderson	RoadHwy 1078	TownHenderson	
Section 5:3	Circuit Name and Number	Spottsville Feeder 1			
Section 5:4	Circuit Location	Hwy 1078 South			
Section 5:5	Total Circuit Length	29.6			
Section 5:6	Member count for this circuit	` <b>310</b>			
Section 5:7	Date of last circuit trim (VM)	2011, 2016			
Section 5:8	List outage causes for circuit along wit	h % of total outage num	bers represented by eac	h cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
6%	,	23.5%	11.8%	23.5%	ĺ

Section 5:9	Circuit 5 year average (SAIDI)	1.682828288	
Section 5:10	Reporting year (SAIDI)	1.473747868	
Section 5:11	Circuit 5 year average (SAIFI)	0.014770059	
Section 5:12	Reporting year (SAIFI)	0.017776767	1
Section 5:13	List of corrective action, if any, taken or to be taken		Evaluate & inspection circuit, VM to tr

ANIMAL

...

25.0%

PUBLIC

18.8%

UNKNOWN

Section 5:1	Substation name and Number	Race Creek 82		
Section 5:2	Substation Location	CountyHenderson	RoadHwy 1078	TownHenderson
Section 5:3	Circuit Name and Number	Baskett Feeder 2		
Section 5:4	Circuit Location	Country Club		
Section 5:5	Total Circuit Length	37.46		
Section 5:6	Member count for this circuit	370		
Section 5:7	Date of last circuit trim (VM)	2011/2016		
Section 5:8	List outage causes for circuit along v	with % of total outage num	nbers represented by ea	ach cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
6%		6.3%	43.8%	6

Section 5:9	Circuit 5 year average (SAIDI)	0.819681231	
Section 5:10	Reporting year (SAIDI)	0.383243229	
Section 5:11	Circuit 5 year average (SAIFI)	0.003828752	
Section 5:12	Reporting year (SAIFI)	0.004930969	
Section 5:13	List of corrective action, if any, taken or to be taken		Evaluate & inspection circuit, VM to trim circuit.

ANIMAL

42.9%

PUBLIC

UNKNOWN

14.3%

Section 5:1	Substation name and Number	Race Creek 82			
Section 5:2	Substation Location	CountyHenderson	RoadHwy 1078	TownHenderson	
Section 5:3	Circuit Name and Number	Rucker Road #1 Feeder	3		
Section 5:4	Circuit Location	Hwy 60, Wathem Lane			
Section 5:5	Total Circuit Length	28.52			
Section 5:6	Member count for this circuit	449			
Section 5:7	Date of last circuit trim (VM)	2011, 2016			
Section 5:8	List outage causes for circuit along with	h % of total outage num	bers represented by eac	:h cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
14%		28.6%			

Section 5:9	Circuit 5 year average (SAIDI)	1.266918368	]
Section 5:10	Reporting year (SAIDI)	1.160034376	
Section 5:11	Circuit 5 year average (SAIFI)	0.009311542	
Section 5:12	Reporting year (SAIFI)	0.013879282	
Section 5:13	List of corrective action, if any, taken o	Evaluate & inspection circuit, VM to trim circuit.	

No Outages 2015							
Section 5:1	Substation name and Number	Riverport 83	-				
Section 5:2	Substation Location	CountyHenderson I	Road	TownHenderson			
Section 5:3	Circuit Name and Number	Valley Grain Feeder 1					
Section 5:4	Circuit Location	Valley Grain Plant					
Section 5:5	Total Circuit Length	0.02					
Section 5:6	Member count for this circuit	1.					
Section 5:7	Date of last circuit trim (VM)	2012					
Section 5:8	List outage causes for circuit along	with % of total o <u>utage num</u>	bers represented i	y each cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOW

٧N

Section 5:9	Circuit 5 year average (SAIDI)	0.004046285
Section 5:10	Reporting year (SAIDI)	<u> </u>
Section 5:11	Circuit 5 year average (SAIFi)	5.47535E-05
Section 5:12	Reporting year (SAIFI)	0
Section 5:12	List of corrective action if any taken (	or to be taken

Section 5:13 List of corrective action, if any, taken or to be taken---

Section 5:1	Substation name and Number	Riverport 83					
Section 5:2	Substation Location	CountyHenderson	Road	TownHenderson			
Section 5:3	Circuit Name and Number	Unison Feeder 2			-		
Section 5:4	Circuit Location	Industrial Drive					
Section 5:5	Total Circuit Length	1.55					
Section 5:6	Member count for this circuit	10					
Section 5:7	Date of last circuit trim (VM)	2012					
Section 5:8	5:8 List outage causes for circuit along with % of total outage numbers represented by each cause						
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
							100.0%

Section 5:9	Circuit 5 year average (SAIDI)	0.001022435	
Section 5:10	Reporting year (SAIDI)	0.001655452	
Section 5:11	Circuit 5 year average (SAIFI)	1.43893E-05	
Section 5:12	Reporting year (SAIFI)	3.56011E-05	
Section 5:13	List of corrective action, if any, taken of	Resolved at	

.

1

Resolved at time of outage.

	,	ΝοΟι	itages 2015				
Section 5:1	Substation name and Number	Riverport 83					
Section 5:2	Substation Location	CountyHenderson	Road	TownHenderson			
Section 5:3	Circuit Name and Number	Shamrock Feeder 3					·
Section 5:4	Circuit Location	Shamrock Tecnologies					
Section 5:5	Total Circuit Length	0.49					
Section 5:6	Member count for this circuit	3					
Section 5:7	Date of last circuit trim (VM)	2012					
Section 5:8	List outage causes for circuit along	with % of total outage nur	nbers represented	by each cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWI

Ν

Section 5:9	Circuit 5 year average (SAIDI)	0.00	
Section 5:10	Reporting year (SAIDI)	0.00	
Section 5:11	Circuit 5 year average (SAIFI)	0.00	
Section 5:12	Reporting year (SAIFI)	0.00	
Section 5:13	List of corrective action, if any, taken or to be taken		

-

PUBLIC

5.6%

11.1%

UNKNOWN

38.9%

Section 5:1	Substation name and Number	Sacramento 50			
Section 5:2	Substation Location	CountyMcLean	RoadHwy 254	TownSacramento	
Section 5:3	Circuit Name and Number	Hwy 81 North Feede	r 1		
Section 5:4	Circuit Location	Hwy 81, Hwy 85			
Section 5:5	Total Circuit Length	49.72			
Section 5:6	Member count for this circuit	269			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along	with % of total outage n	umbers represented b	y each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILUR	E ROW	WEATHER	ANIMAL
		16.79	%	27.8%	11.1

Section 5:9	Circuit 5 year average (SAIDI)	0.332472415	
Section 5:10	Reporting year (SAIDI)	0.468789569	
Section 5:11	Circuit 5 year average (SAIFI)	0.004089766	
Section 5:12	Reporting year (SAIFI)	0.007722882	
Section 5:13	List of corrective action, if any, taken of	Resolved at time of outage.	

~

PUBLIC

UNKNOWN

9.1%

Section 5:1	Substation name and Number	Sacramento 50			
Section 5:2	Substation Location	County <b>McLean</b>	RoadHwy 254	TownSacramento	
Section 5:3	Circuit Name and Number	Hwy 81 South Feeder	3		
Section 5:4	Circuit Location	Hwy 81, Hwy 85			
Section 5:5	Total Circuit Length	25.16			
Section 5:6	Member count for this circuit	133			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along w	ith % of total outage nu	mbers represented by	each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
		36.4%		27.3	% 27.3%

Section 5:9	Circuit 5 year average (SAIDI)	0.259335888	
Section 5:10	Reporting year (SAIDI)	0.105026886	· .
Section 5:11	Circuit 5 year average (SAIFI)	0.00309407	
Section 5:12	Reporting year (SAIFi)	0.001267544	
Section 5:13	List of corrective action, if any, taken o	Resolved at time of outage.	

ANIMAL

PUBLIC

10.5%

UNKNOWN

5.3%

1

Section 5:1	Substation name and Number	Sacramento 50			
Section 5:2	Substation Location	CountyMcLean	RoadHwy 254	TownSacramento	
Section 5:3	Circuit Name and Number	Poplar Grove Feeder 4			
Section 5:4	Circuit Location	Hwy 1155, Bell Rd.			
Section 5:5	Total Circuit Length	53.71			
Section 5:6	Member count for this circuit	287			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along wi	th % of total outage nun	nbers represented by ea	ich cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		31.6%		52.6%	6

Section 5:9	Circuit 5 year average (SAIDI)	0.640682915	]
Section 5:10	Reporting year (SAIDI)	0.788420838	
Section 5:11	Circuit 5 year average (SAIFI)	0.00817432	
Section 5:12	Reporting year (SAIFI)	0.020355716	
Section 5:13	List of corrective action, if any, taken or to be taken		System improvement work order scheduled

ANIMAL

)

25.0%

PUBLIC

8.3%

UNKNOWN

16.7%

Section 5:1	Substation name and Number	Sebree 84			
Section 5:2	Substation Location	CountyWebster	RoadHwy 283	TownSebree	
Section 5:3	Circuit Name and Number	Robards Feeder 1	•		
Section 5:4	Circuit Location	Hwy 283, Hwy 416			
Section 5:5	Total Circuit Length	29.04			
Section 5:6	Member count for this circuit	135			
Section 5:7	Date of last circuit trim (VM)	2015			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by ea	ich cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		25.0%	16.7%	8.3	%

.

Section 5:9	Circuit 5 year average (SAIDI)	0.192025303	
Section 5:10	Reporting year (SAIDI)	0.240968458	
Section 5:11	Circuit 5 year average (SAIFI)	0.002327993	
Section 5:12	Reporting year (SAIFI)	0.003396136	
Section 5:13	List of corrective action, if any, taken of	Evaluate & inspection circuit.	

.

ANIMAL

-

28.6%

PUBLIC

28.6%

UNKNOWN

14.3%

Section 5:2 Su	ubstation Location	CountyWebster	RoadHwy 283	TownSebree	
Section 5:3 Cir	rcuit Name and Number	N/S Truck Stop Feeder	2		
Section 5:4 Cir	ircuit Location	Watkins School Rd.			
Section 5:5 To	otal Circuit Length	29.12			
Section 5:6 M	lember count for this circuit	166			
Section 5:7 Da	ate of last circuit trim (VM)	2015			
Section 5:8 Lis	st outage causes for circuit along with	h % of total outage nun	nbers represented by ea	ach cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
			14.3%	14.3%	

•

Section 5:9	Circuit 5 year average (SAIDI)	0.160499375	
Section 5:10	Reporting year (SAIDI)	0.227139272	
Section 5:11	Circuit 5 year average (SAIFI)	0.001959086	
Section 5:12	Reporting year (SAIFI)	0.002564157	
Section 5:13	List of corrective action, if any, taken of	Evaluate & inspection circuit.	

ANIMAL

7.1%

PUBLIC

7.1%

UNKNOWN

7.1%

Section 5:1	Substation name and Number	Sebree 84		
Section 5:2	Substation Location	CountyWebster	RoadHwy 283	TownSebree
Section 5:3	Circuit Name and Number	Ortiz Feeder 3		
Section 5:4	Circuit Location	Hwy 132, Hwy 138		
Section 5:5	Total Circuit Length	68.78		
Section 5:6	Member count for this circuit	308		
Section 5:7	Date of last circuit trim (VM)	2015		
Section 5:8	List outage causes for circuit along	with % of total outage_nu	mbers represented by ea	ach cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		21.4%	7.1%	50.0%

Section 5:9	Circuit 5 year average (SAIDI)	1.256084947	
Section 5:10	Reporting year (SAIDI)	1.038365841	
Section 5:11	Circuit 5 year average (SAIFI)	0.018640907	
Section 5:12	Reporting year (SAIFI)	0.011813091	
Section 5:13	List of corrective action, if any, taken of	Evaluate & inspection circuit.	

ANIMAL

33.3%

PUBLIC

5

UNKNOWN

33.3%

Section 5:1	Substation name and Number	Sebree 84		
Section 5:2	Substation Location	CountyWebster	RoadHwy 283	TownSebree
Section 5:3	Circuit Name and Number	Poole Feeder 4		
Section 5:4	Circuit Location	Hwy 56		
Section 5:5	Total Circuit Length	23.22		
Section 5:6	Member count for this circuit	120		
Section 5:7	Date of last circuit trim (VM)	2015		
Section 5:8	List outage causes for circuit along v	vith % of total outage nur	mbers represented by ea	ich cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		16.7%	16.7%	

Section 5:9	Circuit 5 year average (SAIDI)	0.40939638	
Section 5:10	Reporting year (SAIDI)	0.136447276	
Section 5:11	Circuit 5 year average (SAIFI)	0.003536985	
Section 5:12	Reporting year (SAIFI)	0.00233846	
	List of corrective action, if any, taken of	Evaluate & inspection circuit.	

PUBLIC

27.3%

ANIMAL

UNKNOWN

Section 5:1	Substation name and Number	South Dermont 18		
Section 5:2	Substation Location	CountyDaviess	RoadSettles Rd	TownOwensboro
Section 5:3	Circuit Name and Number	Lake Forest Feeder 1		
Section 5:4	Circuit Location	Lake Forest, Woodland	ds	
Section 5:5	Total Circuit Length	27.83		
Section 5:6	Member count for this circuit	860		
Section 5:7	Date of last circuit trim (VM)	2011/2016		
Section 5:8	List outage causes for circuit along wit	h % of total outage num	nbers represented by ea	ch cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
	9.1%	63.6%		

Section 5:9	Circuit 5 year average (SAIDI)	0.500052007
Section 5:10	Reporting year (SAIDI)	0.206442746
Section 5:11	Circuit 5 year average (SAIFI)	0.007642156
Section 5:12	Reporting year (SAIFI)	_0.001984666
Section 5:13	List of corrective action, if any, taken o	r to be taken VM to trim circuit

ANIMAL

.

.

.

16.7%

.

PUBLIC

UNKNOWN

Section 5:1	Substation name and Number	South Dermont 18		
Section 5:2	Substation Location	CountyDaviess	RoadSettles Rd	Town <b>Owensboro</b>
Section 5:3	Circuit Name and Number	Old Mill Feeder 2		
Section 5:4	Circuit Location	Country Heights Schoo	bl	
Section 5:5	Total Circuit Length	28.78		
Section 5:6	Member count for this circuit	399		
Section 5:7	Date of last circuit trim (VM)	2011/2016		
Section 5:8	List outage causes for circuit along v	vith % of total outage <u>nur</u>	mbers represented by	each cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		33.3%		50.0%

Section 5:9	Circuit 5 year average (SAIDI)	0.299540833
Section 5:10	Reporting year (SAIDI)	0.059468322
Section 5:11	Circuit 5 year average (SAIFI)	0.004210756
Section 5:12	Reporting year (SAIFI)	0.000393461
Section 5:13	List of corrective action, if any, taken of	or to be taken VM to trim circuit

Section 5:1	Substation name and Number	South Dermont 18				
Section 5:2	Substation Location	CountyDaviess	RoadSettles Rd	TownOwensboro		
Section 5:3	Circuit Name and Number	Windridge Country Ci	ub Feeder 3			
Section 5:4	Circuit Location	Millers Mill Road				
Section 5:5	Total Circuit Length	25.31				
Section 5:6	Member count for this circuit	293				
Section 5:7	Date of last circuit trim (VM)	<b>2011/20</b> 16				
Section 5:8	List outage causes for circuit along v	vith % of total outage nu	mbers represented by	each cause		
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER		ANIMAL
		18.2%			9.1%	54.6%

Section 5:9	Circuit 5 year average (SAIDI)	0.481891085	
Section 5:10	Reporting year (SAIDI)	0.597570821	
Section 5:11	Circuit 5 year average (SAIFI)	0.008943534	
Section 5:12	Reporting year (SAIFI)	0.007376875	
Section 5:13	List of corrective action, if any, taken of	VM to trim circuit, A	

.

VM to trim circuit, Add more critter guard.

PUBLIC

.

UNKNOWN

18.2%

ANIMAL

PUBLIC

.

•

UNKNOWN

Section 5:1	Substation name and Number	South Dermont 18			
Section 5:2	Substation Location	CountyDaviess	RoadSettles Rd	TownOwensboro	
Section 5:3	Circuit Name and Number	Scotty Lane Feeder 4		,	
Section 5:4	Circuit Location	Brookhill, Hunters Rid	ge		
Section 5:5	Total Circuit Length	35.03			
Section 5:6	Member count for this circuit	620			
Section 5:7	Date of last circuit trim (VM)	2011/2016			
Section 5:8	List outage causes for circuit along w	ith % of total outage nur	mbers represented by	each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		100.0%			

Section 5:9	Circuit 5 year average (SAIDI)	1.085986458	
Section 5:10	Reporting year (SAIDI)	0.693528454	
Section 5:11	Circuit 5 year average (SAIFI)	0.025909153	
Section 5:12	Reporting year (SAIFI)	0.015154429	
Section 5:13	List of corrective action, if any, take	or to be taken	Resolved at time of outage. VM to trim circuit

Section 5:1	Substation name and Number	South Dermont 18				
Section 5:2	Substation Location	CountyDaviess	RoadSettles Rd	TownOwensboro		
Section 5:3	Circuit Name and Number	Southeastern Parkwa	y Feeder 5			
Section 5:4	Circuit Location	Hillcrest, Daviess Co.	High			
Section 5:5	Total Circuit Length	27.99				
Section 5:6	Member count for this circuit	572				
Section 5:7	Date of last circuit trim (VM)	2011/2016				
Section 5:8	List outage causes for circuit along w	vith % of total outage nu	mbers represented by	each cause		
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC
		80.0%				

.

UNKNOWN

20.0%

. .

•

Section 5:9	Circuit 5 year average (SAIDI)	0.501972623	
Section 5:10	Reporting year (SAIDI)	0.4186 <u>8922</u>	
Section 5:11	Circuit 5 year average (SAIFI)	0.009820544	
Section 5:12	Reporting year (SAIFI)	0.003983953	
Section 5:13	List of corrective action, if any, taken or to be taken VM to trim circuit		

-

ANIMAL

PUBLIC

UNKNOWN

33.3%

Section 5:1	Substation name and Number	South Dermont 18			
Section 5:2	Substation Location	CountyDaviess	RoadSettles Rd	TownOwensboro	
Section 5:3	Circuit Name and Number	Kenergy Feeder 6			
Section 5:4	Circuit Location	Alvey Park Drive			
Section 5:5	Total Circuit Length	11.62			
Section 5:6	Member count for this circuit	174			
Section 5:7	Date of last circuit trim (VM)	2011/2016			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by	each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		33.3%	,	33.3%	6

Section 5:9	Circuit 5 year average (SAIDI)	0.105439369	
Section 5:10	Reporting year (SAIDI)	0.238771749	
Section 5:11	Circuit 5 year average (SAIFI)	0.00173561	
Section 5:12	Reporting year (SAIFI)	0.003857384	
Section 5:13	List of corrective action, if any, taken or to be taken VM to tri		

ANIMAL

22.2%

PUBLIC

11.1%

UNKNOWN

Section 5:1	Substation name and Number	South Hanson 53				
Section 5:2	Substation Location	CountyHopkins	RoadBrown Badgett Loop	TownMadisonville		
Section 5:3	Circuit Name and Number	Otter Lake Feeder 1				
Section 5:4	Circuit Location	Hwy 1069, Channel 19				
Section 5:5	Total Circuit Length	24.49				
Section 5:6	Member count for this circuit	235				
Section 5:7	Date of last circuit trim (VM)	2013				
Section 5:8	List outage causes for circuit along v	vith % of total outage nu	mbers represented by each caus	se		
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER		
		44.4%		22.29	6	

Section 5:9	Circuit 5 year average (SAIDI)	0.349397215	
Section 5:10	Reporting year (SAIDI)	0.184900492	
Section 5:11	Circuit 5 year average (SAIFI)	0.004556766	
Section 5:12	Reporting year (SAIFI)	0.003414973	
Section 5:13	List of corrective action, if any, taken or to be taken		Resolved at time of outage.

Section 5:1	Substation name and Number	South Hanson 53		
Section 5:2	Substation Location	CountyHopkins	RoadBrown Badgett Loop	TownMadisonville
Section 5:3	Circuit Name and Number	Veterans Hospital Fee	eder 2	
Section 5:4	Circuit Location	Hwy 281, Hwy 260		
Section 5:5	Total Circuit Length	26.25		
Section 5:6	Member count for this circuit	200		
Section 5:7	Date of last circuit trim (VM)	2013		
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by each cau	se
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		21.4%	6 7.19	% 21.4%

.

.

Section 5:9	Circuit 5 year average (SAIDI)	0.616283954		
Section 5:10	Reporting year (SAIDI)	0.957975595		
Section 5:11	Circuit 5 year average (SAIFI)	0.008961431		
Section 5:12	Reporting year (SAIFI)	0.011513448		
Section 5:13	List of corrective action, if any, taken or to be taken R			

•

-

Resolved at time of outage.

.

ANIMAL

35.7%

PUBLIC

7.1%

UNKNOWN

.

7.1%

1

ANIMAL

-

38.5%

PUBLIC

7.7%

UNKNOWN

Section 5:1	Substation name and Number	South Hanson 53			
Section 5:2	Substation Location	CountyHopkins	RoadBrown Badgett Loop	TownMadisonville	
Section 5:3	Circuit Name and Number	Gus Fowler Feeder 3			
Section 5:4	Circuit Location	Hwy 85, Brown Road			
Section 5:5	Total Circuit Length	25.8			
Section 5:6	Member count for this circuit	404			
Section 5:7	Date of last circuit trim (VM)	2013			
Section 5:8	List outage causes for circuit along v	with % of total outage nu	imbers represented by each caus	se	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURI	E ROW	WEATHER	
		30.8%	6 15.49	67.*	7%
POWER SUPPLY	PLANNED	_ <u></u>			7.

Section 5:9	Circuit 5 year average (SAIDI)	0.785718214	
Section 5:10	Reporting year (SAIDI)	0.703636172	
Section 5:11	Circuit 5 year average (SAIFI)	0.010907522	
Section 5:12	Reporting year (SAIFI)	0.012421486	
Section 5:13	List of corrective action, if any, taken of	Resolved at time of outage.	

,

PUBLIC

12.5%

25.0%

UNKNOWN

•

25.0%

-

Section 5:1	Substation name and Number	South Hanson 53			
Section 5:2	Substation Location	CountyHopkins	RoadBrown Badgett Loop	TownMadisonville	
Section 5:3	Circuit Name and Number	Tucker Schoolhouse I	Road Feeder 4		
Section 5:4	Circuit Location	Hwy 41, Rainwater R	oad		
Section 5:5	Total Circuit Length	19.93			
Section 5:6	Member count for this circuit	175			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along	with % of total outage nu	imbers represented by each cau	se	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	E ROW	WEATHER	ANIMAL
		37.5%	6		25.0

Section 5:9	Circuit 5 year average (SAIDI)	0.376236009	
Section 5:10	Reporting year (SAIDI)	0.534871	
Section 5:11	Circuit 5 year average (SAIFI)	0.005519948	
Section 5:12	Reporting year (SAIFI)	0.008420799	
Section 5:13	List of corrective action, if any, taken of	Resolved at time of outage.	

•

ANIMAL

21.1%

PUBLIC

10.5%

UNKNOWN

10.5%

Section 5:1	Substation name and Number	South Hanson 53			
Section 5:2	Substation Location	CountyHopkins	RoadBrown Badgett Loop	TownMadisonville	
Section 5:3	Circuit Name and Number	Wolf Hollow Road F	eeder 5		
Section 5:4	Circuit Location	Rose Creek, Hwy 630	) North		
Section 5:5	Total Circuit Length	60.01			
Section 5:6	Member count for this circuit	466			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along	with % of total outage n	umbers represented by each cau	ISE	
POWER SUPPLY	PLANNED	EQUIPMENT FAILUR	E ROW	WEATHER	
		21.1	% 15.89	%21.1%	
•			-		

Section 5:9	Circuit 5 year average (SAIDI)	1.006264114	
Section 5:10	Reporting year (SAIDI)	0.783763603	
Section 5:11	Circuit 5 year average (SAIFI)	0.010532954	
Section 5:12	Reporting year (SAIFI)	0.012061542	
Section 5:13	List of corrective action, if any, taken of	Resolved at time of outage.	

ANIMAL

48.2%

PUBLIC

11.1%

UNKNOWN

7.4%

Section 5:1	Substation name and Number	South Hanson 53		
Section 5:2	Substation Location	CountyHopkins	RoadBrown Badgett Loop	TownMadisonville
Section 5:3	Circuit Name and Number	Stagecoach Rd. Feed	ler 6	
Section 5:4	Circuit Location	Olive Rd., Jones Rd.		
Section 5:5	Total Circuit Length	72.43		
Section 5:6	Member count for this circuit	543		
Section 5:7	Date of last circuit trim (VM)	2014		
Section 5:8	List outage causes for circuit along	with % of total outage n	umbers represented by each cau	se
POWER SUPPLY	PLANNED	EQUIPMENT FAILUR	E ROW	WEATHER
		7.4	% 11.1'	% 14.8%

Section 5:9	Circuit 5 year average (SAIDI)	0.869502061	
Section 5:10	Reporting year (SAIDI)	3.051716135	
Section 5:11	Circuit 5 year average (SAIFI)	0.010944592	
Section 5:12	Reporting year (SAIFI)	0.028253876	
Section 5:13	List of corrective action, if any, taken of	Resolved at time of outage.	

PUBLIC

100.0%

ANIMAL

UNKNOWN

Section 5:1	Substation name and Number	South Owensboro 58		
Section 5:2	Substation Location	CountyDaviess	RoadBack Sq Drive	TownOwensboro
Section 5:3	Circuit Name and Number	Town quare North Fee	eder 1	
Section 5:4	Circuit Location	Ponderosa		
Section 5:5	Total Circuit Length	4.96		
Section 5:6	Member count for this circuit	312		
Section 5:7	Date of last circuit trim (VM)	2012		
Section 5:8	List outage causes for circuit along with	th % of total outage num	nbers represented by ea	ch cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER

Section 5:9	Circuit 5 year average (SAIDI)	0.334947913	
Section 5:10	Reporting year (SAIDI)	0.563786748	
Section 5:11	Circuit 5 year average (SAIFI)	0.003738323	
Section 5:12	Reporting year (SAIFI)	0.011604711	
Section 5:13	List of corrective action, if any, taken o	Resolved at time of outage.	

Section 5:1	Substation name and Number	South Owensboro 58					
Section 5:2	Substation Location	CountyDaviess	RoadBack Sq Drive	Town <b>Owensboro</b>			
Section 5:3	Circuit Name and Number	Penny's/Town Square	Ct. Feeder 2				
Section 5:4	Circuit Location	Famous Barr					
Section 5:5	Total Circuit Length	1.23					
Section 5:6	Member count for this circuit	30					
Section 5:7	Date of last circuit trim (VM)	2012					
Section 5:8	List outage causes for circuit along	with % of total outage nun	nbers represented by ea	ch cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	
				100.0%			

Section 5:9	Circuit 5 year average (SAIDI)	0.016414152	
Section 5:10	Reporting year (SAIDI)	0.036313147	
Section 5:11	Circuit 5 year average (SAIFI)	0.000357103	
Section 5:12	Reporting year (SAIFI)	0.000534017	
Section 5:13	List of corrective action, if any, taken o	Resolved at time of outage.	

Г

ANIMAL

PUBLIC

~

UNKNOWN

Section 5:1	Substation name and Number	South Owensboro 58	1	
Section 5:2	Substation Location	CountyDaviess	Road <b>Back Sq Drive</b>	TownOwensboro
Section 5:3	Circuit Name and Number	Sear's/Town Square	Ct. Feeder 3	
Section 5:4	Circuit Location	Sears, Ruby Tuesday'	S	
Section 5:5	Total Circuit Length	1.22		
Section 5:6	Member count for this circuit	25		
Section 5:7	Date of last circuit trim (VM)	2012		
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by ea	ich cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILUR	E ROW	WEATHER
		100.09	%	

Section 5:9	Circuit 5 year average (SAIDI)	0.016460834	
Section 5:10	Reporting year (SAIDI)	0.017782762	
Section 5:11	Circuit 5 year average (SAIFI)	0.000197932	
Section 5:12	Reporting year (SAIFI)	0.000480615	
Section 5:13	List of corrective action, if any, taken o	Resolved at time of outage.	

,

PUBLIC

50.0%

UNKNOWN

ANIMAL

Section 5:1	Substation name and Number	South Owensboro 58		
Section 5:2	Substation Location	CountyDaviess	RoadBack Sq Drive	TownOwensboro
Section 5:3	Circuit Name and Number	Hollywood Video Feed	ler 4	
Section 5:4	Circuit Location	Strictland Drive, South	ntown Blvd.	
Section 5:5	Total Circuit Length	1.69		
Section 5:6	Member count for this circuit	185		
Section 5:7	Date of last circuit trim (VM)	2012		
Section 5:8	List outage causes for circuit along wi	ith % of total outage nun	nbers represented by ea	ch cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		50.0%		

Section 5:9	Circuit 5 year average (SAIDI)	0.01073309	
Section 5:10	Reporting year (SAIDI)	0.012086582	
Section 5:11	Circuit 5 year average (SAIFI)	0.000190645	
Section 5:12	Reporting year (SAIFI)	0.00032041	
Section 5:13	List of corrective action, if any, taken o	Resolved at time of outage.	

Section 5:1	Substation name and Number	South Owensboro 58		
Section 5:2	Substation Location	CountyDaviess	Road <b>Back Sq Driv</b> e	Town <b>Owensboro</b>
Section 5:3	Circuit Name and Number	Twin Lakes Feeder 5		
Section 5:4	Circuit Location	South Town		
Section 5:5	Total Circuit Length	23.84		
Section 5:6	Member count for this circuit	830		
Section 5:7	Date of last circuit trim (VM)	2012		
Section 5:8	List outage causes for circuit along wit	h % of total outage num	bers represented by eac	h cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
	14.3%	57.1%		

Section 5:9	Circuit 5 year average (SAIDI)	0.97064948	
Section 5:10	Reporting year (SAIDI)	2.452280903	
Section 5:11	Circuit 5 year average (SAIFI)	0.018782824	
Section 5:12	Reporting year (SAIFI)	0.030777183	
Section 5:13	List of corrective action, if any, taken o	Resolved at time of outage.	

ANIMAL

14.3%

PUBLIC

UNKNOWN

14.3%

Section 5:1	Substation name and Number	South Owensboro 58		
Section 5:2	Substation Location	CountyDaviess	RoadBack Sq Drive	TownOwensboro
Section 5:3	Circuit Name and Number	Cracker Barrel Feeder	6	
Section 5:4	Circuit Location	Wal-Mart		
Section 5:5	Total Circuit Length	3.24		
Section 5:6	Member count for this circuit	41		
Section 5:7	Date of last circuit trim (VM)	2012		
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by e	ach_cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		C0.00/		

	POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
50.0%			50.0%	,			50.0%	

.

.

Section 5:9	Circuit 5 year average (SAIDI)	0.006882213	
Section 5:10	Reporting year (SAIDI)	0.033246103	
Section 5:11	Circuit 5 year average (SAIFI)	0.000131916	
Section 5:12	Reporting year (SAIFI)	0.000623331	
C	the share stress the stress the set of the s	n ha halian 🛛 🗖	ممماه

.

Section 5:13 List of corrective action, if any, taken or to be taken--- Resolved at time of outage.

ANIMAL

50.0%

PUBLIC

UNKNOWN

Section 5:1	Substation name and Number	South Owensboro 58		
Section 5:2	Substation Location	CountyDaviess	RoadBack Sq Drive	TownOwensboro
Section 5:3	Circuit Name and Number	Todd Bridge Rd. Feed	er 7	
Section 5:4	Circuit Location	Todd Bridge Rd.		
Section 5:5	Total Circuit Length	10.04		
Section 5:6	Member count for this circuit	44		
Section 5:7	Date of last circuit trim (VM)	2012		
Section 5:8	List outage causes for circuit along v	vith <u>% of total outage nur</u>	nbers represented by ea	ich cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		50.0%	, D	

Section 5:9	Circuit 5 year average (SAIDI)	0.052082315	
Section 5:10	Reporting year (SAIDI)	0.103653106	
Section 5:11	Circuit 5 year average (SAIFI)	0.000568522	
Section 5:12	Reporting year (SAIFI)	0.001716637	
Section 5:13	List of corrective action, if any, taken o	Resolved at time of outage.	

.

ANIMAL

16.0%

12.0%

PUBLIC

8.0%

UNKNOWN

20.0%

Section 5:1	Substation name and Number	St Joe 32		
Section 5:2	Substation Location	CountyDaviess	RoadHwy 500	Town <b>St. Jo</b> e
Section 5:3	Circuit Name and Number	Curdsville Feeder1		
Section 5:4	Circuit Location	Hwy 500, Hwy 456		
Section 5:5	Total Circuit Length	54.73		
Section 5:6	Member count for this circuit	351		
Section 5:7	Date of last circuit trim (VM)	2011/2016		
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by each	cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		40.0%	4.0%	)

Section 5:9	Circuit 5 year average (SAIDI)	0.638731756	
Section 5:10	Reporting year (SAIDI)	0.88177 <u>432</u>	
Section 5:11	Circuit 5 year average (SAIFI)	0.00953391	
Section 5:12	Reporting year (SAIFI)	0.023998981	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit, VM to trim circuit.

ANIMAL

10.3%

PUBLIC

UNKNOWN

20.7%

Section 5:1	Substation name and Number	St Joe 32			
Section 5:2	Substation Location	CountyDaviess	RoadHwy 500	Town <b>St. Joe</b>	
Section 5:3	Circuit Name and Number	West Louisville Feeder	• 2		
Section 5:4	Circuit Location	Hwy 56, Mulligan Rd.			
Section 5:5	Total Circuit Length	52.79			
Section 5:6	Member count for this circuit	286			
Section 5:7	Date of last circuit trim (VM)	2011/2016			
Section 5:8	List outage causes for circuit along with	h % of total outage nur	nbers represented by each	cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
	3.5%	31.0%	10.3%	24	1.1%

Section 5:9	Circuit 5 year average (SAIDI)	0.953435103	
Section 5:10	Reporting year (SAIDI)	1.376083815	
Section 5:11	Circuit 5 year average (SAIFI)	0.009598834	
Section 5:12	Reporting year (SAIFI)	0.010315459	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit, VM to trim circuit.

.

1

ANIMAL

16.7%

.

33.3%

PUBLIC

UNKNOWN

Section 5:1	Substation name and Number	St Joe 32		
Section 5:2	Substation Location	CountyDaviess	RoadHwy 500	Town <b>St. Jo</b> e
Section 5:3	Circuit Name and Number	Possum Trot Feeder 3		
Section 5:4	Circuit Location	Hwy 56, Mulligan Rd.		
Section 5:5	Total Circuit Length	27.54		
Section 5:6	Member count for this circuit	160		
Section 5:7	Date of last circuit trim (VM)	2011/2016		
Section 5:8	List outage causes for circuit along wi	th % of total outage nur	nbers represented by each	cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		16.7%	33.3%	

Section 5:9	Circuit 5 year average (SAIDI)	0.112943396	
Section 5:10	Reporting year (SAIDI)	0.164900786	
Section 5:11	Circuit 5 year average (SAIFI)	0.002586084	
Section 5:12	Reporting year (SAIFI)	0.005347867	
Section 5:13	List of corrective action, if any, taken	or to be taken	Evaluate & inspection circuit, VM to trim circuit.

PUBLIC

8.0%

ANIMAL

28.0%

.

UNKNOWN

12.0%

Section 5:1	Substation name and Number	Stanley 21			
Section 5:2	Substation Location	CountyDaviess	RoadHwy 1551	Town <b>Stanley</b>	
Section 5:3	Circuit Name and Number	Newman Feeder 1			
Section 5:4	Circuit Location	Hwy 60 West, Steamb	oat Road		
Section 5:5	Total Circuit Length	63.43			
Section 5:6	Member count for this circuit	446			
Section 5:7	Date of last circuit trim (VM)	2013			
Section 5:8	List outage causes for circuit along w	ith % of total outage nu	mbers represented by each	cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		_20.0%	4.0%	28.0%	6

Section 5:9	Circuit 5 year average (SAIDI)	1.499699836	
Section 5:10	Reporting year (SAIDI)	3.485922957	
Section 5:11	Circuit 5 year average (SAIFI)	0.018218177	
Section 5:12	Reporting year (SAIFI)	0.046068622	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

#### Section 5: Circuit Reporting 2015 (Circuits with SAIDI and /or SAIFI exceeding 5 year average)

#### Circuit Numbers should be reported excluding MED

.

.

				100.0%			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL '	PUBLIC	UNKNOWN
Section 5:8	List outage causes for circuit along v	with % of total outage nur	mbers represented by e	ach cause			
Section 5:7	Date of last circuit trim (VM)	2013					
Section 5:6	Member count for this circuit	76					
Section 5:5	Total Circuit Length	9.19					
Section 5:4	Circuit Location	Hwy 60 East					
Section 5:3	Circuit Name and Number	Hwy 60 East Feeder 2					
Section 5:2	Substation Location	CountyDaviess	RoadHwy 1551	TownStanley			
Section 5:1	Substation name and Number	Stanley 21					

Section 5:9	Circuit 5 year average (SAIDI)	0.018895054	
Section 5:10	Reporting year (SAIDI)	0.0153076	
Section 5:11	Circuit 5 year average (SAIFI)	0.000228198	
Section 5:12	Reporting year (SAIFI)	0.000143468	
Section 5:13	List of corrective action, if any, taken o	Evaluate & inspection circuit.	

Г

PUBLIC

14.3%

ANIMAL

UNKNOWN

.

Section 5:1	Substation name and Number	Stanley 21			
Section 5:2	Substation Location	CountyDaviess	Road <b>Hwy 1551</b>	Town <b>Stanley</b>	
Section 5:3	Circuit Name and Number	Birk City Feeder 3			
Section 5:4	Circuit Location	5th Street, Birk City			
Section 5:5	Total Circuit Length	26.77			
Section 5:6	Member count for this circuit	161			
Section 5:7	Date of last circuit trim (VM)	2013			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by each	cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		42.9%		42.9%	

Section 5:9	Circuit 5 year average (SAIDI)	0.118726318	
Section 5:10	Reporting year (SAIDI)	0.042452116	
Section 5:11	Circuit 5 year average (SAIFI)	0.001882449	
Section 5:12	Reporting year (SAIFI)	0.000375961	
Section 5:13	List of corrective action, if any, taken or to be taken		Evaluate & inspection circu

,

ANIMAL

28.6%

21.4%

PUBLIC

14.3%

UNKNOWN

14.3%

Section 5:1	Substation name and Number	Sullivan 85		
Section 5:2	Substation Location	CountyCrittended	RoadBlackford Ch Rd	TownSturgis
Section 5:3	Circuit Name and Number	Sullivan Feeder 1		
Section 5:4	Circuit Location	Hwy 141, Hwy 60 East	:	
Section 5:5	Total Circuit Length	44.54		
Section 5:6	Member count for this circuit	169		
Section 5:7	Date of last circuit trim (VM)	2011/2016		
Section 5:8	List outage causes for circuit along	with % of total outage nur	nbers represented by each	i cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		21.4%		

Section 5:9	Circuit 5 year average (SAIDI)	0.622263113	
Section 5:10	Reporting year (SAIDI)	1.077758637	
Section 5:11	Circuit 5 year average (SAIFI)	0.008355662	
Section 5:12	Reporting year (SAIFI)	0.013322746	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit, VM to trim circuit.

ANIMAL

12.0%

PUBLIC

4.0%

UNKNOWN

16.0%

Section 5:1	Substation name and Number	Sullivan 85			
Section 5:2	Substation Location	CountyCrittended	RoadBlackford Ch Rd	TownSturgis	
Section 5:3	Circuit Name and Number	Blackford Feeder 2			
Section 5:4	Circuit Location	Blackford, Hwy 143			
Section 5:5	Total Circuit Length	83.82			
Section 5:6	Member count for this circuit	273			
Section 5:7	Date of last circuit trim (VM)	2011/2016			
Section 5:8	List outage causes for circuit along v	vith % of total outage nu	mbers represented by each	cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		32.0%	8.0%	28.0%	

Section 5:9	Circuit 5 year average (SAIDI)	0.847451796	
Section 5:10	Reporting year (SAIDI)	0.98365664	
Section 5:11	Circuit 5 year average (SAIFI)	0.009735956	
Section 5:12	Reporting year (SAIFI)	0.016156325	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit, VM to trim circuit.

Section 5:1	Substation name and Number	Sullivan 85		
Section 5:2	Substation Location	CountyCrittenden	RoadBlackford Ch Rd	TownSturgis
Section 5:3	Circuit Name and Number	Ky Stone Feeder 3		
Section 5:4	Circuit Location	Hwy 60 West		
Section 5:5	Total Circuit Length	60.21		
Section 5:6	Member count for this circuit	231		
Section 5:7	Date of last circuit trim (VM)	2011/2016		
Section 5:8	List outage causes for circuit along v	with % of total outage nur	nbers represented by each	cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		9.1%	18.2%	

Section 5:9	Circuit 5 year average (SAIDI)	0.358982749	
Section 5:10	Reporting year (SAIDI)	0.605281902	
Section 5:11	Circuit 5 year average (SAIFI)	0.006825824	
Section 5:12	Reporting year (SAIFI)	0.015207018	
Section 5:13	List of corrective action, if any, taken or to be taken		

Evaluate & inspection circuit, VM to trim circuit.

ANIMAL

27.3%

18.2%

PUBLIC

UNKNOWN

27.3%

Section 5:1	Substation name and Number	Thruston 11		
Section 5:2	Substation Location	CountyDaviess	RoadHighway 405	Town <b>Owensboro</b>
Section 5:3	Circuit Name and Number	Hwy 405 North Feede	er 1	
Section 5:4	Circuit Location	Hwy 405 North, Saur	Lane	
Section 5:5	Total Circuit Length	19.03		
Section 5:6	Member count for this circuit	154		
Section 5:7	Date of last circuit trim (VM)	2012		
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by ea	ch cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
·		10.00	,	

POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN	
		40.0%			40.0%		20.0%	

•

Section 5:9	Circuit 5 year average (SAIDI)	0.228353717	
Section 5:10	Reporting year (SAIDI)	0.134992619	
Section 5:11	Circuit 5 year average (SAIFI)	0.003077036	
Section 5:12	Reporting year (SAIFI)	0.001573437	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit, VM to trim circuit.

ANIMAL

17.7%

PUBLIC

11.8%

UNKNOWN

11.8%

Section 5:1	Substation name and Number	Thruston 11		
Section 5:2	Substation Location	CountyDaviess	RoadHighway 405	TownOwensboro
Section 5:3	Circuit Name and Number	Wrights Acres Feede	er 2	
Section 5:4	Circuit Location	Hwy 1389, Summit		
Section 5:5	Total Circuit Length	66.9		
Section 5:6	Member count for this circuit	578		
Section 5:7	Date of last circuit trim (VM)	2012		
Section 5:8	List outage causes for circuit along	with % of total outage <u>n</u>	numbers represented by eac	ch cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILUF	RE ROW	WEATHER
[		23.5	% 11.8	% 23.5%
	· · · · · · · · · · · · · · · · · · ·			

Section 5:9	Circuit 5 year average (SAIDI)	1.012723998	
Section 5:10	Reporting year (SAIDI)	0.464429208	
Section 5:11	Circuit 5 year average (SAIFI)	0.010683963	
Section 5:12	Reporting year (SAIFI)	0.003857037	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit, VM to trim circuit.

.

.

••

PUBLIC

14.3%

UNKNOWN

14.3%

ANIMAL

21.4%

Section 5:1	Substation name and Number	Thruston 11			
Section 5:2	Substation Location	CountyDaviess	RoadHighway 405	TownOwensboro	
Section 5:3	Circuit Name and Number	Graham Lane Feeder 3	ł		
Section 5:4	Circuit Location	Graham Lane, Yellow	Creek Park		
Section 5:5	Total Circuit Length	19.14			
Section 5:6	Member count for this circuit	411			
Section 5:7	Date of last circuit trim (VM)	2012			
Section 5:8	List outage causes for circuit along wit	h % of total outage nur	nbers represented by each	cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
	7.2%	21.4%	14.3%	7.1	%

Section 5:9	Circuit 5 year average (SAIDI)	0.456769964	
Section 5:10	Reporting year (SAIDI)	0.796208595	
Section 5:11	Circuit 5 year average (SAIFI)	0.00614311	
Section 5:12	Reporting year (SAIFI)	0.013598218	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit, VM to trim circuit.

.

.

PUBLIC

UNKNOWN

Section 5:1	Substation name and Number	Thruston 11			
Section 5:2	Substation Location	CountyDaviess	RoadHighway 405	TownOwensboro	
Section 5:3	Circuit Name and Number	<b>Thruston Feeder 4</b>			
Section 5:4	Circuit Location	Thruston Playground			
Section 5:5	Total Circuit Length	7.92			
Section 5:6	Member count for this circuit	77			
Section 5:7	Date of last circuit trim (VM)	2012			
Section 5:8	List outage causes for circuit along v	with % of total outage nu	mbers represented by ea	ch cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
		100.0%			
<b></b>					

Section 5:9	Circuit 5 year average (SAIDI)	0.027519824	
Section 5:10	Reporting year (SAIDI)	0.078010848	
Section 5:11	Circuit 5 year average (SAIFI)	0.000542313	
Section 5:12	Reporting year (SAIFI)	0.001568403	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit, VM to trim circuit.

.

PUBLIC

20.0%

UNKNOWN

12.0%

ANIMAL

24.0%

Section 5:1	Substation name and Number	Thruston 11				
Section 5:2	Substation Location	CountyDaviess	RoadHighway 40	05 Town4	Owensboro	
Section 5:3	Circuit Name and Number	Lamplite Estate Fee	der 5			
Section 5:4	Circuit Location	Irene Ave., Iceland I	Road			
Section 5:5	Total Circuit Length	37.62				
Section 5:6	Member count for this circuit	473				
Section 5:7	Date of last circuit trim (VM)	2012				
Section 5:8	List outage causes for circuit along	with % of total outage r	umbers represented	by each cause		
POWER SUPPLY	PLANNED	EQUIPMENT FAILUI	RE ROW		WEATHER	
		24.0	%	8.0%	12.0	%

Section 5:9	Circuit 5 year average (SAIDI)	1.150011759	
Section 5:10	Reporting year (SAIDI)	2.173668794	
Section 5:11	Circuit 5 year average (SAIFI)	0.018035914	
Section 5:12	Reporting year (SAIFI)	0.025090714	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit, VM to trim circuit.

Section 5:1	Substation name and Number	Utica 24		
Section 5:2	Substation Location	CountyDaviess	RoadHwy 140	TownUtica
Section 5:3	Circuit Name and Number	BrownsValley Feeder	1	
Section 5:4	Circuit Location	Hwy 431,Hwy 554		
Section 5:5	Total Circuit Length	62.4 <del>9</del>		
Section 5:6	Member count for this circuit	400		
Section 5:7	Date of last circuit trim (VM)	2012		
Section 5:8	List outage causes for circuit along w	vith % of total outage nu	mbers represented by e	each cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		13.9%	8.3%	6 27.8%

Section 5:9	Circuit 5 year average (SAIDI)	0.602975412	
Section 5:10	Reporting year (SAIDI)	1.738194214	
Section 5:11	Circuit 5 year average (SAIFI)	0.009352407	
Section 5:12	Reporting year (SAIFI)	0.0239361	
Section 5:13	List of corrective action, if any, taken or to be taken E		

.

Evaluate & inspection circuit.

ANIMAL

,

22.2%

PUBLIC

UNKNOWN

27.8%

ANIMAL

,

3.9%

PUBLIC

3.9%

UNKNOWN

7.7%

,

Section 5:1	Substation name and Number	Utica 24			
Section 5:2	Substation Location	CountyDaviess	RoadHwy 140	TownUtica	
Section 5:3	Circuit Name and Number	Red Hill Feeder 2			
Section 5:4	Circuit Location	Hwy 140 E			
Section 5:5	Total Circuit Length	67.58			
Section 5:6	Member count for this circuit	431			
Section 5:7	Date of last circuit trim (VM)	2012	•		
Section 5:8	List outage causes for circuit along with % of total outage numbers represented by each cause				
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		26.9%	11.5%	46.2%	

Section 5:9	Circuit 5 year average (SAIDI)	0.593001566	
Section 5:10	Reporting year (SAIDI)	1.222745831	
Section 5:11	Circuit 5 year average (SAIFI)	0.008819955	
Section 5:12	Reporting year (SAIFI)	0.018485245	
Section 5:13	List of corrective action, if any, taken of	Evaluate & inspection circuit.	

ANIMAL

19.1%

PUBLIC

4.8%

UNKNOWN

23.8%

Section 5:1	Substation name and Number	Utica 24		
Section 5:2	Substation Location	CountyDaviess	RoadHwy 140	Town <b>Utica</b>
Section 5:3	Circuit Name and Number	Locust Grove Road Fe	eder 3	
Section 5:4	Circuit Location	Hwy 431 South, Mill S	Street	
Section 5:5	Total Circuit Length	41.49		
Section 5:6	Member count for this circuit	322		
Section 5:7	Date of last circuit trim (VM)	2013		
Section 5:8	List outage causes for circuit along w	vith % of total outage nu	imbers represented by	each cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	E ROW	WEATHER
		19.1%	4.89	6 28.6%

Section 5:9	Circuit 5 year average (SAIDI)	0.385088581	
Section 5:10	Reporting year (SAIDI)	0.718575941	
Section 5:11	Circuit 5 year average (SAIFI)	0.00656 <u>32</u> 75	
Section 5:12	Reporting year (SAIFI)	0.009291677	
Section 5:13	List of corrective action, if any, taken of	Evaluate & inspection circuit.	

ı

PUBLIC

11.1%

UNKNOWN

11.1%

.

ANIMAL

16.7%

Section 5:1	Substation name and Number	Utica 24			
Section 5:2	Substation Location	CountyDaviess	RoadHwy 140	TownUtica	
Section 5:3	Circuit Name and Number	Utica Feeder 4			
Section 5:4	Circuit Location	Hwy 140 West, Hwy 12	207		
Section 5:5	Total Circuit Length	33.34			
Section 5:6	Member count for this circuit	245			
Section 5:7	Date of last circuit trim (VM)	2013			
Section 5:8	List outage causes for circuit along v	vith % of total outage nur	nbers represented by ea	ich cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		16.7%		44.4%	ſ

Section 5:9	Circuit 5 year average (SAIDI)	0.438516368	
Section 5:10	Reporting year (SAIDI)	0.958207136	
Section 5:11	Circuit 5 year average (SAIFI)	0.006020495	
Section 5:12	Reporting year (SAIFI)	0.010256886	
Section 5:13	List of corrective action, if any, taken or to be taken Evaluate & inspection circuit		

.

PUBLIC

UNKNOWN

Section 5:1	Substation name and Number	Utica 24			
Section 5:2	Substation Location	CountyDaviess	RoadHwy 140	Town <b>Utica</b>	
Section 5:3	Circuit Name and Number	Old Barmet Feeder 5			
Section 5:4	Circuit Location	Hwy 431			
Section 5:5	Total Circuit Length	3.66		4	
Section 5:6	Member count for this circuit	12			
Section 5:7	Date of last circuit trim (VM)	2013			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by	/ each cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
		50.0%		50.	.0%

Section 5:9	Circuit 5 year average (SAIDI)	0.02999785	
Section 5:10	Reporting year (SAIDI)	0.04499351	
Section 5:11	Circuit 5 year average (SAIFI)	0.000238833	
Section 5:12	Reporting year (SAIFI)	0.000267475	
Section 5:13	List of corrective action, if any, taken of	Evaluate & inspection circuit.	

Section 5:4	Circuit Location	Hwy 136,					
Section 5:5	Total Circuit Length	2.21					
Section 5:6	Member count for this circuit	30					
Section 5:7	Date of last circuit trim (VM)	2015					
Section 5:8	List outage causes for circuit along	with % of total outage nun	nbers represented by each	n cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	
						1	

-

Section 5:9	Circuit 5 year average (SAIDI)	0.151482406	
Section 5:10	Reporting year (SAIDI)	0.057803128	
Section 5:11	Circuit 5 year average (SAIFI)	0.001395321	
Section 5:12	Reporting year (SAIFI)	0.000539139	
Section 5:13	List of corrective action, if any, taken o	Evaluate & inspection circuit.	

n

ANIMAL

37.5%

PUBLIC

12.5%

UNKNOWN

4.2%

Section 5:1	Substation name and Number	Weaverton 64		
Section 5:2	Substation Location	CountyHenderson	RoadMadisonville RcT	ownHenderson
Section 5:3	Circuit Name and Number	Hwy 41A South Feede	r 2	
Section 5:4	Circuit Location	Hwy 1299, Cario		
Section 5:5	Total Circuit Length	77.9		
Section 5:6	Member count for this circuit	668		
Section 5:7	Date of last circuit trim (VM)	2015		
Section 5:8	List outage causes for circuit along wit	h % of total outage nu	mbers represented by eac	h cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
	4.2%	12.5%	12.5%	16.7%

Section 5:9	Circuit 5 year average (SAIDI)	2.053879398	
Section 5:10	Reporting year (SAIDI)	1.561861025	
Section 5:11	Circuit 5 year average (SAIFI)	0.024489347	
Section 5:12	Reporting year (SAIFI)		
Section 5:13	List of corrective action, if any, taken o	Evaluate & inspection circuit.	

ANIMAL

.

.

33.3%

PUBLIC

UNKNOWN

33.3%

Section 5:1	Substation name and Number	Weaverton 64		
Section 5:2	Substation Location	CountyHenderson	RoadMadisonville Ro	Town <b>Hend</b> erson
Section 5:3	Circuit Name and Number	Country View Feeder	3	
Section 5:4	Circuit Location	Country View		
Section 5:5	Total Circuit Length	8.92		
Section 5:6	Member count for this circuit	269		
Section 5:7	Date of last circuit trim (VM)	2015		
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by ea	ch cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		33.3%		

Section 5:9	Circuit 5 year average (SAIDI)	0.274358201	
Section 5:10	Reporting year (SAIDI)	0.210284131	
Section 5:11	Circuit 5 year average (SAIFI)	0.003848822	
Section 5:12	Reporting year (SAIFI)	0.002910987	
Section 5:13	List of corrective action, if any, taken of	Evaluate & inspection circuit.	

Section 5:1	Substation name and Number	Weberstown 14						
Section 5:2	Substation Location	CountyHancock	Road <b>SR 69</b>	TownHawesville				
Section 5:3	Circuit Name and Number	South Hancock Eleme	entry Feeder 1					
Section 5:4	Circuit Location	Hwy 144, Hwy 69						
Section 5:5	Total Circuit Length	108.86						
Section 5:6	Member count for this circuit	642				•		
Section 5:7	Date of last circuit trim (VM)	2014						
Section 5:8	List outage causes for circuit along wit	h % of total outage nu	mbers represented by o	each cause		_		
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	÷		PUBLIC	UNKNOWN
	6.4%	23.4%	6	6	14.9%	21.3%	4.3%	17.0%

Section 5:9	Circuit 5 year average (SAIDI)	2.468622483	
Section 5:10	Reporting year (SAIDI)	4.391988168	
Section 5:11	Circuit 5 year average (SAIFI)	0.028335689	
Section 5:12	Reporting year (SAIFI)		
Section 5:13	List of corrective action, if any, taken of	Add more critter guard.	

Section 5:1	Substation name and Number	Weberstown 14						
Section 5:2	Substation Location	CountyHancock	RoadSR 69	TownHawesville				
Section 5:3	Circuit Name and Number	Roseville Feeder 2						*
Section 5:4	Circuit Location	Easton Road, Bates H	ollow Road					
Section 5:5	Total Circuit Length	94.9						
Section 5:6	Member count for this circuit	474						•
Section 5:7	Date of last circuit trim (VM)	2014						
Section 5:8	List outage causes for circuit along wit	h % of total outage nu	mbers represented by (	each cause				
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER		ANIMAL	PUBLIC	UNKNOWN
	2.8%	19.4%	16.7%	6	8.3%	25.0%	8.3%	19.4%
			_					

. .

Section 5:9	Circuit 5 year average (SAIDI)	1.469948305	
Section 5:10	Reporting year (SAIDI)	2.286637873	
Section 5:11	Circuit 5 year average (SAIFI)	0.010194933	
Section 5:12	Reporting year (SAIFI)		
Section 5:13	List of corrective action, if any, taken of	Resolved at time of outage.	

Section 5:1	Substation name and Number	Weberstown 14					
Section 5:2	Substation Location	CountyHancock	Road <b>SR 69</b>	TownHawesville			
Section 5:3	Circuit Name and Number	Pellville Feeder 3					
Section 5:4	Circuit Location	Hwy 144 West, Hwy 7	764				
Section 5:5	Total Circuit Length	86.15					
Section 5:6	Member count for this circuit	536					
Section 5:7	Date of last circuit trim (VM)	2014					
Section 5:8	List outage causes for circuit along w	ith % of total outage nu	mbers represented by	each cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOWN
		25.8%	6 9.7	% 29	9.0% 12.9%	3.2%	19.4%

Section 5:9	Circuit 5 year average (SAIDI)	0.928000144			
Section 5:10	Reporting year (SAIDI)	1.756581364			
Section 5:11	Circuit 5 year average (SAIFI)	0.010211345			
Section 5:12	Reporting year (SAIFI)	0.019344353			
Section 5:13	List of corrective action, if any, taken or to be taken				

Resolved at time of outage.

٠

ANIMAL

/

9.1%

PUBLIC

18.2%

UNKNOWN

9.1%

Section 5:2       Substation Location       CountyDaviess       RoadOld Lyddane Br       TownOwensboro         Section 5:3       Circuit Name and Number       Meadowlark Drive Feeder 1       Meadowlark Drive         Section 5:4       Circuit Location       Medowlark Drive       Meadowlark Drive         Section 5:5       Total Circuit Length       3.34       Section 5:6       Member count for this circuit       6         Section 5:7       Date of last circuit trim (VM)       2014       Section 5:8       List outage causes for circuit along with % of total outage numbers represented by each cause         POWER SUPPLY       PLANNED       EQUIPMENT FAILURE       ROW       WEATHER         9 1%       27.3%       27.3%       27.3%	Section 5:1	Substation name and Number	West Owensboro 22			
Section 5:4       Circuit Location       Medowlark Drive         Section 5:5       Total Circuit Length       3.34         Section 5:6       Member count for this circuit       6         Section 5:7       Date of last circuit trim (VM)       2014         Section 5:8       List outage causes for circuit along with % of total outage numbers represented by each cause         POWER SUPPLY       PLANNED       EQUIPMENT FAILURE       ROW       WEATHER	Section 5:2	Substation Location	CountyDaviess	RoadOld Lyddane Br	TownOwensboro	
Section 5:5       Total Circuit Length       3.34         Section 5:6       Member count for this circuit       6         Section 5:7       Date of last circuit trim (VM)       2014         Section 5:8       List outage causes for circuit along with % of total outage numbers represented by each cause         POWER SUPPLY       PLANNED       EQUIPMENT FAILURE       ROW       WEATHER	Section 5:3	Circuit Name and Number	Meadowlark Drive Fee	eder 1		
Section 5:6       Member count for this circuit       6         Section 5:7       Date of last circuit trim (VM)       2014         Section 5:8       List outage causes for circuit along with % of total outage numbers represented by each cause       WEATHER         POWER SUPPLY       PLANNED       EQUIPMENT FAILURE       ROW       WEATHER	Section 5:4	Circuit Location	Medowlark Drive			
Section 5:7       Date of last circuit trim (VM)       2014         Section 5:8       List outage causes for circuit along with % of total outage numbers represented by each cause         POWER SUPPLY       PLANNED       EQUIPMENT FAILURE       ROW       WEATHER	Section 5:5	Total Circuit Length	3.34			
Section 5:8         List outage causes for circuit along with % of total outage numbers represented by each cause           POWER SUPPLY         PLANNED         EQUIPMENT FAILURE         ROW         WEATHER	Section 5:6	Member count for this circuit	6			
POWER SUPPLY PLANNED EQUIPMENT FAILURE ROW WEATHER	Section 5:7	Date of last circuit trim (VM)	2014			
	Section 5:8	List outage causes for circuit along wit	h % of total outage nur	nbers represented by eacl	n cause	
9 1% 27.3% 27.3%	POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
		9.1%	27.3%		27.3%	

Section 5:9	Circuit 5 year average (SAIDI)	0.00316562	
Section 5:10	Reporting year (SAIDI)	0.006706999	
Section 5:11	Circuit 5 year average (SAIFI)	6.11941E-05	
Section 5:12	Reporting year (SAIFI)		
Section 5:13	List of corrective action, if any, taken of	Evaluate & inspection circuit.	

ANIMAL

11.1%

1

PUBLIC

16.7%

UNKNOWN

11.1%

Section 5:1	Substation name and Number	West Owensboro 22			
Section 5:2	Substation Location	CountyDaviess	RoadOld Lyddane Br	TownOwensboro	
Section 5:3	Circuit Name and Number	Airport Feeder 2			
Section 5:4	Circuit Location	Bittle Rd., Boatman			
Section 5:5	Total Circuit Length	11.04			
Section 5:6	Member count for this circuit	118			
Section 5:7	Date of last circuit trim (VM)	2015			
Section 5:8	List outage causes for circuit along with % of total outage numbers represented by each cause				
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
	11.1%	11.1%	11.1%	27.8%	

Section 5:9	Circuit 5 year average (SAIDI)	0.073784095	
Section 5:10	Reporting year (SAIDI)	0.152009229	
Section 5:11-	Circuit 5 year average (SAIFI)	0.00092295	
Section 5:12	Reporting year (SAIFI)	0.001396874	
Section 5:13	List of corrective action, if any, taken o	Evaluate & inspection circuit.	

ANIMAL

.

.

PUBLIC

UNKNOWN

Section 5:1	Substation name and Number	West Owensboro 22			
Section 5:2	Substation Location	CountyDaviess	RoadOld Lyddane Br	TownOwensboro	
Section 5:3	Circuit Name and Number	Hwy 81 South Feeder	3		
Section 5:4	Circuit Location	Wayne Bridge Road			
Section 5:5	Total Circuit Length	66.33			
Section 5:6	Member count for this circuit	660			
Section 5:7	Date of last circuit trim (VM)	2015			
Section 5:8	List outage causes for circuit along w	ith % of total outage nu	imbers represented by eac	h cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	
					-

Section 5:9	Circuit 5 year average (SAIDI)	1.026806197	]
Section 5:10	Reporting year (SAIDI)	0.725567882	
Section 5:11	Circuit 5 year average (SAIFI)	0.030242013	
Section 5:12	Reporting year (SAIFI)	0.029720865	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circ

PUBLIC

UNKNOWN

Section 5:1	Substation name and Number	West Owensboro 22			
Section 5:2	Substation Location	CountyDaviess	Road <b>Old Lyddane Br</b>	TownOwensboro	
Section 5:3	Circuit Name and Number	Lyddane Br Rd Feeder	• 4		
Section 5:4	Circuit Location	Hwy 279, Pruden Land	2		
Section 5:5	Total Circuit Length	24.76			
Section 5:6	Member count for this circuit	148			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by eac	h cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL

Section 5:9	Circuit 5 year average (SAIDI)	0.38121984	
Section 5:10	Reporting year (SAIDI)	0.462859977	
Section 5:11	Circuit 5 year average (SAIFI)	0.004210936	
Section 5:12	Reporting year (SAIFI)	0.005995557	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit.

/

PUBLIC

•

UNKNOWN

Section 5:1	Substation name and Number	West Owensboro 22			•
Section 5:2	Substation Location	CountyDaviess	RoadOld Lyddane Br	TownOwensboro	
Section 5:3	Circuit Name and Number	Hwy 56/Sorgho			
Section 5:4	Circuit Location	Woodlawn Subdivisio	n		
Section 5:5	Total Circuit Length	48.34			
Section 5:6	Member count for this circuit	682			
Section 5:7	Date of last circuit trim (VM)	2014			
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by eac	h cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL

Section 5:9	Circuit 5 year average (SAIDI)	0.877165145	
Section 5:10	Reporting year (SAIDI)	0.237201446	
Section 5:11	Circuit 5 year average (SAIFI)	0.01653543	
Section 5:12	Reporting year (SAIFI)	0.002679732	
Section 5:13	List of corrective action, if any, taken o	or to be taken	Evaluate & inspection

.

.

PUBLIC

UNKNOWN

10.0%

Section 5:1	Substation name and Number	Whitesville 15					
Section 5:2	Substation Location	CountyDaviess	RoadHwy 764	TownWhiteswville			
Section 5:3	Circuit Name and Number	Hwy 54 West Feeder :	1				
Section 5:4	Circuit Location	Haynes Station Road					
Section 5:5	Total Circuit Length	28.58					
Section 5:6	Member count for this circuit	236					
Section 5:7	Date of last circuit trim (VM)	2012					
Section 5:8	List outage causes for circuit along v	vith % of total outage nu	mbers represented by eac	h cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER		ANIMAL	
			70.0%	6 1	0.0%	10.0%	ĺ
-							

Section 5:9	Circuit 5 year average (SAIDI)	0.192444929	
Section 5:10	Reporting year (SAIDI)	0.633460805	
Section 5:11	Circuit 5 year average (SAIFI)	0.00251766	
Section 5:12	Reporting year (SAIFI)	0.007304083	
Section 5:13	List of corrective action, if any, taken of	VM to trim circuit	

.

-

PUBLIC

UNKNOWN

Section 5:1	Substation name and Number	Whitesville 15			
Section 5:2	Substation Location	CountyDaviess	RoadHwy 764	TownWhiteswville	
Section 5:3	Circuit Name and Number	Whitesville Feeder 2			
Section 5:4	Circuit Location	Hwy 764 North, Old L	eitchfield Road		
Section 5:5	Total Circuit Length	69.56			
Section 5:6	Member count for this circuit	731			
Section 5:7	Date of last circuit trim (VM)	2012			
Section 5:8	List outage causes for circuit along v	vith % of total outage nu	mbers represented by eacl	h cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
		20.0%	b 20.0%	30.0%	<u> </u>
					_

.

Section 5:9	Circuit 5 year average (SAIDI)	0.892923408	
Section 5:10	Reporting year (SAIDI)	1.194499296	
Section 5:11	Circuit 5 year average (SAIFI)	0.014694642	
Section 5:12	Reporting year (SAIFI)	0.012774598	
Section 5:13	List of corrective action, if any, taken of	VM to trim circuit	

PUBLIC

.

25.0%

UNKNOWN

18.8%

~

Section 5:1	Substation name and Number	Whitesville 15			
Section 5:2	Substation Location	CountyDaviess	RoadHwy 764	TownWhiteswville	
Section 5:3	Circuit Name and Number	Ralph Feeder 3			
Section 5:4	Circuit Location	Magan, Narrows			
Section 5:5	Total Circuit Length	111.54			
Section 5:6	Member count for this circuit	568			
Section 5:7	Date of last circuit trim (VM)	2012			
Section 5:8	List outage causes for circuit along v	vith % of total outage nu	mbers represented by eac	h cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANÍMAL
		18.8%	15.6%	6 21.9	% 25.0

.

. . .

Section 5:9	Circuit 5 year average (SAIDI)	2.220868441	
Section 5:10	Reporting year (SAIDI)	2.823712561	
Section 5:11	Circuit 5 year average (SAIFI)	0.027417921	
Section 5:12	Reporting year (SAIFI)	0.024245068	
Section 5:13	List of corrective action, if any, taken of	VM to trim circuit	

.

. .

PUBLIC

14.3%

UNKNOWN

14.3%

Section 5:1	Substation name and Number	Whitesville 15			
Section 5:2	Substation Location	CountyDaviess	RoadHwy 764	TownWhiteswville	
Section 5:3	Circuit Name and Number	Stevens School Road F	eeder 4		
Section 5:4	Circuit Location	Deserter Creek Road			
Section 5:5	Total Circuit Length	55.5 <del>9</del>			
Section 5:6	Member count for this circuit	316			
Section 5:7	Date of last circuit trim (VM)	2012			
Section 5:8	List outage causes for circuit along wi	th % of total outage nur	mbers represented by each	cause	
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
		50.0%	-	21.4%	

Section 5:9	Circuit 5 year average (SAIDI)	0.284239506	
Section 5:10	Reporting year (SAIDI)	0.122019156	
Section 5:11	Circuit 5 year average (SAIFI)	0.004235272	
Section 5:12	Reporting year (SAIFI)	0.001837118	
Section 5:13	List of corrective action, if any, taken or to be taken VM to trim circuit		

No Outages 2015							
Section 5:1	Substation name and Number	Wolf Hills 91					
Section 5:2	Substation Location	CountyHenderson	RoadWathen Road	TownHenderson			
Section 5:3	Circuit Name and Number	WFIE Feeder 1					
Section 5:4	Circuit Location	WFIE					
Section 5:5	Total Circuit Length	1.38					
Section 5:6	Member count for this circuit	5					
Section 5:7	Date of last circuit trim (VM)	2014					
Section 5:8	List outage causes for circuit along	with % of total outage nu	mbers represented by ea	ch cause			
POWER SUPPL	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOW

Section 5:9	Circuit 5 year average (SAIDI)	0.0000	
Section 5:10	Reporting year (SAIDI)	0.0000	
Section 5:11	Circuit 5 year average (SAIFI)	0.0000	
Section 5:12	Reporting year (SAIFI)	0.0000	
Section 5:13	List of corrective action, if any, taken or to be taken		

-

PUBLIC

UNKNOWN

-

Section 5:1 Substation name and Number	Wolf Hills 91			
Section 5:2 Substation Location	CountyHenderson	RoadWathen Road	TownHenderson	
Section 5:3 Circuit Name and Number	Wathem Lane Feeder	3		
Section 5:4 Circuit Location	Melody Lane			
Section 5:5 Total Circuit Length	21.61			
Section 5:6 Member count for this circuit	283			
Section 5:7 Date of last circuit trim (VM)	2013			
Section 5:8 List outage causes for circuit along wi	th <u>% of total outage nu</u>	mbers represented by eac	h cause	<u> </u>
POWER SUPPLY PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL
			100.0%	

Section 5:9	Circuit 5 year average (SAIDI)	0.246878047	
Section 5:10	Reporting year (SAIDI)	0.07636584	
Section 5:11	Circuit 5 year average (SAIFI)	0.002401025	
Section 5:12	Reporting year (SAIFI)	0.000750892	,
Section 5:13	List of corrective action, if any, taken of	Resolved at time of outage	

ANIMAL

.

12.5%

PUBLIC

UNKNOWN

Section 5:1	Substation name and Number	Wolf Hills 91		
Section 5:2	Substation Location	CountyHenderson	RoadWathen Road	TownHenderson
Section 5:3	Circuit Name and Number	Ellis Park Feeder 4		
Section 5:4	Circuit Location	Rivber Camps, Ellis Pa	ırk	
Section 5:5	Total Circuit Length	22,03		
Section 5:6	Member count for this circuit	159		
Section 5:7	Date of last circuit trim (VM)	2013		
Section 5:8	List outage causes for circuit along v	with % of total outage nu	mbers represented by each	h cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
		12.5%		75.00%

Section 5:9	Circuit 5 year average (SAIDI)	0.953992862	
Section 5:10	Reporting year (SAIDI)	1.705576625	
Section 5:11	Circuit 5 year average (SAIFI)	0.01009035	
Section 5:12	Reporting year (SAIFI)		
Section 5:13	List of corrective action, if any, taken of	Resolved at time of outage.	

.

-

No Outages 2015							
Section 5:1	Substation name and Number	Yager Material 10					
Section 5:2	Substation Location	CountyHancock	RoadRiver Road	Town Hawesville			
Section 5:3	Circuit Name and Number	Yager Feeder 1					
Section 5:4	Circuit Location	Yager Material, West	Yager Material, Western Ky Energy				
Section 5:5	Total Circuit Length	1.46					
Section 5:6	Member count for this circuit	3					
Section 5:7	Date of last circuit trim (VM)	2012					
Section 5:8	List outage causes for circuit along with % of total outage numbers represented by each cause						
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER	ANIMAL	PUBLIC	UNKNOW

Section 5:9	Circuit 5 year average (SAIDI)	0.0000	
Section 5:10	Reporting year (SAIDI)	0.0000	
Section 5:11	Circuit 5 year average (SAIFI)	0.0000	
Section 5:12	Reporting year (SAIFI)	0.0000	
Section 5:13	List of corrective action, if any, taken or to be taken		

ANIMAL

25.0%

PUBLIC

UNKNOWN

Section 5:1	Substation name and Number	Zion 90		
Section 5:2	Substation Location	CountyHenderson	Road Hwy 1078	TownZion
Section 5:3	Circuit Name and Number	Hwy 1078 N Feeder 1		
Section 5:4	Circuit Location	Hwy 1078		
Section 5:5	Total Circuit Length	16. <b>08</b>		
Section 5:6	Member count for this circuit	216		
Section 5:7	Date of last circuit trim (VM)	2011/2016		
Section 5:8	List outage causes for circuit along wit	h % of total outage numb	pers represented by eacl	n cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
8%		8.3%	25.0%	33.3%

.

Section 5:9	Circuit 5 year average (SAIDI)	0.177897557	
Section 5:10	Reporting year (SAIDI)	0.459568117	
Section 5:11	Circuit 5 year average (SAIFI)	0.002181471	
Section 5:12	Reporting year (SAIFI)	0.005595476	
Section 5:13	List of corrective action, if any, taken or to be taken		Evaluate & inspection circuit, VM to trim circuit.

.

.

PUBLIC

6.3%

UNKNOWN

37.5%

.

ANIMAL

6.3%

Section 5:1	Substation name and Number	Zion 90		
Section 5:2	Substation Location	CountyHenderson	Road Hwy 1078	Town <b>Zion</b>
Section 5:3	Circuit Name and Number	Beals/Reed Feeder 2		
Section 5:4	Circuit Location	Old Hwy 60, Reed		
Section 5:5	Total Circuit Length	77.72		
Section 5:6	Member count for this circuit	544		
Section 5:7	Date of last circuit trim (VM)	2011/2016		
Section 5:8	List outage causes for circuit along with % of total outage numbers represented by each cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	' WEATHER
6%		12.5%	18.8%	12.5%

Section 5:9	Circuit 5 year average (SAIDI)	1.073143684	
Section 5:10	Reporting year (SAIDI)	0.390899057	
Section 5:11	Circuit 5 year average (SAIFI)	0.012476467	
Section 5:12	Reporting year (SAIFI)	0.01578882	
Section 5:13	List of corrective action, if any, taken or to be taken		Evaluate & inspection circuit, VM to trim circuit.

PUBLIC

8.7%

ANIMAL

26.1%

UNKNOWN

21.7%

Section 5:1	Substation name and Number	Zion 90		
Section 5:2	Substation Location	CountyHenderson	Road Hwy 1078	TownZion
Section 5:3	Circuit Name and Number	Hebbardsville Feeder 3		
Section 5:4	Circuit Location	Hwy 351, Hwy 416		
Section 5:5	Total Circuit Length	91.97		
Section 5:6	Member count for this circuit	639		
Section 5:7	Date of last circuit trim (VM)	2011/2016		
Section 5:8	List outage causes for circuit along	with % of total outage numb	ers represented by eacl	n cause
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
4%		13.0%	8.7%	17.4%

Section 5:9	Circuit 5 year average (SAIDI)	0.391303715	
Section 5:10	Reporting year (SAIDI)	0.32512656	
Section 5:11	Circuit 5 year average (SAIFI)	0.004053211	
Section 5:12	Reporting year (SAIFI)	0.00579281	
Section 5:13	List of corrective action, if any, taken or to be taken		Evaluate & inspection circuit, VM to trim circuit.

,

Section 5:1	Substation name and Number	Zion 90		
Section 5:2	Substation Location	CountyHenderson	RoadHwy 1078 N	Town <b>Zion</b>
Section 5:3	Circuit Name and Number	Galloway Corner Feed	er 4	
Section 5:4	Circuit Location	Airline Rd.		
Section 5:5	Total Circuit Length	25.27		
Section 5:6	Member count for this circuit	223		
Section 5:7	Date of last circuit trim (VM)	2011/2016		
Section 5:8	List outage causes for circuit along with % of total outage numbers represented by each cause			
POWER SUPPLY	PLANNED	EQUIPMENT FAILURE	ROW	WEATHER
14.29%		14.29%		28.57%

Section 5:9	Circuit 5 year average (SAIDI)	1.073143684	
Section 5:10	Reporting year (SAIDI)	0.390899057	
Section 5:11	Circuit 5 year average (SAIFI)	0.012476467	
Section 5:12	Reporting year (SAIFI)	0.01578882	
Section 5:13	List of corrective action, if any, taken of	or to be taken	Evaluate & inspection circuit, VM to tr

trim circuit.

-----

ANIMAL

28.57%

PUBLIC

UNKNOWN

14.29%