

RECEIVED

APR 30 2020

PUBLIC SERVICE COMMISSION

A Touchstone Energy® Cooperative

April 15, 2020

Mr. Kent Chandler
Public Service Commission
P.O. Box 615
211 Sower Boulevard
Frankfort, Kentucky 40602-0615

RE: Administrative Case No. 2011-00450: Annual Distribution Reliability Report

Dear Mr. Chandler:

Please find enclosed a paper copy of the 2019 electric distribution utility annual reliability report for Nolin RECC, as well as a copy of Nolin RECC's vegetation management program.

If you have any questions regarding the enclosed information, please contact me at (270) 765-6153 ext 3383 or dwoosley@nolinrecc.com.

Regards,

Devon C. Woosley

Manager - Engineering

Devon C. Wootley

Nolin Rural Electric Cooperative Corporation

Enclosures

Kentucky Public Service Commission Electric Distribution Utility Annual Reliability Report

SECTION 1: CONTACT INFORMATION

UTILITY NAME:	Nolin RECC
REPORT PREPARED BY:	Jordan Horsley
E-MAIL ADDRESS OF PREPARER:	jhorsley@nolinrecc.com
PHONE NUMBER OF PREPARER:	(270) 765-6153 Ext: 3304
SECTION SECTIO	ON 2: REPORTING YEAR 2019
CALENDAR YEAR OF REPORT:	2019
SECTION 3:	MAJOR EVENT DAYS (MED)
TMED:	6.47
FIRST DATE USED TO DETERMINE TMED:	1/1/2014
LAST DATE USED TO DETERMINE TMED:	12/31/2018
NUMBER OF MED IN REPORT YEAR:	0

NOTE: Per IEEE TMED should be calculated using the daily SAIDI values for the five prior years. If five years of data are not available, then utilities should use what is available until five years accumulated.

SECTION 4: SYSTEM RELIABILITY INFORMATION AND RESULTS

System-wide Information

TOTAL CUSTOMERS: 35,685 TOTAL CIRCUITS: 84

Excluding MED

5-YEAR AVERAGE (2014 - 2018) REPORTING YEAR

 SAIDI:
 81.012
 SAIDI:
 63.803

 SAIFI:
 0.896
 SAIFI:
 0.996

Including MED

5-YEAR AVERAGE (2014 - 2018) REPORTING YEAR

 SAIDI:
 122.189
 SAIDI:
 63.803

 SAIFI:
 1.082
 SAIFI:
 0.996

Notes:

- 1) All duration indices (SAIDI) are to be reported in units of minutes.
- 2) Reports are due on the first business day of May of each year.
- 3) Reports cover the calendar year ending in the December before the reports are due.
- 4) IEEE 1366 (latest version) is used to define SAIDI, SAIFI, and TMED.

CIRCUIT #1:	COLESBURG - 2
1. SUBSTATION NAME AND NUMBER:	COLESBURG (1)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - HALL & BARDSTOWN RD YOUNGER CREEK
3. CIRCUIT NAME AND NUMBER:	COLESBURG - 2
4. CIRCUIT LOCATION	ELIZABETHTOWN, KY - BARDSTOWN RD, MOUNTAIN VIEW ESTATES
(TOWN-ROAD-GENERAL AREA):	RD
5. TOTAL CIRCUIT LENGTH (MILES):	23.18
6. CUSTOMER COUNT FOR THIS CIRCUIT:	458
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	09/16
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	4.57% SMALL ANIMALS OR BIRDS 3.89% 1.54% TREES 27.10% 0.11% WIND, HIGH WIND 0.85% 2.56% WEATHER 59.38%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	36.46
10. REPORTING YEAR (SAIDI):	115.77
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.36
12. REPORTING YEAR (SAIFI):	0.67
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Review sectionalizing on feeder to minimize number of customers impacted by equipment operations.

CIRCUIT #2:	COLESBURG - 4
1. SUBSTATION NAME AND NUMBER:	COLESBURG (1)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - HALL & BARDSTOWN RD YOUNGER CREEK
3. CIRCUIT NAME AND NUMBER:	COLESBURG - 4
4. CIRCUIT LOCATION	ELIZABETHTOWN, KY - LOWER COLESBURG RD, BATTLE TRAINING
(TOWN-ROAD-GENERAL AREA):	RD, HAPPY HOLLOW RD
5. TOTAL CIRCUIT LENGTH (MILES):	27.57
6. CUSTOMER COUNT FOR THIS CIRCUIT:	199
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	10/16
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	28.46% SMALL ANIMALS OR BIRDS 0.00% 13.20% TREES 4.54% 0.98% WIND, HIGH WIND 52.30% 0.52% WEATHER 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	79.73
10. REPORTING YEAR (SAIDI):	246.99
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.84
12. REPORTING YEAR (SAIFI):	2.81
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Feeder inspection will identify areas to mitigate wind caused outages.

CIRCUIT #3:	ETOWN 1 - 5
1. SUBSTATION NAME AND NUMBER:	ETOWN 1 (2)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - WOODLAND DR E-TOWN
3. CIRCUIT NAME AND NUMBER:	ETOWN 1 - 5
4. CIRCUIT LOCATION	ELIZABETHTOWN, KY - BYPASS, BANKVIEW RD, DIXIE RD, FREEMAN
(TOWN-ROAD-GENERAL AREA):	LAKE PARK RD
5. TOTAL CIRCUIT LENGTH (MILES):	11.61
6. CUSTOMER COUNT FOR THIS CIRCUIT:	567
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	08/16
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	0.54% SMALL ANIMALS OR BIRDS 0.00% 0.00% TREES 18.32% 8.12% WIND, HIGH WIND 0.00% 72.62% WEATHER 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	94.38
10. REPORTING YEAR (SAIDI):	38.92
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.89
12. REPORTING YEAR (SAIFI):	1.14
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	

CIRCUIT #4:	GLENDALE - 1
1. SUBSTATION NAME AND NUMBER: 2. SUBSTATION LOCATION	GLENDALE (3)
(COUNTY-ROAD-TOWN):	HARDIN - E. GLENDALE HODGENVILLE RD - GLENDALE
3. CIRCUIT NAME AND NUMBER:	GLENDALE - 1
4. CIRCUIT LOCATION	GLENDALE, KY - W GLENDALE HODGENVILLE RD, MUD SPLASH RD,
(TOWN-ROAD-GENERAL AREA):	ANDOVER RD
5. TOTAL CIRCUIT LENGTH (MILES):	9.58
6. CUSTOMER COUNT FOR THIS CIRCUIT:	193
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	11/14
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	37.41
10. REPORTING YEAR (SAIDI):	33.42
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.88
12. REPORTING YEAR (SAIFI):	1.12
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Nolin RECC to work with EKPC to review remedies for transmission/substation reliability issues.

CIRCUIT #5:	GLENDALE - 2
1. SUBSTATION NAME AND NUMBER:	GLENDALE (3)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - E. GLENDALE HODGENVILLE RD - GLENDALE
3. CIRCUIT NAME AND NUMBER:	GLENDALE - 2
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	GLENDALE, KY - SPORTSMAN LAKE RD, OVERALL PHILLIPS RD
5. TOTAL CIRCUIT LENGTH (MILES):	43.34
6. CUSTOMER COUNT FOR THIS CIRCUIT:	861
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	11/14
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	49.87% SMALL ANIMALS OR BIRDS 7.47% 1.23% TREES 17.29% 11.03% WIND, HIGH WIND 0.10% 5.83% WEATHER 0.08%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	93.16
10. REPORTING YEAR (SAIDI):	93.44
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	1.88
12. REPORTING YEAR (SAIFI):	1.79
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Feeder inspection to identify equipment for maintenance.

CIRCUIT #6:	GLENDALE - 4
1. SUBSTATION NAME AND NUMBER:	GLENDALE (3)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - E. GLENDALE HODGENVILLE RD - GLENDALE
3. CIRCUIT NAME AND NUMBER:	GLENDALE - 4
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	GLENDALE, KY - ROUNDTOP RD, LINCOLN PKWY
5. TOTAL CIRCUIT LENGTH (MILES):	40.33
6. CUSTOMER COUNT FOR THIS CIRCUIT:	281
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	02/15
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	1.96% SMALL ANIMALS OR BIRDS 0.00% 63.77% TREES 0.00% 0.00% WIND, HIGH WIND 0.00% 2.47% WEATHER 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	54.81
10. REPORTING YEAR (SAIDI):	22.99
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.91
12. REPORTING YEAR (SAIFI):	1.19
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Identify new surge arrestor placement opportunities. Review overvoltage protection.

CIRCUIT #7:	GLENDALE - 5
1. SUBSTATION NAME AND NUMBER:	GLENDALE (3)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - E. GLENDALE HODGENVILLE RD - GLENDALE
3. CIRCUIT NAME AND NUMBER:	GLENDALE - 5
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	SONORA, KY - HWY 31 W (SOUTH), NOLIN RD, SONORA NOLIN RD
5. TOTAL CIRCUIT LENGTH (MILES):	28.70
6. CUSTOMER COUNT FOR THIS CIRCUIT:	195
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	01/15
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	6.02% SMALL ANIMALS OR BIRDS 0.00% 1.32% TREES 0.50% 5.67% WIND, HIGH WIND 0.00% 2.85% WEATHER 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	91.57
10. REPORTING YEAR (SAIDI):	104.57
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	1.17
12. REPORTING YEAR (SAIFI):	1.21
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Nolin RECC to work with EKPC to review remedies for transmission/substation reliability issues.

CIRCUIT #8:	HODGENVILLE - 4
1. SUBSTATION NAME AND NUMBER:	HODGENVILLE (4)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	LARUE - HWY 31E (NEAR WADDELL RD)- HODGENVILLE
3. CIRCUIT NAME AND NUMBER:	HODGENVILLE - 4
4. CIRCUIT LOCATION	HODGENVILLE, KY - OLD ELIZABETHTOWN RD, CARTER BROTHERS
(TOWN-ROAD-GENERAL AREA):	RD
5. TOTAL CIRCUIT LENGTH (MILES):	31.96
6. CUSTOMER COUNT FOR THIS CIRCUIT:	477
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	01/13
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	11.93% SMALL ANIMALS OR BIRDS 0.00% 0.00% TREES 0.00% 0.00% WIND, HIGH WIND 0.00% 19.48% WEATHER 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	22.96
10. REPORTING YEAR (SAIDI):	11.48
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.30
12. REPORTING YEAR (SAIFI):	1.11
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Nolin RECC to work with EKPC to review remedies for transmission/substation reliability issues.

CIRCUIT #9:	MAGNOLIA - 2
1. SUBSTATION NAME AND NUMBER:	MAGNOLIA (5)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	LARUE - NEW JACKSON HWY - MAGNOLIA
3. CIRCUIT NAME AND NUMBER:	MAGNOLIA - 2
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	SHERMAN, KY - MT SHERMAN RD, JACKSON RD
5. TOTAL CIRCUIT LENGTH (MILES):	25.75
6. CUSTOMER COUNT FOR THIS CIRCUIT:	168
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	09/15
8. LIST OF OUTAGE(S): CONTRACTOR	OUTAGE MINUTES (% OF TOTAL OUTAGE MINUTES): O.00% PUBLIC ACCIDENTS, OTHER 0.00%
EQUIPMENT / MATERIAL FAILURE	
LIGHTNING	
NO CAUSE CODE	
PLANNED OUTAGE	
POWER SUPPLIER	
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	36.15
10. REPORTING YEAR (SAIDI):	39.28
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.40
12. REPORTING YEAR (SAIFI):	1.07
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Review ROW conditions and vegetation management cycle.

CIRCUIT #10:	MAGNOLIA - 4
1. SUBSTATION NAME AND NUMBER:	MAGNOLIA (5)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	LARUE - NEW JACKSON HWY - MAGNOLIA
3. CIRCUIT NAME AND NUMBER:	MAGNOLIA - 4
4. CIRCUIT LOCATION	TANNER, KY - OAK HILL RD, NEW JACKSON HWY, HAWKINS RD,
(TOWN-ROAD-GENERAL AREA):	SONORA RD, SIBERIA RD, MURRIELTOWN RD
5. TOTAL CIRCUIT LENGTH (MILES):	77.35
6. CUSTOMER COUNT FOR THIS CIRCUIT:	503
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	08/15
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	11.34% TREES 20.12% 0.02% WIND, HIGH WIND 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	65.31
10. REPORTING YEAR (SAIDI):	89.11
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	1.07
12. REPORTING YEAR (SAIFI):	2.56
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Feeder inspection to identify equipment for maintenance.

CIRCUIT #11:	STEPHENSBURG - 1
1. SUBSTATION NAME AND NUMBER:	STEPHENSBURG (6)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN-LEITCHFIELD RD-STEPHENSBURG
3. CIRCUIT NAME AND NUMBER:	STEPHENSBURG - 1
4. CIRCUIT LOCATION	GLENDALE, KY - STAR MILLS EASTVIEW RD, BACON CREEK RD, HWY
(TOWN-ROAD-GENERAL AREA):	222, CECILIA SMITH MILL RD, PARTRIDGE WAY
5. TOTAL CIRCUIT LENGTH (MILES):	41.45
6. CUSTOMER COUNT FOR THIS CIRCUIT:	464
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	04/19
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	OUTAGE MINUTES (% OF TOTAL OUTAGE MINUTES): 0.00% PUBLIC ACCIDENTS, OTHER 2.56% 0.46% SMALL ANIMALS OR BIRDS 0.00% 0.00% TREES 17.12% 45.35% WIND, HIGH WIND 19.97% 12.12% WEATHER 0.00% 2.41%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	123.11
10. REPORTING YEAR (SAIDI):	124.82
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	1.19
12. REPORTING YEAR (SAIFI):	2.21
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Feeder inspection will identify areas for correction.

CIRCUIT #12:	STEPHENSBURG - 3
1. SUBSTATION NAME AND NUMBER: 2. SUBSTATION LOCATION	STEPHENSBURG (6) HARDIN-LEITCHFIELD RD-STEPHENSBURG
(COUNTY-ROAD-TOWN):	
3. CIRCUIT NAME AND NUMBER:	STEPHENSBURG - 3
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	STEPHENSBERG, KY - LEITCHFIELD RD, SONORA HARDIN SPRINGS RD, WEBB MILLS RD
5. TOTAL CIRCUIT LENGTH (MILES):	71.76
6. CUSTOMER COUNT FOR THIS CIRCUIT:	544
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	03/19
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	0.36% SMALL ANIMALS OR BIRDS 4.66% 0.14% TREES 67.41% 7.30% WIND, HIGH WIND 0.00% 20.12% WEATHER 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	101.85
10. REPORTING YEAR (SAIDI):	210.45
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	1.22
12. REPORTING YEAR (SAIFI):	1.22
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Review ROW conditions and vegetation management cycle.

CIRCUIT #13:	STEPHENSBURG - 4
1. SUBSTATION NAME AND NUMBER:	STEPHENSBURG (6)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN-LEITCHFIELD RD-STEPHENSBURG
3. CIRCUIT NAME AND NUMBER:	STEPHENSBURG - 4
4. CIRCUIT LOCATION	EASTVIEW, KY -EASTVIEW RD, MEETING CREEK RD, SONORA
(TOWN-ROAD-GENERAL AREA):	HARDIN SPRINGS RD
5. TOTAL CIRCUIT LENGTH (MILES):	75.47
6. CUSTOMER COUNT FOR THIS CIRCUIT:	576
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	02/19
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	OUTAGE MINUTES (% OF TOTAL OUTAGE MINUTES): 0.00% PUBLIC ACCIDENTS, OTHER 0.03% 10.54% SMALL ANIMALS OR BIRDS 62.47% 2.05% TREES 7.07% 11.64% WIND, HIGH WIND 1.62% 4.58% WEATHER 0.00% 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	113.51
10. REPORTING YEAR (SAIDI):	92.40
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	1.10
12. REPORTING YEAR (SAIFI):	1.30
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Feeder inspection will identify areas to mitigate animal caused outages.

CIRCUIT #14:	UPTON - 1
1. SUBSTATION NAME AND NUMBER:	UPTON (7)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - MILERSTOWN RD UPTON
3. CIRCUIT NAME AND NUMBER:	UPTON - 1
4. CIRCUIT LOCATION	UPTON, KY - MILLERSTOWN RD, PLEASANT HILL RD, GEORGE TABB
(TOWN-ROAD-GENERAL AREA):	RD, UPTON RD, FLINT HILL RD, HORSESHOE BEND RD
5. TOTAL CIRCUIT LENGTH (MILES):	66.24
6. CUSTOMER COUNT FOR THIS CIRCUIT:	483
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	08/15
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	0.79% SMALL ANIMALS OR BIRDS 0.00% 0.89% TREES 2.01% 11.04% WIND, HIGH WIND 18.30% 18.07% WEATHER 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	49.60
10. REPORTING YEAR (SAIDI):	87.91
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.69
12. REPORTING YEAR (SAIFI):	1.94
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Nolin RECC to work with EKPC to review remedies for transmission/substation reliability issues.

CIRCUIT #15:	UPTON - 2
1. SUBSTATION NAME AND NUMBER:	UPTON (7)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - MILERSTOWN RD UPTON
3. CIRCUIT NAME AND NUMBER:	UPTON - 2
4. CIRCUIT LOCATION	UPTON, KY - MILLERSTOWN RD, AKERS SCHOOL RD, CASH RD, FLINT
(TOWN-ROAD-GENERAL AREA):	HILL RD, RAIDER HOLLOW RD, WAX RD
5. TOTAL CIRCUIT LENGTH (MILES):	47.41
6. CUSTOMER COUNT FOR THIS CIRCUIT:	336
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	08/15
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	14.63% SMALL ANIMALS OR BIRDS 0.27% 0.00% TREES 12.91% 35.32% WIND, HIGH WIND 0.54% 7.63% WEATHER 15.84%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	64.10
10. REPORTING YEAR (SAIDI):	69.54
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.68
12. REPORTING YEAR (SAIFI):	0.79
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Feeder inspection will identify areas for correction.

CIRCUIT #16:	VERTREES - 5
1. SUBSTATION NAME AND NUMBER:	VERTREES (8)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - SALT RIVER RD VERTREES
3. CIRCUIT NAME AND NUMBER:	VERTREES - 5
4. CIRCUIT LOCATION	EAST VIEW, KY - SALT RIVER RD, LAUREL RIDGE RD, SONORA
(TOWN-ROAD-GENERAL AREA):	HARDIN SPRINGS RD, RIDGE TOP LN
5. TOTAL CIRCUIT LENGTH (MILES):	71.93
6. CUSTOMER COUNT FOR THIS CIRCUIT:	467
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	03/16
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	OUTAGE MINUTES (% OF TOTAL OUTAGE MINUTES): 0.00% PUBLIC ACCIDENTS, OTHER 0.72% 79.52% SMALL ANIMALS OR BIRDS 0.00% 1.11% TREES 17.07% 0.17% WIND, HIGH WIND 0.00% 1.32% WEATHER 0.10% 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	243.07
10. REPORTING YEAR (SAIDI):	168.61
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	1.62
12. REPORTING YEAR (SAIFI):	2.23
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Feeder inspection to identify equipment for maintenance.

CIRCUIT #17:	RADCLIFF - 2
1. SUBSTATION NAME AND NUMBER:	RADCLIFF (10)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - HILL ST (NEAR W. LINCOLN TRAIL BLVD) - RADCLIFF
3. CIRCUIT NAME AND NUMBER:	RADCLIFF - 2
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	VINE GROVE, KY - KNOX AVE, WEST SIDE OF SAFARI TRL, RED HILL RD TO GERONIMO CIR, DITTO LN
5. TOTAL CIRCUIT LENGTH (MILES):	19.51
6. CUSTOMER COUNT FOR THIS CIRCUIT:	422
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	01/18
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	OUTAGE MINUTES (% OF TOTAL OUTAGE MINUTES): 0.00% PUBLIC ACCIDENTS, OTHER 0.00% 3.65% SMALL ANIMALS OR BIRDS 90.22% 0.03% TREES 0.50% 0.00% WIND, HIGH WIND 2.40% 3.20% WEATHER 0.00% 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	79.90
10. REPORTING YEAR (SAIDI):	53.20
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	1.06
12. REPORTING YEAR (SAIFI):	1.08
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Feeder inspection will identify areas to mitigate animal caused outages.

CIRCUIT #18:	RADCLIFF - 4
1. SUBSTATION NAME AND NUMBER:	RADCLIFF (10)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - HILL ST (NEAR W. LINCOLN TRAIL BLVD) - RADCLIFF
3. CIRCUIT NAME AND NUMBER:	RADCLIFF - 4
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	RADCLIFF, KY - CONGRESS DR, CATALPA DR, YATES DR, HILLCREST DR SOUTH OF LOGSDON PKWY
5. TOTAL CIRCUIT LENGTH (MILES):	4.56
6. CUSTOMER COUNT FOR THIS CIRCUIT:	312
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	02/18
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	OUTAGE MINUTES (% OF TOTAL OUTAGE MINUTES): 0.00% PUBLIC ACCIDENTS, OTHER 0.00% 9.00% SMALL ANIMALS OR BIRDS 74.67% 0.00% TREES 16.33% 0.00% WIND, HIGH WIND 0.00% 0.00% WEATHER 0.00% 0.00% 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	67.56
10. REPORTING YEAR (SAIDI):	64.31
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.87
12. REPORTING YEAR (SAIFI):	1.16
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Feeder inspection will identify areas to mitigate animal caused outages.

CIRCUIT #19:	RADCLIFF - 5
1. SUBSTATION NAME AND NUMBER:	RADCLIFF (10)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - HILL ST (NEAR W. LINCOLN TRAIL BLVD) - RADCLIFF
3. CIRCUIT NAME AND NUMBER:	RADCLIFF - 5
4. CIRCUIT LOCATION	RADCLIFF, KY - W LINCOLN TRAIL BLVD, N LORRAINE ST, S LORRAINE
(TOWN-ROAD-GENERAL AREA):	ST
5. TOTAL CIRCUIT LENGTH (MILES):	3.67
6. CUSTOMER COUNT FOR THIS CIRCUIT:	488
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	03/18
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	15.31% SMALL ANIMALS OR BIRDS 84.21% 0.49% TREES 0.00% 0.00% WIND, HIGH WIND 0.00% 0.00% WEATHER 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	52.86
10. REPORTING YEAR (SAIDI):	56.81
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.67
12. REPORTING YEAR (SAIFI):	1.11
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Feeder inspection will identify areas to mitigate animal caused outages.

CIRCUIT #20:	TUNNEL HILL 1 - 1
1. SUBSTATION NAME AND NUMBER: 2. SUBSTATION LOCATION	TUNNEL HILL 1 (11)
(COUNTY-ROAD-TOWN):	HARDIN - TUNNEL HILL RD E-TOWN
3. CIRCUIT NAME AND NUMBER:	TUNNEL HILL 1 - 1
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	ELIZABETHTOWN, KY - DOLPHIN RD, COMMERCE DR
5. TOTAL CIRCUIT LENGTH (MILES):	7.96
6. CUSTOMER COUNT FOR THIS CIRCUIT:	451
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	09/18
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	71.78% SMALL ANIMALS OR BIRDS 0.00% 0.00% TREES 0.00% 0.00% WIND, HIGH WIND 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	38.93
10. REPORTING YEAR (SAIDI):	39.07
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.69
12. REPORTING YEAR (SAIFI):	0.46
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Feeder inspection to identify equipment for maintenance.

CIRCUIT #21:	TUNNEL HILL 1 - 2
1. SUBSTATION NAME AND NUMBER:	TUNNEL HILL 1 (11)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - TUNNEL HILL RD E-TOWN
3. CIRCUIT NAME AND NUMBER:	TUNNEL HILL 1 - 2
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	ELIZABETHTOWN, KY - TUNNEL HILL RD, RING RD, BON AIRE DR
5. TOTAL CIRCUIT LENGTH (MILES):	7.45
6. CUSTOMER COUNT FOR THIS CIRCUIT:	729
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	12/18
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	0.54% SMALL ANIMALS OR BIRDS 0.00% 0.00% TREES 83.24% 5.00% WIND, HIGH WIND 0.00% 11.22% WEATHER 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	39.32
10. REPORTING YEAR (SAIDI):	51.45
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.27
12. REPORTING YEAR (SAIFI):	0.47
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Review ROW conditions and vegetation management cycle.

CIRCUIT #22:	TUNNEL HILL 1 - 4	
1. SUBSTATION NAME AND NUMBER:	TUNNEL HILL 1 (11)	
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - TUNNEL HILL RD	E-TOWN
3. CIRCUIT NAME AND NUMBER:	TUNNEL HILL 1 - 4	
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	ELIZABETHTOWN, KY - TUNNEL HILL RD, R	ING RD, FINANCIAL DR
5. TOTAL CIRCUIT LENGTH (MILES):	2.26	
6. CUSTOMER COUNT FOR THIS CIRCUIT:	62	
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	07/18	
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	OUTAGE MINUTES (% OF TOTAL OUTAGE M 0.00% PUBLIC ACCIDENTS, OTHE 25.21% SMALL ANIMALS OR BIRE 0.00% TREE 23.10% WIND, HIGH WIN 51.69% WEATHE	ER 0.00% OS 0.00% ES 0.00% ID 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	1.91	
10. REPORTING YEAR (SAIDI):	37.20	
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.06	
12. REPORTING YEAR (SAIFI):	0.69	
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN		

CIRCUIT #23:	THARP 1 - 3
1. SUBSTATION NAME AND NUMBER: 2. SUBSTATION LOCATION	THARP 1 (12)
(COUNTY-ROAD-TOWN):	HARDIN - ST. JOHN RD ETOWN
3. CIRCUIT NAME AND NUMBER:	THARP 1 - 3
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	ELIZABETHTOWN, KY - SAINT JOHN RD, RING RD
5. TOTAL CIRCUIT LENGTH (MILES):	2.44
6. CUSTOMER COUNT FOR THIS CIRCUIT:	14
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	05/15
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	0.00% WIND, HIGH WIND 0.00% 0.00% WEATHER 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	43.30
10. REPORTING YEAR (SAIDI):	76.67
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.74
12. REPORTING YEAR (SAIFI):	1.07
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Nolin RECC to work with EKPC to review remedies for transmission/substation reliability issues.

CIRCUIT #24:	THARP 1 - 4
1. SUBSTATION NAME AND NUMBER:	THARP 1 (12)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - ST. JOHN RD ETOWN
3. CIRCUIT NAME AND NUMBER:	THARP 1 - 4
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	ELIZABETHTOWN, KY - SAINT JOHN RD, THOMAS RD
5. TOTAL CIRCUIT LENGTH (MILES):	65.58
6. CUSTOMER COUNT FOR THIS CIRCUIT:	931
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	12/15
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	OUTAGE MINUTES (% OF TOTAL OUTAGE MINUTES): 0.00% PUBLIC ACCIDENTS, OTHER 39.97% 0.64% SMALL ANIMALS OR BIRDS 0.02% 0.96% TREES 8.16% 0.05% WIND, HIGH WIND 0.09% 1.70% WEATHER 0.00% 48.41%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	34.74
10. REPORTING YEAR (SAIDI):	144.72
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.84
12. REPORTING YEAR (SAIFI):	2.19
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Nolin RECC to work with EKPC to review remedies for transmission/substation reliability issues. Feeder inspection will identify areas for correction.

CIRCUIT #25:		THARP 1 - 5
1. SUBSTATION NAME AND NUMBER:		THARP 1 (12)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):		HARDIN - ST. JOHN RD ETOWN
3. CIRCUIT NAME AND NUMBER:		THARP 1 - 5
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	ELIZABETI	HTOWN, KY - SAINT JOHN RD, RING RD, WEST PARK RD
5. TOTAL CIRCUIT LENGTH (MILES):		1.58
6. CUSTOMER COUNT FOR THIS CIRCUIT:		10
7. DATE OF LAST CIRCUIT TRIM (MM/YY):		12/15
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	0.00% 0.00% 0.00% 0.00%	NUTES (% OF TOTAL OUTAGE MINUTES): PUBLIC ACCIDENTS, OTHER 0.00% SMALL ANIMALS OR BIRDS 0.00% TREES 0.00% WIND, HIGH WIND 0.00% WEATHER 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):		35.22
10. REPORTING YEAR (SAIDI):		72.24
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):		1.84
12. REPORTING YEAR (SAIFI):		1.00
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Noli	n RECC to work with EKPC to review remedies for transmission/substation reliability issues.

CIRCUIT #26:	SMITHERSVILLE 1 - 2
1. SUBSTATION NAME AND NUMBER:	SMITHERSVILLE 1 (13)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN -S. WILSON & W.A. JENKINS RD E-TOWN
3. CIRCUIT NAME AND NUMBER:	SMITHERSVILLE 1 - 2
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	RINEYVILLE, KY - PEAR ORCHARD RD NW, REDBUD DR
5. TOTAL CIRCUIT LENGTH (MILES):	6.36
6. CUSTOMER COUNT FOR THIS CIRCUIT:	399
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	06/14
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	0.00% WIND, HIGH WIND 0.00% 3.57% WEATHER 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	22.35
10. REPORTING YEAR (SAIDI):	25.19
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.45
12. REPORTING YEAR (SAIFI):	0.62
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Identify new surge arrestor placement opportunities. Review overvoltage protection.

CIRCUIT #27:	SOUTH BOUNDARY - 5
1. SUBSTATION NAME AND NUMBER:	SOUTH BOUNDARY (14)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - HWY 313 - RADCLIFF
3. CIRCUIT NAME AND NUMBER:	SOUTH BOUNDARY - 5
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	ELIZABETHTOWN, KY - BATTLE TRAINING RD, BEWLEY HOLLOW RD
5. TOTAL CIRCUIT LENGTH (MILES):	19.63
6. CUSTOMER COUNT FOR THIS CIRCUIT:	324
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	03/18
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	OUTAGE MINUTES (% OF TOTAL OUTAGE MINUTES): 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	58.28
10. REPORTING YEAR (SAIDI):	86.59
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	1.04
12. REPORTING YEAR (SAIFI):	0.91
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Feeder inspection will identify areas to mitigate wind caused outages.

CIRCUIT #28:	WILLIAMS - 4
1. SUBSTATION NAME AND NUMBER:	WILLIAMS (16)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - BARDSTOWN RD E-TOWN
3. CIRCUIT NAME AND NUMBER:	WILLIAMS - 4
4. CIRCUIT LOCATION	ELIZABETHTOWN, KY - BARDSTOWN RD, N MULBERRY ST EAST OF I-
(TOWN-ROAD-GENERAL AREA):	65, BETH CT,
5. TOTAL CIRCUIT LENGTH (MILES):	13.31
6. CUSTOMER COUNT FOR THIS CIRCUIT:	455
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	03/17
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	5.36% SMALL ANIMALS OR BIRDS 0.00% 25.07% TREES 57.56% 1.54% WIND, HIGH WIND 0.00% 10.46% WEATHER 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	86.58
10. REPORTING YEAR (SAIDI):	42.80
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.54
12. REPORTING YEAR (SAIFI):	0.58
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Review ROW conditions and vegetation management cycle.

CIRCUIT #29:	SMITHERSVILLE 2 - 2
1. SUBSTATION NAME AND NUMBER:	SMITHERSVILLE 2 (17)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN -W.A. JENKINS RD E-TOWN
3. CIRCUIT NAME AND NUMBER:	SMITHERSVILLE 2 - 2
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	RINEYVILLE, KY - WA JENKINS RD, DIXIE HWY
5. TOTAL CIRCUIT LENGTH (MILES):	1.45
6. CUSTOMER COUNT FOR THIS CIRCUIT:	18
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	06/14
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	0.00% SMALL ANIMALS OR BIRDS 0.00% 0.00% TREES 0.00% 0.00% WIND, HIGH WIND 0.00% 0.00% WEATHER 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	0.00
10. REPORTING YEAR (SAIDI):	82.37
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.00
12. REPORTING YEAR (SAIFI):	1.00
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Nolin RECC to work with EKPC to review remedies for transmission/substation reliability issues.

CIRCUIT #30:	SMITHERSVILLE 2 - 3
1. SUBSTATION NAME AND NUMBER:	SMITHERSVILLE 2 (17)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN -S. WILSON & W.A. JENKINS RD E-TOWN
3. CIRCUIT NAME AND NUMBER:	SMITHERSVILLE 2 - 3
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	RINEYVILLE, KY - WA JENKINS RD, DIXIE HWY, TERESA RD
5. TOTAL CIRCUIT LENGTH (MILES):	15.04
6. CUSTOMER COUNT FOR THIS CIRCUIT:	617
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	06/14
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	OUTAGE MINUTES (% OF TOTAL OUTAGE MINUTES): 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI): 10. REPORTING YEAR (SAIDI): 11. CIRCUIT 5 YEAR AVERAGE (SAIFI): 12. REPORTING YEAR (SAIFI):	80.41 160.63 0.69 1.17
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Nolin RECC to work with EKPC to review remedies for transmission/substation reliability issues.

CIRCUIT #31:	SMITHERSVILLE 2 - 4
1. SUBSTATION NAME AND NUMBER:	SMITHERSVILLE 2 (17)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN -S. WILSON & W.A. JENKINS RD E-TOWN
3. CIRCUIT NAME AND NUMBER:	SMITHERSVILLE 2 - 4
4. CIRCUIT LOCATION	E-TOWN, KY - S WILSON RD, PINE VALLEY DR, HUTCHERSON RD, N
(TOWN-ROAD-GENERAL AREA):	DIXIE AVE
5. TOTAL CIRCUIT LENGTH (MILES):	16.64
6. CUSTOMER COUNT FOR THIS CIRCUIT:	968
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	11/14
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	OUTAGE MINUTES (% OF TOTAL OUTAGE MINUTES): 0.00% PUBLIC ACCIDENTS, OTHER 63.51% 0.78% SMALL ANIMALS OR BIRDS 0.00% 1.85% TREES 15.41% 17.99% WIND, HIGH WIND 0.00% 0.47% WEATHER 0.00% 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	128.06
10. REPORTING YEAR (SAIDI):	277.85
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	2.28
12. REPORTING YEAR (SAIFI):	5.78
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Feeder inspection will identify areas for correction.

CIRCUIT #32:	LOGSDON - 4
1. SUBSTATION NAME AND NUMBER:	LOGSDON (18)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - HILL ST (NEAR ETHAN CT) - VINE GROVE
3. CIRCUIT NAME AND NUMBER:	LOGSDON - 4
4. CIRCUIT LOCATION	RADCLIFF, KY - VINELAND CENTER DR , HILL ST , MANLEY AVE ,
(TOWN-ROAD-GENERAL AREA):	AIRPORT RD
5. TOTAL CIRCUIT LENGTH (MILES):	9.16
6. CUSTOMER COUNT FOR THIS CIRCUIT:	503
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	10/17
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	OUTAGE MINUTES (% OF TOTAL OUTAGE MINUTES): 0.00% PUBLIC ACCIDENTS, OTHER 0.00% 14.75% SMALL ANIMALS OR BIRDS 0.00% 0.00% TREES 0.45% 21.98% WIND, HIGH WIND 62.09% 0.72% WEATHER 0.00% 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	65.78
10. REPORTING YEAR (SAIDI):	115.76
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.96
12. REPORTING YEAR (SAIFI):	1.45
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Feeder inspection will identify areas to mitigate wind caused outages.

CIRCUIT #33:	TUNNEL HILL 2 - 3
1. SUBSTATION NAME AND NUMBER:	TUNNEL HILL 2 (19)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - TUNNEL HILL RD E-TOWN
3. CIRCUIT NAME AND NUMBER:	TUNNEL HILL 2 - 3
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	ETOWN, KY - TUNNEL HILL CHURCH RD, SAINT JOHN RD
5. TOTAL CIRCUIT LENGTH (MILES):	63.04
6. CUSTOMER COUNT FOR THIS CIRCUIT:	1078
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	12/19
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	OUTAGE MINUTES (% OF TOTAL OUTAGE MINUTES): 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	139.46
10. REPORTING YEAR (SAIDI):	107.73
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	1.12
12. REPORTING YEAR (SAIFI):	1.57
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Feeder inspection will identify areas for correction.

CIRCUIT #34:	ETOWN 2 - 5
1. SUBSTATION NAME AND NUMBER:	ETOWN 2 (20)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - WOODLAND DR E-TOWN
3. CIRCUIT NAME AND NUMBER:	ETOWN 2 - 5
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	ELIZABETHTOWN, KY - RING RD, PEAR ORCHARD RD
5. TOTAL CIRCUIT LENGTH (MILES):	20.66
6. CUSTOMER COUNT FOR THIS CIRCUIT:	809
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	09/16
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	32.91% SMALL ANIMALS OR BIRDS 0.00% 0.27% TREES 33.48% 3.47% WIND, HIGH WIND 0.00% 29.87% WEATHER 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	44.41
10. REPORTING YEAR (SAIDI):	83.05
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.93
12. REPORTING YEAR (SAIFI):	3.24
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Feeder inspection to identify equipment for maintenance. Review ROW conditions and vegetation management cycle.

CIRCUIT #35:	THARP 2 - 2
1. SUBSTATION NAME AND NUMBER:	THARP 2 (22)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - ST. JOHN RD ETOWN
3. CIRCUIT NAME AND NUMBER:	THARP 2 - 2
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	ELIZABETHTOWN, KY - SAINT JOHN RD, KING ARTHUR RD
5. TOTAL CIRCUIT LENGTH (MILES):	35.32
6. CUSTOMER COUNT FOR THIS CIRCUIT:	612
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	06/13
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	1.64% SMALL ANIMALS OR BIRDS 0.00% 1.79% TREES 12.64% 0.00% WIND, HIGH WIND 0.13% 0.76% WEATHER 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	54.27
10. REPORTING YEAR (SAIDI):	94.96
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.90
12. REPORTING YEAR (SAIFI):	2.06
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Nolin RECC to work with EKPC to review remedies for transmission/substation reliability issues.

CIRCUIT #36:	THARP 2 - 3
1. SUBSTATION NAME AND NUMBER:	THARP 2 (22)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - ST. JOHN RD ETOWN
3. CIRCUIT NAME AND NUMBER:	THARP 2 - 3
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	ELIZABETHTOWN, KY - SAINT JOHN RD, RING RD, WEST PARK RD
5. TOTAL CIRCUIT LENGTH (MILES):	1.01
6. CUSTOMER COUNT FOR THIS CIRCUIT:	1
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	05/15
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	0.00% SMALL ANIMALS OR BIRDS 0.00% 0.00% TREES 0.00% 0.00% WIND, HIGH WIND 0.00% 0.00% WEATHER 0.00%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	19.20
10. REPORTING YEAR (SAIDI):	72.00
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.40
12. REPORTING YEAR (SAIFI):	2.00
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Nolin RECC to work with EKPC to review remedies for transmission/substation reliability issues.

CIRCUIT #37:	THARP 2 - 5
1. SUBSTATION NAME AND NUMBER:	THARP 2 (22)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	HARDIN - ST. JOHN RD ETOWN
3. CIRCUIT NAME AND NUMBER:	THARP 2 - 5
4. CIRCUIT LOCATION	ELIZABETHTOWN, KY - SAINT JOHN RD, WILMOTH RD, LANGLEY
(TOWN-ROAD-GENERAL AREA):	TRACE, CHARLEMAGNE BLVD
5. TOTAL CIRCUIT LENGTH (MILES):	3.49
6. CUSTOMER COUNT FOR THIS CIRCUIT:	121
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	08/15
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	OUTAGE MINUTES (% OF TOTAL OUTAGE MINUTES): 0.00% PUBLIC ACCIDENTS, OTHER 0.00% 0.00% SMALL ANIMALS OR BIRDS 13.78% 0.00% TREES 13.44% 0.42% WIND, HIGH WIND 0.00% 0.00% WEATHER 0.00% 72.35%
9. CIRCUIT 5 YEAR AVERAGE (SAIDI):	21.35
10. REPORTING YEAR (SAIDI):	98.45
11. CIRCUIT 5 YEAR AVERAGE (SAIFI):	0.57
12. REPORTING YEAR (SAIFI):	1.37
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Nolin RECC to work with EKPC to review remedies for transmission/substation reliability issues.

CIRCUIT #38:	ROANOKE - 1
1. SUBSTATION NAME AND NUMBER:	ROANOKE (23)
2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN):	LARUE - GRAY RD - ROANOKE
3. CIRCUIT NAME AND NUMBER:	ROANOKE - 1
4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA):	HODGENVILLE, KY - RIVER RD, LAFOLLETTE RD
5. TOTAL CIRCUIT LENGTH (MILES):	8.51
6. CUSTOMER COUNT FOR THIS CIRCUIT:	90
7. DATE OF LAST CIRCUIT TRIM (MM/YY):	N/A
8. LIST OF OUTAGE(S): CONTRACTOR EQUIPMENT / MATERIAL FAILURE LIGHTNING NO CAUSE CODE PLANNED OUTAGE POWER SUPPLIER	0.19% SMALL ANIMALS OR BIRDS 0.00% 0.00% TREES 25.40% 62.36% WIND, HIGH WIND 9.47% 2.58% WEATHER 0.00%
9. CIRCUIT 1 YEAR AVERAGE (SAIDI):	21.02
10. REPORTING YEAR (SAIDI):	302.57
11. CIRCUIT 1 YEAR AVERAGE (SAIFI):	0.25
12. REPORTING YEAR (SAIFI):	2.34
13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN	Feeder inspection will identify areas for correction.

SECTION 6: VEGETATION MANAGEMENT PLAN REVIEW INCLUDE CURRENT VEGETATION MANGEMENT PLAN

See attached "Vegetation Management Program 2-18-11 Nolin.pdf"
SECTION 7: UTILITY COMMENTS

NOLIN RURAL ELECTRIC COOPERATIVE CORPORATION'S VEGETATION MANAGEMENT PROGRAM

Purpose is to improve the reliability of the electric distribution systems by preventing outages from vegetation located on distribution rights-of-way and minimizing outages from vegetation located adjacent to rights-of-way, maintaining clearances between distribution lines and vegetation on and along distribution rights-of-ways.

Vegetation Management Program

Definitions of Terms Used in Standard

This section includes newly defined or revised terms used in this standard. New or revised definitions, listed below, become approved when the standard is placed in operation. When the standard becomes effective, these defined terms will be removed from the individual standard and added to the Glossary.

Fire Risk: The likelihood that a fire will ignite or spread in a particular geographic area.

Flashover: An electrical discharge through air around or over the surface of insulation, between objects of different potential, caused by placing a voltage across the air space that results in the ionization of the air space.

IEEE: Institute of Electrical and Electronics Engineers, Inc.

Vegetation Inspection: The systematic examination of a distribution corridor to document vegetation conditions.

Operating Voltage: The voltage level by which an electrical system is designated and to which certain operating characteristics of the system are related; also, the effective (root-mean-square) potential difference between any two conductors or between a conductor and the ground. The actual voltage of the circuit may vary somewhat above or below this value.

Rated Electrical Operating Conditions: The specified or reasonably anticipated conditions under which the electrical system or an individual electrical circuit is intend/designed to operate.

Right-of-Way (ROW): A corridor of land on which electric lines may be located. The distribution owner may own the land in fee, own an easement, or have certain franchise, prescription, or license rights to construct and maintain lines.

Sustained Outage: The de-energized condition of a distribution line resulting from a fault or disturbance following an unsuccessful automatic reclosing sequence and/or unsuccessful manual reclosing procedure.

Distribution Line: A system of structures, wires, insulators and associated hardware that carry electric energy from one point to another in an electric power system. Lines are operated at relatively high voltages varying from 120 V up to 7.2 kV, and are capable of transmitting quantities of electricity over long distances.

Vegetation: All plant material, growing or not, living or dead.

Introduction

Purpose:

To improve the reliability of the electric distribution systems by preventing outages from vegetation located on distribution rights-of-way (ROW) and minimizing outages from vegetation located adjacent to ROW, maintaining clearances between distribution lines and vegetation on and along distribution ROW.

This standard is developed for all distribution lines operated at 7.2 kV and to any lower voltage lines designated by the Nolin Rural Electric Cooperative Corporation (RECC) as critical to the reliability of the electric system in the region.

Requirements:

- 1) Nolin RECC will periodically review, and keep current, the formal distribution vegetation management program. The review will include the evaluation of objectives, practices, approved procedures, work specifications, and evaluation of SAIDI, SAIFI, CAIDI, and CAIFI. The outage management system (OMS) will collect information from the automated meter reading (AMR) system, supervisory control and data acquisition (SCADA) and input from the on-duty dispatcher for evaluation.
- 2) The plan defines a schedule for ROW vegetation inspections. This schedule will be flexible enough to adjust for changing conditions. The inspection schedule is based on the anticipated growth of vegetation and any other environmental or operational factors that could impact the relationship of vegetation to the Nolin RECC's distribution lines.
- 3) Encourage public outreach to educate the public, in general, about the use and acceptance of vegetation management on rights-of-way.
- 4) Nolin RECC will, during initial installation, identify clearances between vegetation and any overhead, ungrounded supply conductors, taking into consideration the line voltage, the effects of ambient temperature on conductor sag under maximum design loading, the configuration and insulated value of the line, and the effects of wind velocities on conductor sway. Specifically, Nolin RECC will establish clearances to be achieved at the time of vegetation management work to maintain a set of clearances identified to prevent flashover between vegetation and overhead-ungrounded supply conductors. Nolin RECC shall determine appropriate clearance distances to be achieved at the time of distribution vegetation management work based upon: operating voltage, appropriate vegetation management techniques, fire risk, reasonably anticipated tree and conductor movement, species types and growth rates, species failure characteristics, local climate and rainfall patterns, line terrain and elevation, location of the vegetation within the span, and worker approach distance requirements.

- 5) Nolin RECC will determine specific radial clearances to be maintained between vegetation and conductors under all rated electrical operating conditions. These minimum clearance distances are necessary to prevent flashover between vegetation and conductors and may vary due to such factors as has been stated. Nolin RECC shall develop mitigation measures to achieve sufficient clearances for the protection of the distribution facilities when it identifies locations on the ROW where it is restricted from attaining the clearances specified in this Requirement.
- 6) All personnel directly involved in the design and implementation of the Vegetation Management Program shall hold appropriate qualifications and training, as defined by Nolin RECC, to perform their duties.
- 7) Nolin RECC shall establish a process for the communication of vegetation conditions that present an imminent threat of an outage to a distribution line. This is so action may be taken (temporary reduction in line's consumers, switching line out of service, etc.) until the threat is relieved.
- 8) Nolin RECC shall create and implement an annual plan for vegetation management work to ensure the reliability of the system. The plan shall describe the methods used, such as manual clearing, mechanical clearing, herbicide treatment, or other actions. The plan should be flexible enough to adjust to changing conditions, taking into consideration the anticipated growth of vegetation and other environmental factors that may have an impact on the reliability of the distribution systems. Adjustments to the plan shall be documented as they occur. The plan should take into consideration the time required to obtain permissions or permits from landowners or regulatory authorities. Each procedure for documenting and tracking the planned vegetation management work and ensuring that the vegetation management work was completed according to work specifications.

Compliance to the Requirements

- 1. The overall 'Vegetation Management Plan' will be evaluated annually to establish the progress of the plans' past year improvement against prior years. The comparison will include outage data of specific feeders, overall system outages, record keeping process of outage tickets, time response to outage lengths, comparison of funds to lines lengths and type of work done, and AMR's blink reports. Each year the progress of the plan will be evaluated; deviations, deficiencies or improvements will be made for the following year, and work procedures will be considered.
- 2. The inspection and right of clearing schedule will be 3 years in dense housing areas (approximately 14 consumers per mile), fast growing tree (locust, sycamore etc.) areas and in areas where trimming maybe limited (historic sites, national forest, and sensitive environmental areas). Other areas will be on the normal 5-year cycle.
- 3. An article describing the need for right of way maintenance, safety issues associated with live electric lines and trees, and proper tree selection for planting near electric lines will be mailed to all consumer's service address.
- 4. During System inspection, employees working on existing facilities will make calls to the dispatcher about tree trimming or removal of trouble areas that may not comply with the RUS standard that is set forth in M1.30G "Right of way clearing guide" and standards set by the National Electrical Safety Code in Section 23. If no imminent danger exists, the dispatcher will generate a Work Order Ticket for the correction of the problem.
- 5. Staking sheets will have notes associated for tree trimming or removal with dimensions from the centerline of the line construction. The notes will remain with the staking sheets throughout the construction phase and final inspection of the jobs. The dimensions will comply with the RUS standard that is set forth in M1.30G "Right of way clearing guide" and standards set in the National Electrical Safety Code in Section 23.
- 6. Employees will have annual training on the RUS standards and National Electrical Safety Code relating to line construction and safety issues.
- 7. The dispatcher will be available 24 hours a day to take calls, make work order tickets, and dispatch employees for imminent danger of hazards to the public.
- 8. An overall system map will be color coded for work to be done each year. The map will be a base for planning and an estimate for budget numbers. The cost of various methods right of way control will be used as the land and environment dictate. Each year, during the planning period, an evaluation of outages and outages data will be used to set an estimated budget number. During the Budget planning, a dollar figure will be set aside for the various methods of right of way control. The areas, as budget permits, will be designated as to method and length of lines to be done.