

**Goss
Samford**

ATTORNEYS AT LAW | PLLC

Mark David Goss
mdgoss@gosssamfordlaw.com
(859) 368-7740

May 19, 2016

RECEIVED

Via U.S. Mail

Executive Director
Kentucky Public Service Commission
P.O. Box 615
211 Sower Boulevard
Frankfort, KY 40602

MAY 25 2016

Public Service
Commission

Re: In the Matter of: An Application of South Kentucky Rural Electric Cooperative Corporation for a Certificate of Public Convenience and Necessity to Construct a New Headquarters Facility and For Approval to Transfer Ownership of Certain Assets or, in the Alternative, a Determination That Such Approval is Unnecessary
PSC Case No. 2014-00355

Dear Executive Director:

This letter is tendered pursuant to the Order entered by the Commission in the above-referenced matter on March 27, 2015 (the "Final Order"), which requires South Kentucky Rural Electric Cooperative Corporation ("SKRECC") to file with the Commission certain authorizations, permits, and related documents issued in connection with SKRECC's construction of its New Headquarters Facility in Somerset, Kentucky.¹

Enclosed please find a letter dated May 12, 2016, from the Kentucky Department of Housing, Buildings and Construction evidencing the Department's conditional approval of the fire suppression (sprinkler) system plans submitted by or on behalf of SKRECC related to its New Headquarters Facility.

With the filing of this letter, SKRECC believes it has provided the Commission with all relevant information and documentation concerning construction permits/authorizations, as required by the Final Order. However, SKRECC will keep the Commission abreast of any additional permitting and approval activities as necessary and appropriate.

¹ SKRECC tendered other relevant information, permits and documents to the Commission by correspondence dated June 22, 2015, June 25, 2015, April 22, 2016, and May 6, 2016.

KPSC Executive Director
May 19, 2016
Page 2

Please return to me a file-stamped copy of this correspondence utilizing the enclosed self-addressed, postage-prepaid envelope, and please do not hesitate to contact me if you have any questions or concerns.

Very truly yours,

A handwritten signature in blue ink, appearing to read "Mark David Goss". The signature is fluid and cursive, with a large initial "M" and "D".

Mark David Goss

Enclosure



PUBLIC PROTECTION CABINET

Department of Housing, Buildings and Construction

Matthew G. Bevin
Governor

Steven A. Milby
Commissioner

Division of Building Code Enforcement
101 Sea Hero Road, Suite 100
Frankfort, KY 40601-5412
Phone: (502) 573-0373
www.dhbc.ky.gov

David A. Dickerson
Secretary

Timothy R. House
Deputy Commissioner

May 12, 2016

Craig Napier
Landmark Sprinkler Inc
2317 Frankfort Ct
Lexington, KY 40510-9674

RE: Case No: 085947-000-A & 002-0
South Ky RECC Building A/New Office Building,
Building B/Warehouse Building
200 Somerset Blvd
Somerset, KY/Pulaski County
Code Year: 2013 Kentucky Building Code
Sprinkler System Conditional Approval

Dear Craig Napier:

The Division of Building Code Enforcement has reviewed the suppression system plans submitted by your organization.

We find they are acceptable to this office and meet the intent of the codes as established by the Commonwealth of Kentucky.

Failure of this office to note all violations in the review of plans and specifications does not relieve contractors of the responsibility of complying with the applicable Codes and Regulations.

Upon completion, a test of the system shall be performed in the presence of either a representative of this office, the owner or his agent and so certified to this office.

Sincerely,

Jeff Hogan
Plan Reviewer
jeff.hogan@ky.gov

JH/ms

Conditional Approval Note:

1. Provide shunt trip devices to disconnect main line power in the Elevator shaft and Elevator Machine Room prior to the operation of sprinklers. Section 3009.2.3, 2013 Kentucky Building Code (KBC).

Note: Please ensure the location of the fire department connection meets with the approval of the fire department having jurisdiction.

CC: Allen Anderson/ South Ky RECC, Owner
Ken Milburn. Field Inspector
Martin S Friedman/ MSE of Kentucky Inc, Applicant
Steve Skinner, Field Supervisor