

CANCELLED

September 1, 2021

**KENTUCKY PUBLIC
SERVICE COMMISSION**

PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE

MAR 01 1995

EXHIBIT A

PURSUANT TO 807 KAR 5.011,
SECTION 9(1)

Fleming-Mason RECC
Average Cost Differential Data
March 1, 1995 - March 1, 1996

BY: Jordan C. Neal
FOR THE PUBLIC SERVICE COMMISSION

A.	1. <u>Primary Overhead</u> (1 pole tap 300 feet in length)	
	Pole, Units, Ground, Anchors, Conductor, Hardware, Transformer, etc.	\$ 982.62
	Labor	\$ 261.00
	Total Cost	\$1,263.62
	Total Cost Per Foot	\$ 4.15
	2. <u>Primary Underground</u> (tap 300 feet in length)	
	Conduit, Padmount Transformer, Arrester, Cutout, Conductor, Loadbreak Elbow, Arrester Elbow, Hardware, etc.	\$1,718.12
	Labor	\$ 313.31
	Total Cost	\$2,031.41
	Total Cost Per Foot	\$ 6.77
B.	1. <u>Secondary Overhead</u> (service 100 feet in length)	
	Transformer, Conductor, Hardware, Etc.	\$ 46.02
	Labor	\$ 64.00
	Total Cost	\$ 110.02
	Total Cost Per Foot	\$ 1.10
	2. <u>Secondary Underground</u> (service 100 feet in length)	
	Transformer, Conductor, Hardware, Etc.	\$ 252.65
	Labor	\$ 77.00
	Total Cost	\$ 329.65
	Total Cost Per Foot	\$ 3.30
C.	<u>Cost Differential</u> (per foot)	
	Primary Overhead vs. Underground	\$ 2.62
	Secondary Overhead vs. Underground	\$ 2.20