

CANCELLED

INTER-COUNTY ENERGY

(Name of Utility)

May 1, 2026

CLASSIFICATION OF SERVICE

**KENTUCKY PUBLIC
SERVICE COMMISSION**

ALL ELECTRIC SCHOOLS (AES) - SCHEDULE 5

FOR ENTIRE TERRITORY SERVED
Community, Town or City

P.S.C. KY. NO. 8
REVISION #4 SHEET NO. 18

CANCELLING P.S.C. KY. NO. 8
REVISION #3 SHEET NO. 18

Applicable

In all territory served by the seller.

Availability

Available to all public or non-profit private schools whose total energy requirements, including but not limited to heating, air conditioning, lighting and water heating is supplied by electricity furnished by the cooperative.

Character of Service

The electric service furnished under this rate schedule will be 60 Hz, alternating current, single phase or three phase service, present facilities permitting, and at the following nominal voltages: single phase 120, 120/240, 480, 240/480 volts; three phase 120/240, 120/208Y, 240/480, 277/480Y volts.

Rate

Facilities Charge \$32.64 (T)
All Kilowatt Hours Per Month \$0.09843 Per kWh

Minimum Charge

The minimum annual charge will be not less than \$16.00 per kVA of required transformer capacity as determined by the cooperative.

Fuel Adjustment Clause

All rates are applicable to the fuel adjustment clause and may be increased or decreased by an amount per kWh equal to fuel adjustment amount per kWh as billed by the wholesale power supplier plus an allowance for line losses. The allowance for line losses will not exceed 10% and is based on a twelve-month moving average of such losses. This fuel adjustment clause is subject to all other applicable provisions as set forth in 807 KAR 5:056.

DATE OF ISSUE April 15, 2026
Month / Date / Year

DATE EFFECTIVE May 15, 2026
Month / Date / Year

ISSUED BY Jerry W. Carter
Signature of Officer

TITLE President/CEO
BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE COMMISSION
IN CASE NO. DATED

**KENTUCKY
PUBLIC SERVICE COMMISSION**

Linda C. Bridwell
Executive Director

Linda C. Bridwell

EFFECTIVE

5/15/2026

PURSUANT TO 807 KAR 5:011 SECTION 9 (1)