

STANDARD NOMINAL VOLTAGES

The voltage available to any individual customer shall depend upon the voltage of the Company's lines serving the area in which customer is provided service.

Electric service provided under the Company's rate schedules will be 60 hertz alternating current delivered from various load centers at nominal voltages and phases as available in a given location as follows:

SECONDARY DISTRIBUTION VOLTAGES.

Residential Service

Single phase 120/240 volts three wire or 120/208 volts three wire on network system.

General Service - All Except Residential

Single-phase 120/240 volts three wire or 120/208 volts three wire on network system. Three-phase 120/208 volts four wire on network system, 120/240 volts four wire, 240 volts three wire, 480 volts three wire and 277/480 volts four wire.

PRIMARY DISTRIBUTION VOLTAGES.

The Company's primary distribution voltage levels at load centers are 2,400; 4,160Y; 7,200; 12,470Y, 19,900 and 34,500Y.

SUBTRANSMISSION LINE VOLTAGES.

The Company's sub transmission voltage levels are 19,900; 34,500; 46,000; and 69,000.

TRANSMISSION LINE VOLTAGES.

The Company's transmission voltage levels are 138,000; 161,000; 345,000; and 765,000.

CANCELLED
JAN 19 2013
KENTUCKY PUBLIC
SERVICE COMMISSION

DATE OF ISSUE: July 10, 2015

DATE EFFECTIVE: Service Rendered on or after June 30, 2015

ISSUED BY: JOHN A. ROGNESS III

TITLE: Director Regulatory Services

By authority of an Order by the Public Service Commission

In Case No. 2014-00396 Dated June 22, 2015

KENTUCKY PUBLIC SERVICE COMMISSION
JEFF R. DEROUEN EXECUTIVE DIRECTOR
TARIFF BRANCH <i>Brent Kirtley</i>
EFFECTIVE 6/30/2015
PURSUANT TO 807 KAR 5:011 SECTION 9 (1)