

CAPACITY AND ENERGY CONTROL PROGRAM

The Company's Capacity and Energy Control Program consists of:

- I. Procedures During Abnormal System Frequency
- II. Capacity Deficiency Program
- III. Energy Emergency Control Program

A copy of the Company's Emergency Operating Plan was filed with the Kentucky Public Service Commission on October 22, 2004 in Administrative Case No. 353 in compliance with the Commission's Order dated January 20, 1995.

I. PROCEDURES DURING ABNORMAL SYSTEM FREQUENCY

A. INTRODUCTION

Precautionary procedures are required to meet emergency conditions such as system separation and operation at subnormal frequency. In addition, the coordination of these emergency procedures with neighboring companies is essential. The AEP program, which is in accordance with ECAR Document 3, is noted below.

B. PROCEDURES AEP/PJM

- 1. From 59.8 - 60.2 Hz to the extent practicable utilize all operating and emergency reserves. The manner of utilization of these reserves will depend greatly on the behavior of the System during the emergency. For rapid frequency decline, only that capacity on-line and automatically responsive to frequency (spinning reserve), and such items as interconnection assistance and load reductions by automatic means are of assistance in arresting the decline in frequency.

If the frequency decline is gradual, the Generation/Production Optimization Group, particularly in the deficient area, should invoke non-automatic procedures involving operating and emergency reserves. These efforts should continue until the frequency decline is arrested or until automatic load-shedding devices operate at subnormal frequencies.

- 2. At 59.75 Hz
 - a. Suspend Automatic Generation Control (AGC)
 - b. Notify Interruptible Customers to drop load
- 3. At 59.5 Hz automatically shed 5% of System internal load, excluding interruptibles, by relay action. (25 cycle, .42 sec. delay)
- 4. At 59.4 Hz automatically shed an additional 5% of System internal load, excluding interruptibles, by relay action. (25 cycle, .42 sec. delay)
- 5. At 59.3 Hz automatically shed an additional 5% of System internal load, excluding interruptibles, by relay action. (25 cycle, .42 sec. delay)
- 6. At 59.1 Hz automatically shed an additional 5% of System internal load, excluding interruptibles, by relay action. (25 cycle, .42 sec. delay)
- 7. At 59.0 Hz automatically shed an additional 5% of System internal load, excluding interruptibles, by relay action. (25 cycle, .42 sec. delay)
- 8. At 58.9 Hz automatically shed an additional 5% of System internal load, excluding interruptibles, by relay action. (25 cycle, .42 sec. delay)
- 9. At 58.2 Hz automatically trip the D.C. Cook Nuclear Units 1 and 2.
- 10. At 58.0 Hz or at generator minimum turbine off-frequency value, isolate generating unit without time delay.

If at any time in the above procedure the decline in area frequency is arrested below 59.0 Hz, that part of the System in the low frequency area should shed an additional 10% of its initial load. If, after five minutes, this action has not returned the area frequency to 59.0 Hz or above, that part of the System shall shed an additional 10% of its remaining load and continue to repeat in five-minute intervals until 59.0 Hz is reached. These steps must be completed within the time constraints imposed upon the operation of generating units.

(Cont'd on Sheet No. 2)

CANCELLED
JUN 29 2010
KENTUCKY PUBLIC SERVICE COMMISSION

PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE
3/30/2006
PURSUANT TO 897 KAR 5-001
SECTION 6(1)

DATE OF ISSUE March 20, 2006 DATE EFFECTIVE Service rendered on and after March 30, 2006
By [Signature] Executive Director

ISSUED BY E. K. WAGNER DIRECTOR OF REGULATORY SERVICES FRANKFORT, KENTUCKY
NAME TITLE ADDRESS

CAPACITY AND ENERGY CONTROL PROGRAM (Cont'd)

II. CAPACITY DEFICIENCY PROGRAM

A. PURPOSE

To provide a plan for full utilization of emergency capacity resources and for orderly reduction in the aggregate customer demand on the American Electric Power AEP East/PJM System in the event of a capacity deficiency.

B. CRITERIA

The goals of AEP are to safely and reliably operate the interconnected network in order to avoid widespread system outages as a consequence of a major disturbance. Precautionary procedures including maintaining Daily Operating Reserves, as specified in ECAR document 2 and PJM Manual M13, will assist in avoiding serious emergency conditions such as system separation and operation at abnormal frequency. However, adequate Daily Operating Reserves cannot always be maintained, so the use of additional emergency measures may be required. A Capacity Deficiency is a shortage of generation versus load and can be caused by generating unit outages and/or extreme internal load requirements.

C. AEP EAST/PJM PROCEDURES

(note: the following section contains excerpts from PJM Manual - M13)

OVERVIEW

PJM is responsible for determining and declaring that an Emergency is expected to exist, exists, or has ceased to exist in any part of the PJM RTO or in any other Control Area that is interconnected directly or indirectly with the PJM RTO. PJM directs the operations of the PJM Members as necessary to manage, allocate, or alleviate an emergency.

- *PJM RTO Reserve Deficiencies* — If PJM determines that PJM-scheduled resources available for an Operating Day in combination with Capacity Resources operating on a self-scheduled basis are not sufficient to maintain appropriate reserve levels for the PJM RTO, PJM performs the following actions:
- Recalls energy from Capacity Resources that otherwise deliver to loads outside the Control Area and dispatches that energy to serve load in the Control Area.
- Purchases capacity or energy from resources outside the Control Area. PJM uses its best efforts to purchase capacity or energy at the lowest prices available at the time such capacity or energy is needed. The price of any such capacity or energy is not considered in determining Locational Marginal Prices in the PJM Energy Market. The cost of capacity or energy is allocated among the Market Buyers as described in the PJM Manual for Operating Agreement Accounting (M-28)

The AEP System Control Center will be referred to as SCC and the AEP Production Optimization Group will be referred to as POG.

CAPACITY SHORTAGES

PJM is responsible for monitoring the operation of the PJM RTO, for declaring the existence of an Emergency, and for directing the operations of the PJM Member as necessary to manage, alleviate, or end an Emergency. PJM also is responsible for transferring energy on the PJM Members behalf to meet an Emergency. PJM is also responsible for agreements with other Control Areas interconnected with the PJM RTO for the mutual provision of service to meet an Emergency.

Exhibit 1 illustrates that there are three general levels of emergency actions for capacity shortages:

- alerts
- warnings
- actions


ALERTS

The intent of the alerts is to keep all affected system personnel aware of the forecast and/or actual status of the PJM RTO. All alerts and cancellation thereof are broadcast on the "ALL-CALL" system and posted to selected PJM web sites to ensure that all members receive the same information.

Alerts are issued in advance of a scheduled load period to allow sufficient time for members to prepare for anticipated initial capacity shortages.

(Cont'd on Sheet 3-3)

CANCELLED
JUN 29 2010
KENTUCKY PUBLIC SERVICE COMMISSION

PUBLIC SERVICE COMMISSION OF KENTUCKY
EFFECTIVE 3/30/2006
PURSUANT TO 807 KAR 5:011
SECTION 9 (1)
By 
Director

DATE OF ISSUE March 20, 2006 DATE EFFECTIVE Service rendered on and after March 30, 2006

ISSUED BY E. K. WAGNER DIRECTOR OF REGULATORY SERVICES FRANKFORT, KENTUCKY
NAME TITLE ADDRESS

CAPACITY AND ENERGY CONTROL PROGRAM (Cont'd)

AEP East/PJM Procedures (cont'd)

Alerts(Cont'd)

Maximum Emergency Generation Alert

The purpose of the Maximum Emergency Generation Alert is to provide an early alert that system conditions may require the use of the PJM emergency procedures. It is implemented when Maximum Emergency Generation is called into the operating capacity.

Primary Reserve Alert

The purpose of the Primary Reserve Alert is to alert members of the anticipated shortage of operating reserve capacity for a future critical period. It is implemented when estimated operating reserve capacity is less than the forecast primary reserve requirement.

Voltage Reduction Alert

The purpose of the Voltage Reduction Alert is to alert members that a voltage reduction may be required during a future critical period. It is implemented when the estimated operating reserve capacity is less than the forecast spinning reserve requirement.

Voluntary Customer Load Curtailment Alert

The purpose of the Voluntary Customer Load Curtailment Alert is to alert members of the probable future need to implement a voluntary customer load curtailment. It is implemented whenever the estimated operating reserve capacity indicates a probable future need for voluntary customer load curtailment.

Warnings

Warnings are issued during present operations to inform members of actual capacity shortages or contingencies that may jeopardize the reliable operation of the PJM RTO. The intent of warnings is to keep all affected system personnel aware of the forecast and/or actual status of the PJM RTO. All warnings and cancellations are broadcasted on the "ALL-CALL" system and posted to selected PJM web sites to assure that all members receive the same information.

Primary Reserve Warning

The purpose of the Primary Reserve Warning is to warn members that the available primary reserve is less than required and present operations are becoming critical. It is implemented when available primary reserve capacity is less than the primary reserve requirement, but greater than the spinning reserve requirement, after all available secondary reserve capacity (except restricted maximum emergency capacity) is brought to a primary reserve status and emergency operating capacity is scheduled from adjacent systems.

Voltage Reduction Warning & Reduction of Non-Critical Plant Load

The purpose of the Voltage Reduction Warning & Reduction of Non-Critical Plant Load is to warn members that the available spinning reserve is less than the Spinning Reserve Requirement and that present operations have deteriorated such that a voltage reduction may be required. It is implemented when the available spinning reserve capacity is less than the spinning reserve requirement, after all available secondary and primary reserve capacity (except restricted maximum emergency capacity) is brought to a spinning reserve status and emergency operating capacity is scheduled from adjacent systems.

Manual Load Dump Warning

The purpose of the Manual Load Dump Warning is to warn members of the increasingly critical condition of present operations that may require manually dumping load. It is issued when available primary reserve capacity is less than the largest operating generator or the loss of a transmission facility jeopardizes reliable operations after all other possible measures are taken to increase reserve. The amount of load and the location of areas(s) are specified.

Actions


The PJM RTO is normally loaded according to bid prices; however, during periods of reserve deficiencies, other measures must be taken to maintain system reliability. These measures involve:

- Loading generation that is restricted for reasons other than cost
- Recalling non-capacity backed off-system sales
- Purchasing emergency energy from participants / surrounding pools
- Load relief measures

(Cont'd on Sheet No. 3-4)

CANCELLED
JUN 29 2010
KENTUCKY PUBLIC SERVICE COMMISSION

PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE
3/30/2006
PURSUANT TO 807 KAR 5:011
SECTION 9 (1)

By  Executive Director

DATE OF ISSUE March 20, 2006 DATE EFFECTIVE Service rendered on and after March 30, 2006

ISSUED BY E. K. WAGNER DIRECTOR OF REGULATORY SERVICES FRANKFORT, KENTUCKY
NAME TITLE ADDRESS

CAPACITY AND ENERGY CONTROL PROGRAM (Cont'd)

AEP East/PJM Procedures (Cont'd)

Actions (Cont'd)

The procedures to be used under these circumstances are described in the general order in which they are applied. Due to system conditions and the time required to obtain results, PJM dispatcher may find it necessary to vary the order of application to achieve the best overall system reliability. Issuance and cancellation of emergency procedures are broadcast over the "ALL-CALL" and posted to selected PJM web sites. Only affected systems take action. PJM dispatcher broadcasts the current and projected PJM RTO status periodically using the "ALL-CALL" during the extent of the implementation of the emergency procedures.

Maximum Emergency Generation

The purpose of the Maximum Emergency Generation is to increase the PJM RTO generation above the maximum economic level. It is implemented whenever generation is needed that is greater than the highest incremental cost level.

Load Management Curtailments (ALM)

Steps 1 and 2 (PJM Control)

The purpose of the Load Management Curtailments, Steps 1 and 2, is to provide additional load relief by using PJM controllable load management programs. Steps 1 and 2 are differentiated only by the expected time to implement. Load relief is required after initiating Maximum Emergency Generation.

Step 1: Short Time Frame to Implement (1 Hour or Less)

- PJM dispatcher requests members to implement Load Management Curtailment, Step 1.

Step 2: Long Time Frame To Implement (Greater Than 1 Hour)

- PJM dispatcher requests members to implement Load Management Curtailment, Step 2.

Steps 3 and 4 (SCC Control)

The purpose of the Local Control Center Programs of Load Management Curtailments, Steps 3 and 4, is to provide additional load relief by requesting use of Local Control Center load management programs.

Load Reduction Program

The purpose of the Load Reduction Action is to request end-use customers to reduce load during emergency conditions.

Voltage Reduction

The purpose of Voltage Reduction during capacity deficient conditions is to reduce load to provide a sufficient amount of reserve to maintain tie flow schedules and preserve limited energy sources. A curtailment of non-essential building load is implemented prior to or at this same time as a Voltage Reduction Action. It is implemented when load relief is still needed to maintain tie schedules.

CANCELLED
JUN 29 2010
KENTUCKY PUBLIC SERVICE COMMISSION

Note: Voltage reductions can also be implemented to increase transmission system voltage.

Note: Curtailment of non-essential building load may be implemented prior to, but not later than, the same time as a voltage reduction.

Curtailment of Non-Essential Building Load

The purpose of the Curtailment of Non-Essential Building Load is to provide additional load relief expedited prior to, but no later than the same time as a voltage reduction.

(Cont'd on sheet No. 3-5)

PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE
3/30/2006
PURSUANT TO 807 KAR 5:011
SECTION 9 (1)

DATE OF ISSUE March 20, 2006 DATE EFFECTIVE Service rendered on and after March 30, 2006 Director

ISSUED BY E. K. WAGNER DIRECTOR OF REGULATORY SERVICES
NAME TITLE ADDRESS
FRANKFORT, KENTUCKY

CAPACITY AND ENERGY CONTROL PROGRAM (Cont'd)

AEP East/PJM Procedures (cont'd)

Actions

Voluntary Customer Load Curtailment

The purpose of the Voluntary Customer Load Curtailment (VCLC) is to provide further load relief. It is implemented when the estimated peak load minus the relief expected from curtailment of non-essential building load and a 2.5% - 5% voltage reduction is greater than operating capacity.

PJM/SCC - Public Appeal to conserve electricity usage

Manual Load Dump

The purpose of the Manual Load Dump is to provide load relief when all other possible means of supplying internal PJM RTO load have been used to prevent a catastrophe within the PJM RTO or to maintain tie schedules so as not to jeopardize the reliability of the other interconnected regions. It is implemented when the PJM RTO cannot provide adequate capacity to meet the PJM RTO's load or critically overloaded transmission lines or equipment cannot be relieved in any other way and/or low frequency operation occurs in the PJM RTO, parts of the PJM RTO, or PJM RTO and adjacent Control Areas that may be separated as an island.

Addendum to Manual Load Dump Procedures

AEP understands that PJM intends to implement these curtailment protocols consistent with the agreements that PJM entered into in Kentucky and Virginia, in Stipulations approved by the Kentucky Public Service Commission and Virginia State Corporation Commission (with modifications) in Case No. 2002-00475 and Case No. PUE-2000-00550, respectively.

Capacity Deficiency Summary

A summary of the emergency alerts, warning and actions, together with the typical sequence and the method of communication, are presented in the following Table III-2 on Tariff Sheet No. 3-6.

(Cont'd on Sheet No. 3-6)

CANCELLED
JUN 29 2010
KENTUCKY PUBLIC
SERVICE COMMISSION

PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE
3/30/2006
PURSUANT TO 807 KAR 5:011
SECTION 9 (1)

DATE OF ISSUE March 20, 2006 DATE EFFECTIVE Service rendered on and after March 20, 2006 By [Signature] Director

ISSUED BY E. K. WAGNER DIRECTOR OF REGULATORY SERVICES FRANKFORT, KENTUCKY
NAME TITLE ADDRESS

Issued by authority of an Order at the Public Service Commission in Case No. 2005-00341 dated March 14, 2006

CAPACITY AND ENERGY CONTROL PROGRAM (Cont'd)				
		Communications	Description	
Alert	Maximum Emergency Generation	PJM-POG via All-Call PJM-SCC via All-Call SCC-TDC	SCC/POG review scheduled or actual maintenance affecting capacity or critical transmission to determine if it can be deferred or cancelled	EEA 1
	Primary Reserve	PJM-POG via All-Call PJM-SCC via All-Call SCC-TDC	(Same as above)	
	Voltage Reduction	PJM-SCC via All-Call SCC-TDC	SCC/TDC to identify stations for Voltage Reduction	
	Voluntary Customer Load Curtailment	PJM-POG via All-Call PJM-SCC via All-Call	Not Applicable	
Warning	Primary Reserve	PJM-POG via All-Call PJM-SCC via All-Call SCC-TDC	SCC/POG ensure that all deferrable maintenance or testing affecting capacity or critical transmission is halted.	
	Voltage Reduction & Reduction of Non-Critical Plant Load	PJM-POG via All-Call PJM-SCC via All-Call SCC-TDC	SCC to inform TDC to man Voltage Reduction Stations & prepare for Voltage Reduction	POG to reduce plant load. (See Table III-4)
	Manual Load Dump	PJM-SCC via All-Call SCC- POG-Environmental Services SCC-TDC-DDC	Lifting of Environmental Restrictions (See Table III-5)	Manual & Automatic Load Shedding
		Make preparations for a Public Appeal if one becomes necessary.	a. Obtain permission to exceed opacity limits b. Obtain permission to exceed heat input limits c. Obtain permission to exceed river temperature limits	SCC/TDC will review local computer procedures and man manual load shedding stations
Action	Maximum Emergency Generation	PJM-POG via All-Call PJM-SCC via All-Call	Supplemental Oil & Gas Firing; Operate Generator Peakers; Emergency Hydro; Extra Load Capability	See Table III-3
	Load Management Curtailment (ALM)	PJM-SCC via All-Call SCC - POG	Step 3 - 1267 Mws - 1 hr, 249 Mws - 2 hr	EEA 2 (DOE Report)
	Load Reduction Program	PJM-SCC via All-Call	Not Applicable	
	Voltage Reduction	PJM-SCC via All-Call SCC -TDC & SCC - POG	Initiate Voltage Reduction - AEP/PJM - 64 Mws	
	Curtailment of Non-Essential Building Load	PJM-POG via All-Call PJM-SCC via All-Call SCC- Building Services	Initiate curtailment of AEP building load - 4.4 Mws	Issued approx. same time as Voltage Reduction
	Voluntary Customer Load Curtailment	PJM-POG via All-Call PJM-SCC via All-Call	Not Applicable	EEA 3 (DOE Report)
	Public Appeal (may be issued at any stage of the Action items)	SCC - Corporate Communications	a. Radio and TV alert to general public	2% of AEP Internal Load
		SCC - Customer Services SCC - POG	b. Call to Industrial and Commercial Customers	1276 Mws - 1 hr + 320 Mws - 2 hr
		SCC - TDC	c. Municipal and REMC Customers	7% of Cust. Load
	Manual Load Dump	PJM-SCC via All-Call SCC-POG-Environmental Services SCC-TDC-DDC	PJM Allocation based on generation zones	PUBLIC SERVICE COMMISSION OF KENTUCKY EFFECTIVE 3/30/2006 PURSUANT TO 807 KAR 5:010
		a. Lift Environmental Restrictions on units	(regains curtailed generation)	
		b. Selected distribution 9 (1) customers (manual load curtailment)	Execute MLD	

(Cont'd on Sheet 3-7)

By  Director

DATE OF ISSUE March 20, 2006 DATE EFFECTIVE Service rendered on and after March 30, 2006

ISSUED BY E.K. WAGNER DIRECTOR OF REGULATORY SERVICES FRANKFORT, KENTUCKY

NAME TITLE ADDRESS

Issued by authority of an Order at the Public Service Commission in Case No. 2005-00341 dated March 14, 2006

CAPACITY AND ENERGY CONTROL PROGRAM (Cont'd)

Energy Emergency Alert Levels (reference NERC Appendix 5C)

1. Alert 1 - All available resources in use.

Circumstances:

- Control Area, Reserve Sharing Group, or Load Serving Entity foresees or is experiencing conditions where all available resources are committed to meet firm load, firm transactions, and reserve commitments, and is concerned about sustaining its required Operating Reserves, and
- Non-firm wholesale energy sales (other than those that are recallable to meet reserve requirements) have been curtailed.

2. Alert 2 - Load management procedures in effect.

Circumstances:

- Control Area, Reserve Sharing Group, or Load Serving Entity is no longer able to provide its customers' expected energy requirements, and is designated an Energy Deficient Entity.
- Energy Deficient Entity foresees or has implemented procedures up to, but excluding, interruption of firm load commitments. When time permits, these procedures may include, but are not limited to:
 - Voltage reduction
 - Public appeals to reduce demand
 - Interruption of non-firm end use loads in accordance with applicable contracts, for emergency, not economic reasons
 - Demand-side management
 - Utility load conservation measures


- During Alert 2, The Reliability Coordinators, Control Areas, and Energy Deficient Entities have the following responsibilities:

- 2.1 Notifying other Control Areas and Market Participants.
- 2.2 Declaration Period. The Energy Deficient Entity shall update the Reliability Coordinator of the situation at a minimum of every hour until the Alert 2 is terminated.
- 2.3 Share information on resource availability.
- 2.4 Evaluating and mitigating transmission limitations.
 - 2.4.1 Notification of ATC adjustments.
 - 2.4.2 Availability of generation redispatch options.
 - 2.4.3 Evaluating impact of current Transmission Loading Relief events.
 - 2.4.4 Initiating inquiries on reevaluating Operating Security Limits.

CANCELLED
JUN 29 2010
 KENTUCKY PUBLIC
 SERVICE COMMISSION

- 2.5 Coordination of emergency responses. The Reliability Coordinator shall communicate and coordinate the implementation of emergency operating responses.
- 2.6 Energy Deficient Entity actions. Before declaring an Alert 3, the Energy Deficient Entity must make use of available resources. This includes but is not limited to:
 - 2.6.1 All available generation units are on line. All generation capable of being on line in the time frame of the emergency is on line including quick-start and peaking units, regardless of cost.
 - 2.6.2 Purchases made regardless of cost. All firm and non-firm purchases have been made, regardless of cost.

PUBLIC SERVICE COMMISSION
 OF KENTUCKY
 EFFECTIVE
 3/30/2006
 PURSUANT TO 807 KAR 5:011
 SECTION 9 (1)

(Cont'd on Sheet No. _____)
By  Executive Director

DATE OF ISSUE March 20, 2006 DATE EFFECTIVE Service rendered on and after March 30, 2006

ISSUED BY E.K. WAGNER DIRECTOR OF REGULATORY SERVICES FRANKFORT, KENTUCKY

NAME TITLE ADDRESS
Issued by authority of an Order at the Public Service Commission in Case No. 2005-00341 dated March 14, 2006

CAPACITY AND ENERGY CONTROL PROGRAM (Cont'd)

Energy Emergency Alert Levels (reference NERC Appendix 5C) (Cont'd)

2.6.3 Non-firm sales recalled and contractually interruptible loads and DSM curtailed. All non-firm sales have been recalled, contractually interruptible retail loads curtailed, and Demand-side Management activated within provisions of the agreements.

2.6.4 Operating Reserves. Operating reserves are being utilized such that the Energy Deficient Entity is carrying reserves below the required minimum or has initiated emergency assistance through its operating reserve sharing program.

3. **Alert 3 - Firm load interruption imminent or in progress.**

Circumstances:

- Control Area or Load Serving Entity foresees or has implemented firm load obligation interruption. The available energy to the Energy Deficient Entity, as determined from Alert 2, is only accessible with actions taken to increase transmission transfer capabilities.

3.1 Continue actions from Alert 2.

3.2 Declaration Period. The Energy Deficient Entity shall update the Reliability Coordinator of the situation at a minimum of every hour until the Alert 3 is terminated.

3.3 Use of Transmission short-time limits.

3.4 Reevaluating and revising Operating Security Limits.

3.4.1 Energy Deficient Entity obligations. The deficient Control Area or Load Serving Entity must agree that, upon notification from its Reliability Coordinator of the situation, it will immediately take whatever actions are necessary to mitigate any undue risk to the Interconnection. These actions may include load shedding.

3.4.2 Mitigation of cascading failures. The Reliability Coordinator shall use his best efforts to ensure that revising Operating Security Limits would not result in any cascading failures within the Interconnection.

3.5 Returning to pre-emergency Operating Security Limits. Whenever energy is made available to an Energy Deficient Entity such that the transmission systems can be returned to their pre-emergency Operating Security Limits, the Energy Deficient Entity shall notify its respective Reliability Coordinator and downgrade the Alert.

3.5.1 Notification of other parties.

3.6 Reporting. Any time an Alert 3 is declared, the Energy Deficient Entity shall complete the report listed in NERC Appendix 9B, Section C and submit this report to its respective Reliability Coordinator within two business days of downgrading or termination of the Alert. Upon receiving the report, the Reliability Coordinator shall review it for completeness and immediately forward it to the NERC staff for posting on the NERC web site. The Reliability Coordinator shall present this report to the Reliability Coordinator Working Group at its next scheduled meeting.


4. **Alert 0 - Termination.** When the Energy Deficient Entity believes it will be able to supply its customers' energy requirements, it shall request of his Reliability Coordinator that the EEA be terminated.

4.1 Notification.

CANCELLED
JUN 29 2010
KENTUCKY PUBLIC
SERVICE COMMISSION

PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE
3/30/2006
PURSUANT TO 807 KAR 5:011
SECTION 9 (1)

(Cont'd on Sheet 3-9)

By  Director

DATE OF ISSUE March 20, 2006 DATE EFFECTIVE Service rendered on and after March 30, 2006

ISSUED BY E. K. Wagner DIRECTOR OF REGULATORY SERVICES FRANKFORT, KENTUCKY

CAPACITY AND ENERGY CONTROL PROGRAM (Cont'd)

III. ENERGY EMERGENCY CONTROL PROGRAM

A. INTRODUCTION

The purpose of this plan is to provide for the reduction of the consumption of electric energy on the American Electric Power Company System in the event of a fuel shortage, such as might result from a general strike, or severe weather.

B. PROCEDURES

In the event of a potential severe coal shortage, such as one resulting from a general coal strike, the following steps will be implemented. These steps will be carried out to the extent permitted by contractual commitments or by order of the regulatory authorities having jurisdiction.

A. To be initiated when system fuel supplies are decreased to 70% of target days' operation of coal-fired generation and a continued downward trend in coal stocks is anticipated:

1. Optimize the use of non-coal-fired generation to the extent possible.
2. For individual plants under 50% of minimum target days' supply, review the prudence of modifying economic dispatching procedures to conserve coal.
3. If necessary discontinue all economy sales to neighboring utilities.
4. Curtail the use of energy in company offices, plants, etc., over and above the reductions already achieved by current in-house conservation measures.


B. To be initiated when system fuel supplies are decreased to 60% of target days' operation of coal-fired generation and a continued downward trend in coal stocks is anticipated:

1. Substitute the use of oil for coal, as permitted by plant design, oil storage facilities, and oil availability.
2. Discontinue all economy and short-term sales to neighboring utilities.
3. Limit emergency deliveries to neighboring utilities to situations where regular customers of such utilities would otherwise be dropped or where the receiving utility agrees to return like quantities of energy within 14 days.
4. Curtail electric energy consumption by customers on Interruptible contracts to a maximum of 132 hours of use at contract demand per week.
5. Purchase energy from neighboring systems to the extent practicable.
6. Purchase energy from industrial customers with generation facilities to the extent practicable.
7. Through the use of news media and direct consumer contact, ~~appeal to all customers (retail as well as wholesale) to reduce their nonessential use of electric energy as much as possible, in any case by at least 25%.~~ ^{appeal to all customers (retail as well as wholesale) to reduce their nonessential use of electric energy as much as possible, in any case by at least 25%.}
8. Reduce voltage around the clock to the extent feasible.
9. The Company will advise customers of the nature of the mandatory program to be introduced in C below, through direct contact and mass media, and establish an effective means of answering specific customer inquiries concerning the impact of the mandatory program on electricity availability.

CANCELLED
JUN 29 2010
KENTUCKY PUBLIC SERVICE COMMISSION

PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE
3/30/2006
PURSUANT TO 807 KAR 5:011
SECTION 9 (1)

(Cont'd on Sheet No. 3-10)

By 
Director

DATE OF ISSUE March 20, 2006 DATE EFFECTIVE Service rendered on and after March 30, 2006

ISSUED BY E.K. Wagner DIRECTOR OF REGULATORY SERVICES FRANKFORT, KENTUCKY
NAME TITLE ADDRESS

CAPACITY AND ENERGY CONTROL PROGRAM(Cont'd)

III. ENERGY EMERGENCY CONTROL PROGRAM(Cont'd)

B. PROCEDURES (Cont'd)

C. To be initiated -- in the order indicated below -- when system fuel supplies are decreased to 50% of target days' operation of coal-fired plants and a continued downward trend in coal stocks is anticipated:

1. Discontinue emergency deliveries to neighboring utilities unless the receiving utility agrees to return like quantities of energy within seven days.
2. Request all customers, retail as well as wholesale, to reduce their nonessential use of electric energy by 100%.
3. Request, through mass communication media, curtailment by all other customers a minimum of 15% of their electric use. These uses include lighting, air-conditioning, heating, manufacturing processes, cooking, refrigeration, clothes washing and drying and any other loads that can be curtailed.
4. All customers will be advised of the mandatory program specified below in D.

D. To be initiated when system fuel supplies are decreased to 40% of target days' operation of coal-fired generation and a continued downward trend in coal stocks is anticipated:

1. Implement procedures for curtailment of service to all customers to a minimum service level that is not greater than that required for protection of human life and safety, protection of physical plant facilities and employees' security. This step asks for curtailment of the maximum load possible without endangering life, safety and physical facilities.
2. All customers will be advised of the mandatory program specified below in E.

E. To be initiated when system fuel supplies are decreased to 30% of target days' operation of coal-fired generation and a continued downward trend in coal stocks is anticipated:

Implement procedures for interruption of selected distribution circuits on a rotational basis, while minimizing -- to the extent practicable -- interruption to facilities that are essential to the public health and safety.

F. The Energy Emergency Control Program will be terminated when:

1. The AEP System's remaining days of operation of coal-fired generation is at least 40% of normal target days' operation, and
2. Coal deliveries have been resumed, and
3. There is reasonable assurance that the AEP System's coal stocks are being restored to adequate levels.

With regard to mandatory curtailments identified in Items C, D, and E above, the Company proposes to monitor compliance after the fact. A customer exceeding his electric allotment would be warned to curtail his usage or face, upon continuing noncompliance and upon one day's actual written notice, disconnection of electric service for the duration of the energy emergency.

CANCELLED
JUN 29 2010
KENTUCKY PUBLIC
SERVICE COMMISSION

PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE
3/30/2006
PURSUANT TO 807 KAR 5:011
SECTION 9 (1)

DATE OF ISSUE March 20, 2006 DATE EFFECTIVE Service rendered on and after March 20, 2006 By [Signature] Director

ISSUED BY E. K. WAGNER DIRECTOR OF REGULATORY SERVICES FRANKFORT, KENTUCKY
NAME TITLE ADDRESS