

STANDARD NOMINAL VOLTAGES

The voltage available to any individual customer shall depend upon the voltage of the Company's lines serving the area in which customer is provided service.

Electric service provided under the Company's rate schedules will be 60 hertz alternating current delivered from various load centers at nominal voltages and phases as available in a given location as follows:

SECONDARY DISTRIBUTION VOLTAGES

Residential Service

Single phase 120/240 volts three wire or 120/208 volts three wire on network system.

General Service - All Except Residential

Single-phase 120/240 volts three wire or 120/208 volts three wire on network system. Three-phase 120/208 volts four wire on network system, 120/240 volts four wire, 240 volts three wire, 480 volts three wire and 277/480 volts four wire.

PRIMARY DISTRIBUTION VOLTAGES

The Company's primary distribution voltage levels at load centers are 2,400; 4,160Y; 7,200; 12,470Y, 19,900 and 34,500

SUBTRANSMISSION LINE VOLTAGES

The Company's sub transmission voltage levels are 19,900; 34,500; 46,000; and 69,000.

TRANSMISSION LINE VOLTAGES

The Company's transmission voltage levels are 138,000; 161,000; 345,000; and 765,000.

CANCELLED
JUN 29 2010
KENTUCKY PUBLIC
SERVICE COMMISSION

**PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE**

3/30/2006

PURSUANT TO 807 KAR 5:011
SECTION 9 (1)

DATE OF ISSUE March 20, 2006 DATE EFFECTIVE Service rendered on and after March 20, 2006

ISSUED BY E.K. Wagner DIRECTOR OF REGULATORY SERVICES
NAME TITLE ADDRESS Director