

## Standard Nominal Voltages

The voltage available to any individual customer shall depend upon the voltage of the Company's lines serving the area in which customer is provided service.

Electric service provided under the Company's rate schedules will be 60 hertz alternating current delivered from various load centers at nominal voltages and phases as available in a given location as follows:

### Secondary Distribution Voltages

#### Residential Service

Single phase 120/240 volts three wire or 120/208 volts three wire on network system.

#### General Service - All Except Residential

Single-phase 120/240 volts three wire or 120/208 volts three wire on network system. Three-phase 120/208 volts four wire on network system, 120/240 volts four wire, 240 volts three wire, 480 volts three wire and 277/480 volts four wire, Single-phase 480 volts two wire, and Single-phase 240/480 volts three wire.

### Primary Distribution Voltages

The Company's primary distribution voltage levels at load centers are 2,400; 4,160Y; 7,200; 12,470Y; 19,900 and 34,500Y.

### Subtransmission Line Voltages

The Company's sub transmission voltage levels are 34,500; 46,000; and 69,000.

### Transmission Line Voltages

The Company's transmission voltage levels are 138,000; 161,000; 345,000; and 765,000.

DATE OF ISSUE: February 8, 2024  
DATE EFFECTIVE: Services Rendered On And After January 16, 2024  
ISSUED BY: /s/ Brian K. West  
TITLE: Vice President, Regulatory & Finance  
By Authority of an Order of the Public Service Commission  
In Case No.: 2023-00159 Dated January 19, 2024


**CANCELLED**

March 1, 2026

**KENTUCKY PUBLIC  
SERVICE COMMISSION**

**KENTUCKY  
PUBLIC SERVICE COMMISSION**

**Linda C. Bridwell**  
Executive Director



EFFECTIVE

**1/16/2024**

PURSUANT TO 807 KAR 5:011 SECTION 9 (1)