

STANDARD RATE SHEET

4th Rev. SHEET NO. 27.1 OF P. S. C. of Ky. No. 1  
CANCELLING 3rd Rev. SHEET NO. 27.1 OF P. S. C. of Ky. No. 1

LOUISVILLE GAS AND ELECTRIC COMPANY

STANDARD RATE SCHEDULE

Special Terms and Conditions Relating to Application  
of Residential Rate Schedule R Electric

1. Residential Rate R is based on service to single family units and is not applicable to multi-family dwellings served through a single meter. Where two or more families occupy a residential building the Company will require as a condition precedent to the application of the residential rate that the wiring in the building be so arranged as to permit each family to be served through a separate meter. In those cases where such segregation of wiring would involve undue expense to the customer, the Company will allow service to two or more families to be taken through one meter, but in this event the energy blocks and minimum bills of the residential rate shall be multiplied by the number of families thus served, such number of families to be determined on the basis of the number of kitchens in the building. At the customer's option, in lieu of the foregoing, electric service rendered to a multi-family residential building through a single meter will be classified as commercial and billed on the basis of service to one customer at the commercial rate.

2. Family unit service shall include usage of electric energy customarily incidental to home occupations, such as the office of a physician, surgeon, dentist, musician or artist when such occupation is carried on by the customer in his residence.

3. A residential building used to accommodate roomers or boarders for compensation will be billed at the residential rate provided it does not exceed twelve rooms in size. A residential building of more than twelve rooms used to accommodate roomers or boarders for compensation will be classified as commercial and billed at commercial rates. In determining the room rating of rooming and boarding houses all wired rooms shall be counted except hallways, vestibules, alcoves, closets, bathrooms, lavatories, garrets, attics, storage rooms, trunk rooms, basements, cellars, porches and private garages.

4. Service used in residential buildings occupied by fraternity or sorority organizations associated with educational institutions will be classified as residential and billed at the residential rate.

5. Where both residential and ~~commercial~~ classes of service are supplied through a single meter such combined service shall be classified as commercial and billed at the commercial rate. The customer may arrange his wiring so as to separate the commercial service from the residential service, in which event two meters will be installed by the Company and separate residential and commercial rates applied to the respective classes of service.

APPROVED

DEC 5 1957

PUBLIC SERVICE COMMISSION  
ENGINEERING DIVISION

DATE OF ISSUE November 27, 1957

DATE EFFECTIVE Meter readings taken on and after Dec. 26, 1957

ISSUED BY

G. R. Armstrong

President

Louisville, Kentucky

NAME

TITLE

ADDRESS

Issued by authority of an order of the Public Service Commission of Ky., dated Nov. 26, 1957

STANDARD RATE SHEET

4th Rev. SHEET NO. 27.2 OF P. S. C. of Ky. No. 1  
3rd Rev. SHEET NO. 27.2 OF P. S. C. of Ky. No. 1  
CANCELLING

LOUISVILLE GAS AND ELECTRIC COMPANY

STANDARD RATE SCHEDULE

Special Terms and Conditions Relating to Application  
of Residential Rate Schedule R (Cont.) Electric

6. If a farm customer's barns, pumphouse, or other outbuildings are located at such distance from his residence as to make it impracticable to supply service thereto through his residential meter, the separate meter required to measure service to such remotely located buildings will be considered a separate service contract and billed as a separate customer.

7. Single-phase power service used for domestic purposes will be permitted under residential rate R when measured through the residential meter to the extent and subject to the conditions set forth below:

- (a) Single-phase motors which are manually controlled and infrequently started will be permitted to be served at 120 volts provided the locked-rotor current at rated voltage does not exceed 46 amperes.
- (b) Single-phase motors which are automatically controlled will be permitted to be served at 120 volts provided the locked-rotor current at rated voltage does not exceed 23 amperes.
- (c) All single-phase motors having locked-rotor currents in excess of the maximum values specified in paragraphs (a) and (b) above must be served at 240 volts. Subject to such exceptions as may be authorized in writing by the Company pursuant to the provisions of paragraph (e) below, the locked-rotor currents of single-phase motors served at 240 volts shall not exceed a maximum of 28.75 amperes if automatically controlled nor a maximum of 57.5 amperes if such motors are manually controlled and infrequently started.
- (d) In the case of multi-motored devices arranged for sequential starting of the motors, the above rules are considered to apply to the locked-rotor currents of the individual motors; if arranged for simultaneous starting of the motors, the rules apply to the sum of the locked-rotor currents of all motors so started. When a current reducing starter is used, the locked-rotor current to be considered is the current taken from the line with the rotor locked, with the starting device in the starting position, and with rated voltage and frequency applied.
- (e) Subject to the Company's written consent, 240-volt single-phase motors having locked-rotor currents in excess of the maximum values specified in paragraph (c) above may be permitted to be served through a customer's residential meter provided the available capacity of Company's existing electric

APPROVED  
DEC 5 1957  
PUBLIC SERVICE COMMISSION  
ENGINEERING DIVISION

DATE OF ISSUE November 27, 1957 Meter readings taken on  
ISSUED BY G. R. Armstrong President Louisville, Kentucky End after Dec. 26, 1957  
NAME TITLE ADDRESS

Issued by authority of an order of the Public Service Commission of Ky., dated Nov. 26, 1957

STANDARD RATE SHEET

3rd Rev. SHEET NO: 27.3 OF P. S. C. of Ky. No. 1  
CANCELLING 2nd Rev. SHEET NO: 27.3 OF P. S. C. of Ky. No. 1

LOUISVILLE GAS AND ELECTRIC COMPANY

STANDARD RATE SCHEDULE


Special Terms and Conditions Relating to Application  
of Residential Rate Schedule R (Cont.) Electric

distribution facilities at desired point of supply is such that, in Company's judgment, the starting of such motors will not result in excessive voltage dips and undue impairment of lighting service and television reception of nearby electric customers. As a condition precedent to Company's grant of written consent for the connection of such motors and supply of service thereto at residential rate schedules, Company may require that they be equipped with approved devices for reducing starting currents to such maximum amperage as may be designated by Company. If, in Company's judgment, the only basis on which such motors can be served without undue impairment of lighting service and television reception of nearby customers is by installation of a separate distribution transformer, applicant may be further required to make a payment to Company covering the estimated cost of providing and installing such separate transformer.

(f) Any motor or motors served through a separate meter will be billed as a separate customer.

8. No three-phase power service will be rendered under residential Rate Schedule R. Any residential customer or group of customers desiring to contract for three-phase service for power purposes will be required to advance the cost of extending such service to the premises at which desired and shall be billed for such service at Company's applicable general power rate.

6-6-62



DATE OF ISSUE November 27, 1957

Meter readings taken on  
DATE EFFECTIVE End after Dec. 26, 1957

ISSUED BY G. R. Armstrong  
NAME

President  
TITLE

Louisville, Kentucky  
ADDRESS

Issued by authority of an order of the Public Service Commission of Ky., dated Nov. 26, 1957