

FOR ENTIRE AREA SERVED

P.S.C. Ky. No. 1

Original Sheet No. 1

SALT RIVER RURAL ELECTRIC COOP. CORP.

Cancelling P.S.C. Ky. No. \_\_\_\_\_

Sheet No. \_\_\_\_\_

RULES AND REGULATIONS

The Company will install underground distribution lines to a residential subdivision under the following conditions:

1. The subdivision being developed must consist of a tract of land which is divided into ten (10) or more lots for the construction of new residential buildings or the land on which is constructed two (2) or more new multiple occupancy buildings (refer to PSC Electric Rules Appendix A, for definitions of terms).
2. Developer or owner of subdivision shall be required to advance to the company an amount equal to an "estimated average cost differential" if any, between the average or representative cost of underground distribution system in residential subdivisions and of equivalent overhead distribution systems within the utility service areas. If the amount deposited exceeds the normal charge for underground extensions, the amount in excess shall be refunded to the applicant over a ten (10) year period as provided in Public Service Commission Rule Elec.-1-X-3.
3. The Company will construct underground distribution facilities in the subdivision adequate to render single phase 120/240 volt service.
4. Three phase primary mains or feeders required within a subdivision to supply local distribution or to serve individual three phase loads may be overhead unless underground is required by governmental authorities or chosen by applicant, in either of which case the charges shall be made under the policy for the single phase system and to this shall be added the Company's estimate of cost for the additional facilities required for feeders or to serve the three phase loads.
5. Developer or successor in title shall grant a right-of-way satisfactory to the company for the installation, operation and maintenance of its underground facilities.
6. The service conductors from the property line to the house are to be installed, owned and maintained by the (customer, developer). The Company shall credit the applicant fifty dollars (\$50.00) or the equivalent cost of an overhead service line to the applicants meter base, whichever is greater. Service lines to house (provided by developer) shall be installed and ready for inspection at the same time as the residence. Trench is to be left open until inspection has been made.
7. For all developments that do not meet the conditions set forth in Paragraph 1 above, underground distribution will be installed provided an advance to the Company is made in an amount equal to the difference between the Company's estimated cost of underground facilities and overhead facilities, which it would otherwise provide.

*[Handwritten signature]*

PUBLIC SERVICE COMMISSION
   
 MAY 31 1973
   
 by *J.R.*
  
 ENGINEERING DIVISION

DATE OF ISSUE	<u>5</u>	<u>24</u>	<u>1973</u>	DATE EFFECTIVE	<u>June</u>	<u>7</u>	<u>1973</u>
	Month	Day	Year		Month	Day	Year

ISSUED BY	<u><i>J.R. [Signature]</i></u>	Manager	P. O. Box 130, Bardstown, Ky. 40004
	Name of Officer	Title	Address


ATTACHMENT: ADMINISTRATIVE CASE NUMBER 146  
SALT RIVER RURAL ELECTRIC COOP. CORP.

COST DIFFERENTIAL JUSTIFICATION DATA:

Salt River Rural Electric Cooperative Corporation's policy on underground distribution is to charge \$1.35 a front foot difference between underground and overhead distribution.

To date we have not done any residential underground work and do not have an accurate price differential.

376



FOR ENTIRE SERVICE AREA

P.S.C. Ky. No. 1

Original Sheet No. 2

Cancelling P.S.C. Ky. No.


Sheet No.

SALT RIVER RURAL ELECTRIC COOP. CORP.

RULES AND REGULATIONS

8. Estimated cost differential:

Where the facilities are located on front or street side of lot, a unit charge of \$1.35 per front foot will be made. This applies to where houses are to occupy both sides of the street. Where houses to be served occupy only one side of the street, the charge will be doubled. Lots running on two or more streets shall have frontage included along each street in which underground facilities are to be installed. Where rock is encountered and cannot be removed by conventional trenching machines, an additional charge of \$20.00 per cubic yard of rock removed will be made.



Handwritten signature/initials '376' over the stamp.

DATE OF ISSUE May 24 1973 DATE EFFECTIVE June 7 1973

ISSUED BY J. Braddy Manager P. O. Box 130 Hardstown, Ky. 40004