

Shelby Rural Electric

COOPERATIVE CORPORATION
P.O. BOX 309 SHELBYVILLE, KENTUCKY 40065

Telephones: Shelbyville (502) 633-4420; Bedford (502) 255-3260
New Castle (502) 845-2845

SHELBY RURAL ELECTRIC COOPERATIVE CORPORATION

ENGINEERING DEPARTMENT

January 9, 1985

Cost data were developed from construction work orders of the latest twelve (12) month period for which accounting tabulations were available and were of a comparable facilities function to develop the differential.

The results are listed for your review.

PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE

FEB 4 1985

PURSUANT TO 807 KAR 5:011,
SECTION 9 (1)

BY Jordan C. Cuel

C 1-86

SHELBY RURAL ELECTRIC COOPERATIVE CORPORATION
Shelbyville, Kentucky

Date: January 9, 1984

AVERAGE UNDERGROUND COST DIFFERENTIAL

(Filed in compliance with Appendix to the Order of the Public Service Commission
in Administrative Case Number 146, dated February 2, 1973.)

Average cost differential of Underground Primary per foot	\$3.07
Average cost differential of Underground Residential Service per foot	\$3.29

NOTE: Above prices do not include rock removal or other procedures which
may be taken to assure proper burial depth. If rock is encountered
or other procedures are taken to insure proper depth, the actual
additional cost shall apply.

PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE

JAN 9 1984

PURSUANT TO 807 KAR: 5011,
SECTION 9(1)

BY: Jordan C. Neal

e

EXHIBIT A

SHELBY RURAL ELECTRIC COOPERATIVE CORPORATION
Shelbyville, Kentucky

Date: January 14, 1982


AVERAGE UNDERGROUND COST DIFFERENTIAL

(Filed in compliance with Appendix to the Order of the Public Service Commission in Administrative Case Number 146, dated February 2, 1973.)

Average cost differential of Underground Primary per foot** \$4.66

(Average cost differential of Underground Residential Service per foot \$1.79

NOTE: Above prices do not include rock removal or other procedures which may be taken to assure proper burial depth. If rock is encountered or other procedures are taken to insure proper depth, the actual additional cost shall apply.



** Same as 1980 differential.

(No underground primary extensions were encountered in 1981.

C1-86