



**Shelby Rural Electric**

COOPERATIVE CORPORATION

PUBLIC SERVICE COMMISSION  
OF KENTUCKY  
EFFECTIVE

RECEIVED

MAY 22 1995

MAY 25 1995

PURSUANT TO 807 KAR 5:011,  
SECTION 9(1)

PUBLIC SERVICE  
COMMISSION

BY: Jordan C. Neal  
FOR THE PUBLIC SERVICE COMMISSION

Date: May 22, 1995

### AVERAGE UNDERGROUND COST DIFFERENTIAL

(Filed in compliance with 807 KAR 5:041 Section 21 (5)).

Average cost differential of UNDERGROUND PRIMARY per foot:

Option I: Cooperative to provide complete installation:  
\$9.32/foot\*.

Option II: Consumer to trench, furnish, and install all conduit and fittings, and backfill per Shelby RECC specifications. The Cooperative will then complete the installation for a charge of: \$ 259.61 for each precast or prefabricated equipment pad required to complete the installation. This does not include underground primary distribution systems for real estate developments (subdivisions, etc.).

Average cost differential of UNDERGROUND RESIDENTIAL SERVICE per foot:

Option I: Cooperative to provide complete installation for a minimum charge of \$ 275.00 plus materials for all underground services 100 feet or less in length. For underground services in excess of 100 feet, the differential cost shall be \$2.75/foot plus materials. (see attached work sheet)

Option II: Consumer to trench, install and supply conduit and backfill per Shelby RECC specification. Shelby RECC will supply conductor and other associated facilities to complete the installation: NO CHARGE.

NOTE: Above prices do not include rock removal or other procedures which may be taken to assure proper burial depth. If rock is encountered or other procedures are taken to insure proper depth, the actual additional cost shall apply.

\*SAME AS 1994 DIFFERENTIAL. NO UNDERGROUND PRIMARY EXTENSIONS WERE ENCOUNTERED IN 1994 THAT WERE REPRESENTATIVE FOR CALCULATING AN AVERAGE DIFFERENTIAL.

C 5-96