

SHELBY ENERGY COOPERATIVE
(NAME OF UTILITY)

FOR: ALL TERRITORY SERVED

PSC KY NO.	9
2nd Revised SHEET NO.	406.3
CANCELLING PSC KY NO.	9
1st Revised SHEET NO.	406.3

CANCELLED
MAR 02 2019
KENTUCKY PUBLIC SERVICE COMMISSION **DSM**

DIRECT LOAD CONTROL PROGRAM-RESIDENTIAL (continued)

TIME PERIODS FOR DIRECT LOAD CONTROL PROGRAM

Water Heaters: Existing load control switches may be electrically interrupted for a maximum time period of six (6) hours per event during the May through September months indicated below and for a maximum time period of four (4) hours per event during the October through April months indicated below.

EKPC will cycle the water heaters only during the hours listed below.

<u>Months</u>	<u>Hours Applicable for Demand Billing -EPT</u>
October through April	6:00 a.m. to 12:00 noon 4:00 p.m. to 10:00 p.m.
May through September	10:00 a.m. to 10:00 p.m.

Air Conditioners and Heat Pumps: A load control device (switch or Wi-Fi enabled thermostat) will be placed on each central air conditioning unit or heat pump that will allow the operating characteristics of the unit to be modified to reduce demand on the system. Communication to the load control device will be accomplished via AMR, AMI or Wi-Fi or similar communication technologies.

EKPC will control the air conditioning units and heat pumps only during its summer on-peak billing hours listed below and up to (4) four hours per event.

Hours Applicable for Demand Billing - EPT
10:00 a.m. to 10:00 p.m.

DATE OF ISSUE January 30, 2019
MONTH / DATE / YEAR

DATE EFFECTIVE March 2, 2019
MONTH / DATE / YEAR

ISSUED BY [Signature]
SIGNATURE OF OFFICER

TITLE President & CEO

BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE COMMISSION

IN CASE NO. 2019-00060 DATED: November 26, 2019

**KENTUCKY
PUBLIC SERVICE COMMISSION**

Gwen R. Pinson
Executive Director

Gwen R. Pinson

EFFECTIVE
3/2/2019
PURSUANT TO 807 KAR 5:011 SECTION 9 (1)