

FOR ALL TERRITORY SERVED

P.S.C. KY No.

Sheet No. 67

TAYLOR COUNTY RURAL ELECTRIC  
COOPERATIVE CORPORATION

Cancelling P.S.C. No.

Sheet No.

RULES AND REGULATIONS

VOLUNTARY LOAD REDUCTION PROCEDURE

OBJECTIVE:

To reduce demand on Taylor County RECC's system over the period during which an electric energy shortage is anticipated through media appeal for consumers to curtail energy use.

CRITERIA:

This procedure is implemented when requested by EKPC Marketing and Communications Division personnel.

PROCEDURE:

Notify the following radio and television stations WAIN, Columbia; WGRK, Greensburg; WKDO, Liberty; WVLC, Campbellsville; WCKQ, Campbellsville; WGRB, Campbellsville of the electrical energy shortage and ask them to make the public service announcement recommended by EKPC personnel. An example announcement is as follows:

"Attention all Rural Electric Memebers:

Taylor County RECC is experiencing a critical shortage of electricity to its members, and is requesting that all non-essential electrical appliances and lighting be turned off, and thermostats be lowered/raised immediately until (time of emergency).

The cooperative is encountering record high usage of electricity during this period of extreme low/high temperatures, and to help us keep from having a power blackout in your area, we need your help NOW until (time of emergency).  
PUBLIC SERVICE COMMISSION  
EFFECTIVE

Please turn off all electricity you do not have to have on.

Thank you for your cooperation."

MAR 18 1996

PURSUANT TO 807 KAR 5:011,  
SECTION 9(1)

DATE OF ISSUE March 15, 1995

DATE EFFECTIVE March 18, 1996

BY: Andrew E. Neal  
FOR THE PUBLIC SERVICE COMMISSION

P. O. Bcx. 100

ISSUED BY Benny L. Byer Manager,  
(Name of Officer) (Title)

Campbellsville, KY 42719  
(Address)

C 3-96

FOR ALL TERRITORY SERVED

P.S.C. KY No.

Sheet No. 68

TAYLOR COUNTY RURAL ELECTRIC  
COOPERATIVE CORPORATION

Cancelling P.S.C. No.

Sheet No.

RULES AND REGULATIONS

MANDATORY LOAD CURTAILMENT PROCEDURE

OBJECTIVE

To reduce demand on the cooperative system over the period during which an electric energy shortage is anticipated by interrupting firm consumer load in 5% blocks up to a total of 20% of the system load.

CRITERIA:

This procedure is implemented when requested by the EKPC System Operator. This procedure will only be requested after the Governor of Kentucky has issued a statewide State of Emergency Order.

PROCEDURES:

The cooperative will immediately dispatch personnel to interrupt service to member consumer loads to achieve the reduction requested by EKPC. This may be achieved by interrupting services to certain nonessential loads for the entire period of the emergency or by rotating outages to various substation feeder circuits. The cooperative's specific plan is on file in it's office.

PUBLIC SERVICE COMMISSION  
OF KENTUCKY  
EFFECTIVE

MAR 18 1996

PURSUANT TO 807 KAR 5:011,  
SECTION 9(1)

BY: Jordan C. Neel  
FOR THE PUBLIC SERVICE COMMISSION

DATE OF ISSUE March 15, 1995 DATE EFFECTIVE March 18, 1996

ISSUED BY Barry L. New Manager, P. O. Box 100  
(Name of Officer) (Title) Campbellsville, KY 42719  
(Address)

C3-96