

SECTION X – METER LOCATION AND REQUIREMENTS

1. Where a meter is located within a building, it shall be the responsibility of the customer to maintain appropriate conditions to prevent physical or freezing damage to the meter. Meters shall be accessible to the District during normal business hours. If normal access to the meter is refused, the District shall require the meter be moved outside and all cost incurred shall be borne by the customer. If the customer fails to provide access to move the meter outside after 30 days written notice from the District, water service shall be disconnected for failure to allow access as required by the District’s Rules and Regulations and not turned on until the meter is moved outside. Should the meter be damaged, the District will replace the meter at a charge of the cost of the meter and time and material, and the customer will be billed per the District’s Invoice Billing Policy. If the customer fails to pay the invoice by the stated date, water service will be discontinued until payment is received. The customer will also be required to pay the service charge as outlined in Section IV.
2. Where the meter is located within a building, the District’s responsibility is the meter and meter connection nut only, and at no time will the District be responsible for any piping making connection to the meter.

SECTION XI – METER TEST

1. All District meters will be tested at least every ten years as required by the Public Service Commission.
2. The meter testing procedure and equipment will conform and be in accordance with all regulations set by the Public Service Commission.
3. Meters will be removed and tested for accuracy when requested by any customer provided that the customer or a representative of the customer accompanies the meter to the District testing location to witness the test or the customer fills out the form stating they do not want to witness the test. This form must be submitted to the office before the test is done. If the meter is within the allowable + or – 2% accuracy, the customer will be charged for the cost of the test. For a 1" meter or smaller, the charge is \$30.00 per test. For meters larger than 1", the charge is the actual cost to the District for the test. In the event the meter accuracy varies more than two percent, the cost of the testing shall be borne by the District and a new or reconditioned meter will be installed at no cost to the customer. If the meter is more than two percent fast, a refund shall be computed on the basis of the percentage fast that the meter tested for a period not exceeding the previous 12 months.

CANCELLED

August 29, 2019

**KENTUCKY PUBLIC
SERVICE COMMISSION**

**KENTUCKY
PUBLIC SERVICE COMMISSION**

**JEFF R. DEROUEN
EXECUTIVE DIRECTOR**

TARIFF BRANCH

Date Effective: January *Brent Kirtley*


2835 Crescent Springs Road, Erlanger, KY 41018

**EFFECTIVE
1/7/2011**

PURSUANT TO 807 KAR 5:011 SECTION 9 (1)

Date of Issue: June 4, 2010

Date Effective: January

Issued by: 
Officer & Title Jack Bragg, Jr. CPA, CMA
Vice President - Finance

2835 Crescent Springs Road, Erlanger, KY 41018