

**SECTION XVIII-A – POLICY FOR INSTALLATION OF PUBLIC  
FIRE HYDRANTS ON UPGRADED AND NEW DISTRIBUTION MAINS**

For distribution main replacement projects, which involve replacement of existing distribution mains that currently do not have any fire hydrants or have a limited number of fire hydrants, the following procedures shall be used:

1. Existing fire hydrants will be replaced in the approximate same location, unless the local fire department or city requests relocation and the adjacent property owners to the existing fire hydrant agree, in writing, to the relocation.
2. Anchoring tees and valves may be installed along the water main project at approximately 450' – 500' intervals for future fire hydrant installations.
3. New fire hydrants may be installed at the District's expense for flushing purposes and at high points in the main for air releases, depending on hydrant spacing and as determined by the District.
4. Additional fire hydrants may be installed if the property owners, local fire departments and/or cities wish to pay the cost of such hydrants. (Fire protection districts, under KRS 75.080 may install fire hydrants and apportion the costs of the installation against the owners of the property fronting the public ways in which the fire hydrants are installed.)

**CANCELLED**

August 29, 2019

**KENTUCKY PUBLIC  
SERVICE COMMISSION**

**KENTUCKY  
PUBLIC SERVICE COMMISSION**

**JEFF R. DEROUEN  
EXECUTIVE DIRECTOR**


TARIFF BRANCH

Date Effective: January *Brent Kirtley*

EFFECTIVE  
**1/7/2011**

PURSUANT TO 807 KAR 5:011 SECTION 9 (1)

Date of Issue: June 4, 2010

Issued by:   
 Officer & Title Jack Bragg, Jr. CPA, CMA  
 Vice President - Finance

Date Effective: January *Brent Kirtley*  
 2835 Crescent Springs Road, Erlanger, KY 41018