	Community, Town or City
	P.S.C. KY. NO.
1 Constitution to entire talk argumentation (assemble on the second	Original SHEET NO. 41
South Anderson Water District (Name of Utility)	CANCELING P.S.C. KY. NO.
(Name of Curity)	SHEET NO
(Name of Othiny)	SHEET NO
R	ULES AND REGULATIONS

AA. <u>Fire Departments</u>. For the purpose of off-setting fifty percent or more of its operation expenses, any fire department not receiving public funds from the Commonwealth of Kentucky, or any political subdivision thereof, may withdraw water from the utility's facilities at no charge, for the extinguishing of fires or the training of firemen. A fire department making such withdrawals shall provide an estimate of its withdrawals to the utility at the end of each month.

AB. Fire Hydrants:

- 1. In accordance with 807 KAR 5:066 Section 10(2)(b), a new fire hydrant will not be installed unless:
 - a) A professional engineer with a Kentucky registration has certified that the system can provide a minimum fire flow of 250 gallons per minute, and
 - b) The system supporting this flow has the capability of providing this flow for a period of not less than two (2) hours plus consumption at the maximum daily rate.
- 2. The location, installation, and the responsibility for maintenance of fire hydrants, public and private fire protection facilities, connecting mains, and their ownership may be subject to negotiation between the utility and the applicant/customer. Fire hydrants and public and private fire protection facilities shall be installed as required by the utility and if owned by the utility shall be subject to any conditions the Public Service Commission may impose, based upon the compensation received for this service.

CANCELLED

CCT 1 1 2014

KENTUCKY PUBLIC SERVICE COMMISSION

DATE OF ISSUE Month / Date / Year	
ISSUED BY Gold (Signature of Officer) TITLE Chairman	PUBLIC SERVICE COMMISSION OF KENTUCKY EFFECTIVE 5/28/2005 PURSUANT TO 807 KAR 5:011 SECTION 9 (1)
BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE COMMISSION IN CASE NO. 2004-00525 DATED	By Executive Director