

FOR Western Fleming County
Community, Town or City

P.S.C. KY. NO. 1

Original SHEET NO. 42

Western Fleming Co. Water District
(Name of Utility)

CANCELLING P.S.C. KY. NO. _____

_____ SHEET NO. _____

RULES AND REGULATIONS

flow rate or pressure. The fire flow may cannot guarantee a water supply at any particular flow rate or pressure. The fire flow may vary depending upon other water demands on the system, various water facility limitations, or other circumstances. The customer will indemnify and hold harmless the utility and its employees from and against all claims, damages, losses, and expenses incurred as a result of insufficient water supply or deficient system facilities.

C
5/19/2010
~~AA. Fire Departments. For the purpose of off setting fifty percent or more of its operation expenses, any fire department not receiving public funds from the Commonwealth of Kentucky, or any political subdivision thereof may withdraw water from the utility's facilities at no charge, for the extinguishing of fires or the training of firemen. A fire department making such withdrawals shall provide an estimate of its withdrawals to the utility at the end of each month.~~

AB. Fire Hydrants:

1. In accordance with 807 KAR 5:066 Section 10(2)(b), a new fire hydrant will not be installed unless:

- a) A professional engineer with a Kentucky registration has certified that the system can provide a minimum fire flow of 250 gallons per minute, and
- b) The system supporting this flow has the capability of providing this flow for a period of not less than two (2) hours plus consumption at the maximum daily rate.

DATE OF ISSUE _____

Month/Date/Year

DATE EFFECTIVE _____

Month/Date/Year

ISSUED BY Jerry Neal

(Signature of Officer)

TITLE Chairman

PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE

MAY 01 2002

PURSUANT TO 807 KAR 5:011.
SECTION 9 (1)

BY: Stephan Bee
SECRETARY OF THE COMMISSION

BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE COMMISSION
IN CASE NO. _____ DATED _____