

FOR GREEN VALLEY WATER DISTRICT

P.S.C. Ky. No. 2

original Sheet No. 6

Cancelling P.S.C. Ky. No. _____

Sheet No. _____

Green River Valley W.D.

RULES AND REGULATIONS

1. Fire hydrants:

The District would only install fire hydrants on six inch (6") lines or larger lines. Water hydrants installed on four inch (4") lines or smaller lines will be for flushing purposes only and shall not be used as a fire hydrant. The District is not in the fire protection business.

2. Fire department damage:

The District shall not be responsible for any damage caused to its water lines by a fire truck or any fire department.

3. First 50 feet of main:

The District shall install the first fifty feet (50') of main for each customer on each water line and the customer shall pay the remainder of any cost for any other extension of the water line.

**PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE**

JUL 01 1987

**PURSUANT TO 807 KAR 5:011,
SECTION 9 (1)**

**BY: Sharon Miller
PUBLIC SERVICE COMMISSION MANAGER**

DATE OF ISSUE July 1 1987
Month Day Year

DATE EFFECTIVE July 1 1987
Month Day Year

ISSUED BY Sharon Miller
Name of Officer

Manager Box 399, Cave City, KY 42127
Title Address

C12-87