



AREA McCreary County, Ky

PSC KY NO. 4

Original SHEET NO. 19

CANCELLING PSC KY NO. \_\_\_\_\_

\_\_\_\_\_ SHEET NO. \_\_\_\_\_

McCreary County Water District  
**KENTUCKY PUBLIC SERVICE COMMISSION**

**RULES AND REGULATIONS**

for periodic tests or for repairs or replacement and may, at its option and expense, test any Meter when the District has reason to believe that it is registering inaccurately. (N)

f. The District shall test any Meter upon a Customer’s written request if the request is not made more frequently than once each twelve (12) months. The Customer shall be given the opportunity to be present at the requested test. The Customer will be charged a fee of \$12.50 if the said Meter be found less than two percent incorrect to the prejudice of the Customer. (T)

g. The District reserves the right to put seals on any water Meter, or on couplings in and for any premises, and may shut off the supply if such seals are found broken or removed. (N)

h. After meter placement, a Customer may request a change in the meter’s location. The District will relocate the Meter at the Customer’s expense if the location is acceptable. (N)

i. Meters must be located in a utility easement or public right-of-way. (N)

j. Meters may be located either in an outdoor Meter box or vault, at the option of the District. The location of the Meter must be acceptable to the District and allow for the Meter to be easily examined, tested, repaired, read, removed or replaced. The Meter box or vault shall be located in a convenient and readily accessible location acceptable to the District. The Meter box or vault must be constructed to protect the Meter from freezing and damage by vehicular traffic, and its location and design shall prevent, as far as possible, the inflow of surface water. After the District installs a Meter, a Customer shall not tamper with, alter, repair or remove the Meter or allow anyone other than the District to do so. Any plumbing, piping, grading or structural modification which could result in the relocation of the Meter or impact accessibility must first be approved by the District. (N)

k. The point of delivery is at the meter or vault. Customer is responsible for installation and maintenance of all water lines, plumbing and equipment beyond the meter. (N)

DATE OF ISSUE April 3, 2023  
MONTH / DATE / YEAR  
DATE EFFECTIVE March 22, 2023  
MONTH / DATE / YEAR  
ISSUED BY /s/Randy Kidd  
SIGNATURE OF OFFICER  
TITLE Chairman

BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE COMMISSION IN CASE NO. 2022-00336 DATED March 22, 2023

