

HENDERSON-UNION RURAL ELECTRIC
COOPERATIVE CORPORATION

Name of Issuing Corporation

FOR All Territory Served

P.S.C. Ky. No. 6

Fourth Revised Sheet No. 10

Cancelling P.S.C. Ky. No. 5

Third Revised Sheet No. 10

RULES AND REGULATIONS

and service conductor to be installed at an average per foot cost differential in accordance with the Average Cost Differential filed herewith as Exhibit "A", which Average Cost Differential shall be updated annually as required by order dated February 2, 1973 of the Public Service Commission of Kentucky in Administrative Case No. 146. (Three (3) wire secondary and service conductor runs shall be considered as one conductor, i.e. triplex). The average cost differential per foot, as stated, is representative of construction in soil free of rock, shale, or other impairments which are anticipated or encountered in construction, the actual increased cost of trenching and backfilling shall be borne by the Applicant.

- (f) The Applicant may be required to deposit the entire estimated cost of the extension. If this is done, the amount deposited in excess of the normal charge for the underground extensions, as provided in paragraph "e" above, shall be refunded to the applicant over a ten (10) year period as provided (T) in 807 KAR 5 :041 Section 21 (d).
- (g) The Applicant may be required to perform all necessary trenching and backfilling in accordance with the Cooperative's specifications. The Cooperative shall then credit the applicant's cost in an amount equal to the Cooperative's normal cost for trenching and backfilling.
- (h) The Cooperative shall furnish, install and maintain the service lateral to the Applicant's meter base (which normally will be at the corner of the building nearest the point to be served) except that the Applicant shall furnish and install proper size conduit from the meter base to two (2) feet below ground level. The Cooperative will install twenty (20) foot section of proper size conduit (metal or PVC) from Applicant's below grade conduit termination, back toward source.

EXHIBIT "A"

INSTALLATION OF UNDERGROUND DISTRIBUTION SYSTEM-SUBDIVISIONS

Single Phase, Loop Feed		PUBLIC SERVICE COMMISSION OF KENTUCKY EFFECTIVE
Estimated Cost per foot Underground	\$4.00	JUL 15 1985
Estimated Cost per foot Overhead	\$2.50	PURSUANT TO 807 KAR 5:011, SECTION 9 (c)
Cost Differential per foot	\$1.50	BY: <i>J. Grogan</i>

DATE OF ISSUE	November	30	1981	DATE EFFECTIVE	December	20	1981
	Month	Day	Year		Month	Day	Year
ISSUED BY	<i>John West</i>			Manager	P. O. Box 18, Henderson, KY 42420		
	Name of Officer			Title	Address		

C5-86

FOR All Territory Served

P.S.C. Ky. No. 6

Second Revised Sheet No. 13

Cancelling P.S.C. Ky. No. 5

First Revised Sheet No. 13

HENDERSON-UNION RURAL
COOPERATIVE CORPORATION

Name of Issuing Corporation

RULES AND REGULATIONS

If the consumer insists on a voltage requiring a delta connected transformer the consumer will be required to pay for the equipment required to avoid ferroresonance, such as (1) 3Ø OCR, (2) gang operated air break switch at riser pole, or (3) dummy loads.

23. HOUSE WIRING AND INSPECTION

Standards. All wiring of consumers' premises must conform with the requirements of the National Electric Code and Henderson-Union Rural Electric Cooperative Corporation.

Inspections. Inspections of all permanent wiring installations which have not previously had service should be required prior to energizing. If energization is made prior to inspection, Temporary Release Form shall be signed by the owner and wiring contractor.

Additions to the consumers' wiring should be inspected, and it shall be the consumers' responsibility to report such additions to the Cooperative.

PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE

JUL 15 1985

Fees:

PURSUANT TO 807 KAR 5-011,

SECTION 9.01

BY *J. Geoghegan*

1. Time of Payment

- (a) New Service-Inspection fee shall be paid with application for service or at the time of issuance of meter base.
- (b) Additional wiring-Inspection fee shall be paid at the time of consumer's report to the Cooperative of the proposed addition.

2. Residential and Farm:

- (a) 100-amp, or less, service complete with branch circuits \$20.00
- (b) 200-amp service complete with branch circuits \$30.00
- (c) 400-amp service complete with branch circuits \$35.00
- (d) Services above 400-amp will be 15¢ per amp
- (e) Additional wiring which does not require change in service entrance equipment \$10.00

If it is necessary to change out service entrance equipment the schedule above shall apply.

In determining the fee for an installation involving a meter pole, the meter pole shall govern the inspection fee. (Initial installation only.)

DATE OF ISSUE	November	30	1981	DATE EFFECTIVE	December	20	1981
	Month	Day	Year		Month	Day	Year
ISSUED BY	<i>John West</i>			Manager	P. O. Box 18, Henderson, KY 42420		
	Name of Officer			Title	Address		

C5-86

**SOUTH KENTUCKY RECC
SOMERSET, KENTUCKY 42501**

APPENDIX A OF P.S.C. KENTUCKY NO. 5

A Sub-division of which 113 lots are served Underground.

The line designed at 7.2 KV Primary voltage, using loop feed:

Underground Cost per Foot	\$8.78
Overhead Cost per Foot	2.70
	<hr/>
Average Cost Differential	<u>\$6.08</u>

Underground Cost Computation

	<u>Footage</u>	<u>Material</u>	<u>Estimated: Trench, Sand Backfill, Backhoe</u>	<u>Initial Labor & Overhead</u>	<u>Total Cost</u>
Job					
Totals	33,518	\$95,861.48	\$69,294.93	\$129,044.30	\$294,200.71
Cost Per					
Foot		2.86	2.07	3.85	8.78

TYPICAL ROCK CLAUSE: An additional \$47.67 per linear trench foot shall be charged where extreme rock conditions are encountered, such conditions being defined as limestone or other hard stratified material in a continuous volume of at least one cubic yard or more which cannot be removed using ordinary excavation equipment.

PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE

MAY 01 1985

PURSUANT TO 807 KAR 5:011,
SECTION 9 (1)
BY: Jordan C. Neel

DATE OF ISSUE APRIL 26, 1985 DATE EFFECTIVE MAY 1, 1985
Month Day Year Month Day Year

ISSUED BY J. Keith Sloan President P.O. Box 910 Somerset, KY
Name of Officer Title Address

C5-86