

## RULES AND REGULATIONS GOVERNING THE SUPPLY OF ELECTRIC SERVICE

Special Terms and Conditions Governing the Supply of  
Reserve, Breakdown, Standby or Auxiliary Service

All reserve, breakdown, standby or auxiliary service furnished by the Company to commercial and industrial customers whose premises or equipment are regularly supplied with electric energy from a private generating plant shall be subject to the following special terms and conditions:

1. Contract Demand. Customer shall contract for a specified maximum kilowatt capacity based on an adequate and acceptable estimate of his prospective maximum service requirements as indicated by such factors as connected load, largest unit of equipment to be served, size of largest generating unit, required transformer capacity, previously recorded demands or test demands under full load conditions, etc. The maximum capacity thus contracted for, which in no case shall be for less than 10 kilowatts, will be checked by means of a suitable demand meter to be installed by the Company. In the event that the highest average load in kilowatts recorded in any fifteen minute interval by such demand meter exceeds the previously established or original contract demand, then such higher recorded demand shall automatically become the new contract demand commencing with the month in which it was recorded and continuing until superseded by a higher demand.

2. Metering. Metering and billing for reserve, breakdown, standby or auxiliary service shall be kept separate and distinct from the metering or billing for any regular service supplied exclusively by the Company at the same location. Each separate meter used to measure reserve, breakdown, standby or auxiliary service will be considered and billed as a separate customer, but customer has the option of arranging his wiring so as to permit the Company to supply all such service, whether used for lighting, power, or combined light and power purposes, through a single meter. Customer shall furnish and maintain any transformation or voltage regulatory equipment which may be necessary for lighting purposes when service is delivered at power voltage.

3. Rates. Reserve, breakdown, standby or auxiliary service will be supplied only under the Company's standard rate schedules GP, LC, and LP. In the case of loads involving maximum demands of not to exceed 200 kilowatts, customer may elect to take service under Rate GP or under Rate LC or LP, depending on the suitability and applicability of each of these rates for the class and character of the service to be supplied. Loads involving maximum demands in excess of 200 kilowatts will not be served under Rate GP and must be taken under appropriate Rate LC or LP.

In no case shall the monthly billing demand used in the determination of demand charges under Rates LC and LP be taken as less than 50% of the customer's original or subsequently established contract demand.

Issued by authority of an order of the PSC of Ky. in Case 3300, dated Nov. 26, 1957

DATE OF ISSUE May 1, 1962 DATE EFFECTIVE May 20, 1962  
ISSUED BY G. R. Armstrong President Louisville, Ky.  
NAME TITLE ADDRESS