## LOUISVILLE GAS AND ELECTRIC COMPANY

8th	Rev.	SHEET NO	29
CANCELLING 7th	Rev.		29

P.S.C. OF KY, ELECTRIC NO. 4

RULES AND REGULATIONS GOVERNING THE SUPPLY OF ELECTRIC SERVICE

Underground Electric Extension Rules for New Residential Subdivisions

The Company will install underground electric distribution facilities within new residential subdivisions in accordance with its standard policies and procedures and the rules of the Public Service Commission of Kentucky applicable thereto (807 KAR 5:041E, Section 21, Electric) under the following conditions:

- These rules shall apply only to 120/240 volt, single phase service to:
- (a) Residential subdivisions containing ten or more lots for the construction of new residential buildings designed for less than five-family occupancy.
- (b) High density, multiple-occupancy residential building projects consisting of two or more buildings not more than three stories above grade level and containing not less than five family units per building.
- 2. When an Applicant has complied with these rules and with the applicable rules of the Public Service Commission, and has given the Company at least 120 days' written notice prior to the anticipated date of completion (i.e., ready for occupancy) of the first building in the subdivision, the Company will undertake to complete the installation of its facilities at least 30 days prior to such estimated date of completion. However, nothing herein shall be interpreted to require the Company to extend service to portions of subdivisions not under active development.
- 3. Any Applicant for underground distribution facilities to a residential subdivision, as described in Paragraph 1(a) above, shall pay to the Company, in addition to such refundable deposits as may be required in accordance with Paragraph 5 below, a unit charge of \$1.98 per aggregate lot front foot along all streets contiguous to the lots to be served underground. Such Mayment shall be non-refundable.
  - The Convery will install underground single-phase facilities to

4. The Company will install underground single-phase facilities to where the projects will install underground single-phase facilities to where the projects as follows:

(a) O the part such projects have a density of not less than eight whits part where a refundable deposit way be required in accordance with Paragraph 5 below.

(b) Where such buildings are widely separated and have a density of less than eight family units per acre, at a cost to the Applicant equivalent to the difference between the actual cost of constructing the

puber 12, 1990 DATE EFFECTIVE January 12, 1991 DATE OF ISSUE\_ Vice President David R. Carey Marketing & Planning Louisville, Kentucky ISSUED BY\_

	9th	Rev.	_SHEET	NO	30
CANCELLING.					30

P.S.C. OF KY. ELECTRIC NO. 4

RULES AND REGULATIONS GOVERNING THE SUPPLY OF ELECTRIC SERVICE

Underground Electric Extension Rules for New Residential Subdivisions (Cont'd)

underground distribution system and the Company's estimated cost for construction of an equivalent overhead distribution system, the latter including an allowance of not less than \$50 per service drop required. Such payment shall be non-refundable.

- 5. The Applicant may be required to advance to the Company the full estimated cost of construction of its underground electric distribution extension. This advance, to the extent it exceeds the non-refundable charges set forth above, shall be subject to refund.
- (a) In the case of residential subdivisions, this advance, if required, shall be calculated at a unit charge of \$8.01 per aggregate front-foot and the refund shall be made, on the basis of 2000 times the amount by which such unit charge advance exceeds the non-refundable unit charge set forth in Paragraph 3 above, for each permanent customer connected to the underground distribution system during the ten year period following the date such advance is made.
- (b) In the case of high-density, multiple-occupancy residential building projects, this advance, if required, shall be based on construction costs for the project as estimated by the Company and shall be refunded, to the extent such advance exceeds any non-refundable charges applicable, when permanent service is commenced to 20 percent of the family units in the project, provided such conditions are met within ten years following the date such advance is made.
- (c) In no case shall the refunds provided for herein exceed the amounts deposited less those non-refundable charges applicable to the project.
- Applicant performs the trenching and/or backfilling in accordance with the Company is specifications, the Company will credit the Applicant's costs in an Applicant to the Company's estimated cost for such trenching and/or backfilling. Which credit will be based on the system as actually designed and constructed.
- backfilling. Such creuse and conscribed and conscribed and equipment of contract between an Applicant and the Company for an underground extension under these rules shall ordinarily be required at least six months pictor to the date service in the subdivision is needed. The Applicant shall advance not less than 10% of the amounts due under the said contract at the time of its execution. The remaining amounts due shall be

DATE OF ISSUE

ecomber 12, 1990

Vice President

January 12, 1991

ISSUED BY\_\_

avid R. Car

Marketing and Planning

Louisville, Kentucky

ADDRESS

Issued by authority of an Order of the PSC of Ky. in Adm. Case No. 146 dated 2/2/73.

PUBLIC SERVICE COMMISSION OF KENTUCKY