

# Louisville Gas and Electric Company

Original Sheet No. 61  
P.S.C. of Ky. Electric No. 6

## ELECTRIC RIDER

LRI

### Experimental Load Reduction Incentive Rider

#### APPLICABLE

In all territory served.

#### AVAILABILITY OF SERVICE

This schedule shall be made available as a rider to any customer served on the Company's standard tariffs, having stand-by generation facilities of at least 500 kW, and agreeing to operate such facilities in accordance with the terms and conditions of this tariff. Service under this schedule is offered on an experimental basis for a period of six years from the effective date of August 1, 2000, for a total maximum contracted load of 10,000 kW.

#### RATE

Up to \$0.30 per KWH

#### TERMS AND CONDITIONS


- 1) Company will have the option to require Customer to operate Customer's stand-by generation to replace Customer's electric usage. Such period of generation shall not exceed 8 hours in any 24-hour period nor shall the total hours of generation in any 12-month period exceed 300 hours.
- 2) Should Company request Customer to operate Customer's stand-by generation, Company will notify Customer by 12 noon on a day ahead basis.
- 3) Company's request for Customer to operate Customer's stand-by generation will include an offer of a payment per KWH for Customer to operate Customer's stand-by generation.
- 4) Customer is obligated to operate Customer's stand-by generation should Customer accept the Company's offered price.
- 5) Customer's stand-by generation shall not be operated in parallel with Company's system (i.e., such generation shall be connected to circuits which are isolated from Company's system).
- 6) Customer will be responsible for maintaining Customer's stand-by generation, including an adequate fuel supply, to ensure meeting Customer's obligation under this schedule.
- 7) Company will meter the output of Customer's stand-by generation, base the payment for Customer reducing load on the metered output, and provide payment to Customer through a credit to Customer's standard service billing.
- 8) Customer may provide Company with the option to install equipment that will permit Company to remotely start stand-by generation and switch circuits to such generation so that they are isolated from Company's system.
- 9) Company has no obligation to request operation of Customer's stand-by generation nor to provide any credit to Customer without first requesting Customer to provide stand-by generation.

#### TERM OF CONTRACT

The minimum term of contract shall be for one year and thereafter until terminated by either party giving at least six months written notice. Company may require a longer initial term when deemed necessary. Failure of Customer to operate stand-by generation may result in termination of contract.

Date of Issue: June 30, 2004

Issued By

  
Michael S. Beer, Vice President  
Louisville, Kentucky

Date Effective: August 1, 2000  
July 20, 2004

Executive Director

Issued By Authority of an Order of the KPSC in Case No. 2003-00433 dated June 30, 2004

**CANCELLED**  
**FEB 06 2009**  
KENTUCKY PUBLIC  
SERVICE COMMISSION

PUBLIC SERVICE COMMISSION  
OF KENTUCKY  
EFFECTIVE  
7/1/2004  
PURSUANT TO 807 KAR 5:011  
SECTION 9 (1)