

Terms and Conditions Residential Rate Specific Terms and Conditions

Residential electric service is available for uses customarily associated with residential occupation, including lighting, cooking, heating, cooling, refrigeration, household appliances, and other domestic purposes.

1. **DEFINITION OF RESIDENTIAL RATE** - Residential rates are based on service to single family units served through a single meter. Such service may include incidental usage of electricity for home occupations, such as the office of a physician, surgeon, dentist, musician or artist when such occupation is practiced by Customer in his residence. Service to both a single family unit and a detached structure may both be served through a single meter, regardless of the meter location, and qualify for the residential service provided the consumption in the non-residential portion of the detached structure is incidental.
2. **DEFINITION OF SINGLE FAMILY UNIT** - A single family unit is a structure or part of a structure used or intended to be used as a home, residence, or sleeping place by one or more persons maintaining a common household. Residential service is not available to transient multi-family structures including, but not limited to, hotels, motels, studio apartments, college dormitories, separately metered vacation rentals, boat slips, campers, or any structure without a permanent foundation or attached to sanitation facilities. Fraternity or sorority organizations associated with educational institutions may be classified as residential and billed at the residential rate.
3. **DETACHED STRUCTURES** - If Customer has detached structures that are located at such distance from Customer's residence as to make it impracticable to supply service through customer's residential meter, the separate meter required to measure service to the detached structures will be considered a separate service and billed as a separate customer.
4. **POWER REQUIREMENT** - Single-phase power service used for domestic purposes will be permitted under Residential Rates RS, RTOD-Energy, and RTOD-Demand when measured through the residential meter subject to the conditions set forth below:
 - a. Single-phase motors may be served at 120 volts if the locked-rotor current at rated voltage does not exceed 50 amperes. Motors with locked-rotor current ratings in excess of 50 amperes must be served at 240 volts.
 - b. Single-phase motors of new central residential cooling installations with total locked-rotor ratings of not to exceed 125 amperes (inclusive of any auxiliary motors arranged for simultaneous starting with the compressor) may be connected for across-the-line starting provided the available capacity of Company's electric distribution facilities at desired point of supply is such that, in Company's judgment, the starting of such motors will not result in excessive voltage dips and undue disturbance of lighting service and television reception of

CANCELLED

DATE OF ISSUE: July 20, 2021

February 16, 2026

DATE EFFECTIVE: With Service Rendered
On and After July 1, 2021

**KENTUCKY PUBLIC
SERVICE COMMISSION**

ISSUED BY: /s/ Robert M. Conroy, Vice President
State Regulation and Rates
Louisville, Kentucky

Issued by Authority of an Order of the
Public Service Commission in Case No.
2020-00350 dated June 30, 2021

**KENTUCKY
PUBLIC SERVICE COMMISSION**

Linda C. Bridwell
Executive Director



EFFECTIVE

7/1/2021

PURSUANT TO 807 KAR 5:011 SECTION 9 (1)

Louisville Gas and Electric Company

P.S.C. Electric No. 13, Original Sheet No. 100.1

Terms and Conditions Residential Rate Specific Terms and Conditions

nearby electric Customers. However, except with Company's express written consent, no new single-phase central residential cooling unit having a total lock-rotor rating in excess of 125 amperes inclusive of auxiliary motors arranged for simultaneous starting with the compressor) shall hereafter be connected to Company's lines, or be eligible for electric service therefrom, unless it is equipped with an approved type of current-limiting device for starting which will reduce the initial and incremental starting current inrush to a maximum of 100 amperes per step. Company shall be furnished with reasonable advance notice of any proposed central residential cooling installation.

- c. In the case of multi-motored devices arranged for sequential starting of the motors, the above rules are considered to apply to the locked-rotor currents of the individual motors; if arranged for simultaneous starting of the motors, the rules apply to the sum of the locked-rotor currents of all motors so started.
- d. Any motor or motors served through a separate meter will be billed as a separate Customer.

CANCELLED

February 16, 2026

**KENTUCKY PUBLIC
SERVICE COMMISSION**

DATE OF ISSUE: July 20, 2021


DATE EFFECTIVE: With Service Rendered
On and After July 1, 2015

ISSUED BY: /s/ Robert M. Conroy, Vice President
State Regulation and Rates
Louisville, Kentucky

**Issued by Authority of an Order of the
Public Service Commission in Case No.
2014-00372 dated June 30, 2015**

**KENTUCKY
PUBLIC SERVICE COMMISSION**

Linda C. Bridwell
Executive Director



EFFECTIVE

7/1/2021

PURSUANT TO 807 KAR 5:011 SECTION 9 (1)