

Nolin RECC
411 Ring Road
Elizabethtown, KY 42701-6767

PSC KY NO. 10
2nd Revision Sheet No. 8

CANCELING PSC KY NO. 10
1st Revision Sheet No. 8

RULES AND REGULATIONS

18. ELECTRICAL REQUIREMENTS AND INSPECTIONS FOR ALL MEMBERS (Cont'd)

entrance which shall be dug to a depth of forty-two (42") inches from the final grade. Furnish, own and install schedule forty (40) electrical PVC conduit per Nolin specifications as required from the meter base to the pole extending one (1') foot above final grade. Should the member desire, the Cooperative will perform or have performed by an outside contractor, all trenching and backfilling and PVC pipe installation provided member agrees to reimburse the Cooperative for actual expenses occurred. Exception to the underground service requirement must be made in writing to Nolin RECC. Variance request may be approved in areas where trench depth is not obtainable, extreme terrain conditions or manmade obstacles exist. Variance to the underground service may be granted only after meeting with the member and viewing the obstacle.

- (T) 4. In the event an exception to the underground policy is granted to allow overhead service, the height of the weatherhead or eye bolt shall be not less than twelve (12') feet above final grade on residences, and for trailers or mobile homes the weatherhead or eye bolt shall be installed within twelve (12") inches of the pole top. Minimum height above grade for pole is fifteen (15') feet. For commercial buildings, the height and location shall be determined by the contract and power line location. No weatherheads to be installed in excess of thirty (30') feet.

19. SERVICE CONNECTION

The Cooperative shall furnish without charge a service drop to the point closest to the existing line. When the members outlet is inaccessible, or the member desires that the service outlet be in a location other than the closest to the Cooperatives lines, the cost of such special construction shall be borne by the member. The distance to nearest point of attachment shall then be subtracted from the special construction distance and the member shall pay for the difference in advance. This applies to both overhead and underground services. Approval shall be obtained from the Cooperative as to the proper location.

C. Meters

20. METER TEST

All new meters shall be checked for accuracy before installation. The Cooperative will, at its own expense, make periodical test and inspection of its meters in order to maintain a high standard of accuracy and to conform with the regulations of the Public Service Commission. Reference: 807 KAR 5:006 Section 10, 16, 17, 18; 807 KAR 5:041.

The Cooperative will make additional tests of meters at the request of members, not to exceed once each twelve (12) months and upon an advance payment of twenty (\$20.00) dollars. The member shall be given the opportunity of being present for the test. The cost of testing the meter found to be inaccurate shall be borne by the Cooperative and the twenty (\$20.00) dollar fee shall be returned to the member.

No fee shall be charged for testing any meter if more than eight (8) years has elapsed since the last test date.

DATE OF ISSUE January 19, 2010

DATE EFFECTIVE Feb 2/10/2010

ISSUED BY Michael T. Miller President & CEO
NAME TITLE

411 Ring Road
Elizabethtown, KY 42701-6767
PURSUANT TO 807 KAR 5:011 SECTION 9(1)
ADDRESS

KENTUCKY PUBLIC SERVICE COMMISSION
JEFF R. DEROUEN EXECUTIVE DIRECTOR
DATE 2/10/2010
SIGNATURE <u>Burt Kirtley</u>

C 8/29/10