

ENG

Shelby Rural Electric Cooperative Corporation
Shelbyville, Kentucky

P.S.C. No. 3
Revised Sheet No. 5.3
Cancelling P.S.C. No. 3
Original Sheet No. 5.3

SCHEDULE A-1-W/H (Cont.)

FARM AND HOME SERVICE WITH STORAGE-TYPE WATER HEATER

Conditions of Service

1. The consumer shall install and operate in regular use a standard approved storage type of electric water heater and shall have no non-electric household water heating device in use during any part of the year (such as heating coils in a fuel-burning range or furnace).
2. Regardless of number of storage type water heaters connected to any single service only one block of 300 kwh per month at 1¢ per kwh will be allowed for any single service.
3. The standard approved type of water heater shall consist of an insulated tank containing two thermostatically controlled, non-inductive heating elements, so connected that only one element is permitted to operate any time. The capacity of the tank shall be sufficient to furnish an ample supply of hot water but in no case shall it be less than 30 gallons. The wattage of the heating elements may be a maximum of 4,500 watts on the upper element and a maximum of 3,000 watts on the lower element. The entire installation shall be subject to the approval of the cooperative including the insulation and size of the tank, the wiring and the size of the heating elements.
4. Provision shall be made in the consumer's water heater wiring installation for an automatic control device which the cooperative may install at its discretion.

(C)
(C)

1-26-62

20/gal
30/gal

CHECKED
APR 22 1959
BY *hw*

FILED

APR 17 1959

**PUBLIC SERVICE
COMMISSION**

Date of Issue - April 10, 1959

Date Effective - April 30, 1959

Issued by

J. C. Long

Manager
Title

Shelbyville, Kentucky