

FOR All Territory Served

PSC KY NO. 9

Original SHEET NO. 253.1

CANCELLING PSC KY NO. 8


Original SHEET NO. 30

Shelby Energy Cooperative, Inc.
Shelbyville, Kentucky
(NAME OF UTILITY)

RULES AND REGULATIONS

53. ENERGY EMERGENCY CONTROL PROGRAM (continued)

4. EKPC will notify Shelby Energy to initiate its Voltage Reduction Procedure, Appendix D.
5. EKPC will notify Shelby Energy and EKPC and Shelby Energy will initiate media appeal for general Voluntary Load Reduction Procedure, Appendix E.
6. EKPC will, in coordination with other Kentucky electric utilities, request the Governor to declare a statewide Energy Emergency.
7. EKPC will request Shelby Energy to initiate mandatory load reduction of up to twenty percent (20%) in five percent (5%) steps, Appendix F.



DATE OF ISSUE April 24, 2013

MONTH / DATE / YEAR

DATE EFFECTIVE October 1, 2013

MONTH / DATE / YEAR

ISSUED BY _____

SIGNATURE OF OFFICER

TITLE President and CEO

BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE COMMISSION IN CASE NO. _____ DATED _____

KENTUCKY PUBLIC SERVICE COMMISSION
JEFF R. DEROUEN EXECUTIVE DIRECTOR
TARIFF BRANCH <i>Beant Kintley</i>
EFFECTIVE 10/1/2013 PURSUANT TO 807 KAR 5.011 SECTION 9 (1)

FOR All Territory Served

PSC KY NO. 9

Original SHEET NO. 253.9

CANCELLING PSC KY NO. 8

Original SHEET NO. 37

Shelby Energy Cooperative, Inc.
Shelbyville, Kentucky
(NAME OF UTILITY)

RULES AND REGULATIONS

53. ENERGY EMERGENCY CONTROL PROGRAM (continued)

APPENDIX "F"

MANDATORY LOAD CURTAILMENT PROCEDURE

Objective:

- (T) To reduce demand on Shelby Energy's system over the period during which an electric energy shortage is anticipated by interrupting firm member load in five percent (5%) blocks up to a total of twenty percent (20%) of the system load.

Criteria:

This procedure is implemented when requested by the EKPC System Operator. This procedure will only be requested after the Governor of Kentucky has issued a statewide State of Emergency Order.

Procedures:

- (T) Shelby Energy will immediately dispatch personnel to interrupt service to member loads to achieve the reduction requested by EKPC. This may be achieved by interrupting services to certain nonessential loads for the entire period of the emergency or by rotating outages to various substation feeder circuits. Shelby Energy's specific plan is on file in its office.

CANCELLED
DEC 30 2017
KENTUCKY PUBLIC SERVICE COMMISSION

DATE OF ISSUE April 24, 2013
MONTH / DATE / YEAR

DATE EFFECTIVE October 1, 2013
MONTH / DATE / YEAR

ISSUED BY *Debra J. Martin*
SIGNATURE OF OFFICER

TITLE President and CEO

BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE COMMISSION IN CASE NO. _____ DATED _____

KENTUCKY PUBLIC SERVICE COMMISSION
JEFF R. DEROUEN EXECUTIVE DIRECTOR
TARIFF BRANCH <i>Brent Kinley</i>
EFFECTIVE 10/1/2013 PURSUANT TO 807 KAR 5.011 SECTION 9 (1)