

FOR ENTIRE TERRITORY SERVED

P. S. C. KY. NO. 5

1st Revised SHEET NO. 14

CANCELLING P.S.C. KY. NO. 5

Original SHEET NO. 14

SOUTH KENTUCKY RECC
SOMERSET, KENTUCKY 42501

RULES AND REGULATIONS

F. LINE EXTENSIONS (Continued)

30. UNDERGROUND EXTENSIONS (Residential Subdivision)

- 6. an overhead service line to the applicant's meter base, whichever is greater and only the difference after giving such credit will be required as a deposit. Service lines to house (provided by developer) shall be installed and ready for inspection at the same time as the residence. Trench is to be left open until inspection has been made. If the Cooperative provides secondary service lines, applicant shall pay the "estimated average cost differential" between overhead and underground service.
- 7. The requirements as to wiring specifications of the utility and those of any regulatory body having jurisdiction must be followed. The Cooperative's Rates, Rules and Regulations for furnishing electric service apply in the case of underground service and overhead service alike.
- 8. A copy of the current cost differential will be kept on file in the Cooperative's office at all times. (File annually with Commission).

31. UNDERGROUND SERVICE - (Individual)

Underground service will be provided to residential members under the following conditions:

- (a) The load's main entrance is 150 amps or greater.
- (b) The member must furnish the raceway* from the transformer pole to the meter base.
- (c) The distance of the service is not to exceed 200' from base of the transformer pole to the meter base.
- (d) The Cooperative will open and close the necessary trench and the member shall pay the actual cost of this, or if the member chooses, he can open and close the trench in which case there will be no charge made by the Cooperative.

EFFECTIVE

*UNDERGROUND RACEWAY-can be conduit (metal or PVC), drainage pipe (rigid or flexible), or other suitable protective raceway approved by the cooperative that conductors can be enclosed in. Three inch ¹⁰⁻¹⁸⁻⁸² conduit must be used when service goes under road, driveway, patio, etc. ^{larger size needed. Section 9(1)}

DATE OF ISSUE SEPTEMBER 29, 1982 DATE EFFECTIVE OCTOBER 18, 1982
 ISSUED BY Henry Schuchert MANAGER P.O. BOX 910 SOMERSET, KENTUCKY 42501
 Name of Officer Title Address