

SOUTH KENTUCKY R.E.C.C
SOMERSET, KENTUCKY 42501

FOR: ENTIRE TERRITORY SERVED
P.S.C. KY. NO. 7
ORIGINAL SHEET NO. R-22
CANCELLING P.S.C.KY.NO.6
_____ SHEET NO. _____

RULES AND REGULATIONS

6.60 UNDERGROUND EXTENSION - RESIDENTIAL SUBDIVISION

The Cooperative will install underground distribution lines to a residential subdivision under the following conditions:

- (a) The subdivision being developed must consist of a tract of land which is divided into ten(10) or more lots for the construction of new residential buildings or the land on which is constructed two (2) or more new multiple occupancy buildings (refer to PSC Electric rules, Appendix A for definition of terms).
- (b) Developer or owner of subdivision shall be required to advance to the Cooperative a non-refundable payment in an amount equal to an "estimated average cost differential", if any, between the average or representative cost of underground distribution systems in residential subdivisions and of equivalent overhead distribution systems within the utility service areas. If the applicant is required to deposit the entire estimated cost of the extensions, the amount in excess of the normal charge for underground extensions shall be refunded to the applicant over a ten (10) year period as provided in Public Service Commission 807 KAR 5:041, Section 11.
- (c) The Cooperative will construct underground distribution facilities in the subdivision adequate to render single-phase 120/240 volt service.
- (d) Three phase primary mains or feeders required within a subdivision to supply local distribution or to serve individual three phase loads may be overhead
- (e) Developer or successor in title shall grant a right-of-way satisfactory to the Cooperative for the installation operation and maintenance of its underground facilities.

CANCELLED

January 4, 2021

**KENTUCKY PUBLIC
SERVICE COMMISSION**

PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE

OCT 15 1992

PURSUANT TO 807 KAR 5:011,
SECTION 1, 1992

DATE OF ISSUE: JULY 22, 1992

DATE EFFECTIVE: AUGUST 1, 1992

ISSUED BY: *Kath Sloan* PRESIDENT/GEN. MANAGER
SOUTH KENTUCKY R.E.C.C. P.O. BOX 910, SOMERSET, KENTUCKY 42502
Issued by authority of an order of the Public Service Commission of
Kentucky in Case No. _____ dated _____.

SOUTH KENTUCKY R.E.C.C.
SOMERSET, KENTUCKY 42501

FOR: ENTIRE TERRITORY SERVED
P.S.C. KY. NO. 7
ORIGINAL SHEET NO. R-23
CANCELLING P.S.C.KY.NO.6
SHEET NO. _____

RULES AND REGULATIONS

- (f) If developer provides and installs the secondary service lines to the residence from service pedestal located on easement, the Cooperative shall give the applicant credit in computing the entire estimated cost of the extensions for \$50.00 (fifty dollars) or the equivalent cost of an overhead service line to the applicant's meter base, whichever is greater and only the difference after giving such credit will be required as a deposit. Service lines to house (provided by developer) shall be installed and ready for inspection at the same time as the residence. Trench is to be left open until inspection has been made. If the Cooperative provides secondary service lines, applicant shall pay the "estimated average cost differential" between overhead and underground service.
- (g) The requirements as to wiring specifications of the utility and those of any regulatory body having jurisdiction must be followed. The Cooperative's Rates, Rules and Regulations for furnishing electric service apply in the case of underground service and overhead service alike.
- (h) A copy of the current cost differential will be kept on file in the Cooperative's office at all times. (Filed annually with Commission).

6.70 UNDERGROUND SERVICE - INDIVIDUAL

Underground service will be provided to residential members under the following conditions:

- (a) If the load's main entrance is 150 - 200 amp, the member must furnish the raceway from the transformer pole to the meter base. The raceway material will be Schedule 40 PVC - Two and one half inches (2 1/2") in diameter and will include two (2) ten foot (10') sections for the pole along with a weatherhead. A fiber pull rope shall be installed to pull conductors.
- (b) For a 400 amp main entrance there shall be two (2) raceways, each with the raceway material installed as described in (a) above.
- (c) The distance of the service is not to exceed 200' from base of the transformer pole to the meter base.
- (d) It is the consumers responsibility to open and close the necessary trench.

CANCELLED
January 4, 2021
**KENTUCKY PUBLIC
SERVICE COMMISSION**

PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE

DATE OF ISSUE: JULY 22, 1992

DATE EFFECTIVE: AUGUST 31, 1992

ISSUED BY: Keith Sloan PRESIDENT & MANAGER
SOUTH KENTUCKY R.E.C.C. P.O. BOX 910, SOMERSET, KENTUCKY 42502
Issued by authority of an order of the Public Service Commission of
Kentucky in Case No. _____ dated _____.

AUG 15 1992
SUBMIT TO 807-493-5011.
BY SECTION 9(1)
PUBLIC SERVICE COMMISSION

SOUTH KENTUCKY R.E.C.C.
SOMERSET, KENTUCKY 42501

FOR: ENTIRE TERRITORY SERVED
P.S.C. KY. NO. 7
ORIGINAL SHEET NO. R-24
CANCELLING P.S.C.KY.NO.6
SHEET NO. _____

RULES AND REGULATIONS

Underground service will not be provided where overhead service is existing nor will overhead service be provided where underground service is existing, except at the member's expense.

6.80 UNDERGROUND SERVICE - COMMERCIAL OR OTHER LARGE SERVICE

- (a) Single phase and three phase loads not able to use self-contained meters will be metered on the pole by current transformer metering equipment.
- (b) The service from the metering point is the consumer's and will be furnished by the consumer. This includes furnishing service wire and conduit to the transformer location. The member will furnish the conduit to go on the pole along with the weatherhead. The Co-op will make connection at the transformer and furnish all metering equipment. The member is responsible to coordinate the conduit on the pole with the Co-op so as to allow the Co-op to ensure that it is done safely.
- (c) It is the consumers responsibility to open and close the necessary trench.
- (d) Problems arising on the service in the future are the member's responsibility. The Co-op will aid in correcting the fault, if possible, but it is recognized that the wire belongs to the member.

6.90 OBTAINING RIGHT-OF-WAY EASEMENTS

- (a) Obtaining right-of-way easements shall be the responsibility of the Cooperative.
- (b) If the Cooperative incurs cost in obtaining right-of-way easements, that cost shall be included in the total per foot cost of the line extension, and shall be apportioned among the Cooperative and the consumer in accordance with the applicable extension regulation.

CANCELLED

January 4, 2021

**KENTUCKY PUBLIC
SERVICE COMMISSION**

PUBLIC SERVICE COMMISSION
OF KENTUCKY
EFFECTIVE

OCT 15 1992

DATE OF ISSUE: JULY 22, 1992

DATE EFFECTIVE: AUGUST 9, 1992

ISSUED BY: Keith Sloan PRESIDENT/GEN. MANAGER
SOUTH KENTUCKY R.E.C.C. P.O. BOX 910, SOMERSET, KENTUCKY 42502
Issued by authority of an order of the Public Service Commission of
Kentucky in Case No. _____ dated _____.

PURSUANT TO 997 KAR 5:011.
SECTION 9(4)
PUBLIC SERVICE COMMISSION