LOUISVILLE GAS AND ELECTRIC COMPANY

Original SHEET NO

SHEET NO ...

14

CANCELLING

P.S.C. OF KY. ELECTRIC NO. 4

STANDARD	R	ID	EF
----------	---	----	----

Supplemental or Standby Service

Applicable:

To Large Commercial Rate LC and Industrial Power Rate LP.

Availability:

Available to customers whose premises or equipment are regularly supplied with electric energy from generating facilities other than those of Company and who desire to contract with Company for reserve, breakdown, supplemental or standby service.

Rate:

Electric service actually used each month will be charged for in accordance with the provisions of the applicable rate schedule; provided, however, that the monthly bill shall in no case be less than an amount calculated at the rate of \$4.25 per kilowatt applied to the Contract Demand.

Contract Demand:

Contract Demand is defined as the number of kilowatts mutually agreed upon as representing customer's maximum service requirements and contracted for by customer; provided, however, if such number of kilowatts is exceeded by a recorded demand, such recorded demand shall become the new contract demand commencing with the month in which recorded and continuing for the remaining term of the contract or until superseded by a higher recorded demand.

Special Terms and Conditions:

- a. In order to protect its equipment from overload damage, Company may require customer to install at his own expense an approved shunt trip type breaker for secondary voltages and an approved automatic pole mounted disconnect for primary service. Such circuit breakers shall be under the sole control of the Company and will be set by the Company to break the connection with its service in the event customer's demand materially exceeds that contracted for.
- b. Company will provide meter enclosures and furnish, place and maintain necessary suitable meters for measurement of service rendered here-under. Customer will be responsible for installing and wiring the respective meter enclosures.
 C. HECKED
- c. Customer will be required at all times to maintain a power factor of not less than 80% lagging.
- d. In the event customer's use of service is internyitten. Company to install to violent fluctuations, the Company will require customer to install

DATE OF ISSUE	January 26, 1982	DATE EFFECTIVE_	January 1, 1982J ³
ISSUED BY	R. L. Koyer		ouisville, Kentucky
	NAME	TITLE	ADDRESS
Issued pursuant	to an Order of the	PSC of Ky. in Case No.	8284 dated 1/4/82

Т