## LOUISVILLE GAS AND ELECTRIC COMPANY

	9th	Rev.	_SHEET	NO3
CANCELLING			_	_

P.S.C. OF KY. ELECTRIC NO. 4

I

CTANDARD	πυνα	SCHEDULE
DIAMBAND	NATE	מתוטענונוטע

WH

Water Heating Rate

# Applicable:

In all territory served.

### Availability - RESTRICTED:

Available to residential and commercial customers for electric service to automatic storage electric water heaters of approved type, in conjunction with electric service for other purposes at the same location, under the terms and conditions herein specified UBLThis Wrate oschedule will continue to be available only to customers that we're we're we're we're on August 20, 1974, and will not be available for the addition of new customers.

APR 2 0 1989

#### Rate:

4.771¢ per kilowatt-hour.

PURSUANT 70 807 KAR 5:011. SECTION 9/1),

### Fuel Clause:

The monthly amount computed at the charges specified above shall be increased or decreased in accordance with the Fuel Clause set forth on Sheet No. 24 of this Tariff.

### Minimum Bill:

\$2.05 per month per heater.

#### Prompt Payment Provision:

The monthly bill will be rendered at the above net charges (including net minimum bills when applicable) plus an amount equivalent to 5% thereof, which amount will be deducted provided bill is paid within 15 days from date.

#### Special Terms and Conditions:

- 1. To be eligible for service under this rate, water heaters must conform to the specifications herein set forth. Any water heater which does not conform to these specifications will be billed under the rate applicable to other electric service at the same premises.
- 2. Approved water heaters shall be of the automatic insulated storage type having a tank size not less than 30 gallons, equipped with either one or two 240-volt non-inductive heating elements, each controlled by a separate thermostat. Two-element heaters shall be so connected that only one element can be in operation at any one time.
- 3. The water heater shall be served at 240 volts (nominal) through a separate meter over a special circuit run in conduit or approved flexible metallic cable with no service outlets in the circuit or on the heater.

April 20, 1989 DATE EFFECTIVE\_ DATE OF ISSUE Louisville, Kentucky Roy President ISSUED BY\_ TITLE